

PROPERTY APPRAISER OF MIAMI-DADE COUNTY

Summary Report


Generated On: 10/07/2025

PROPERTY INFORMA	TION
Folio	03-4108-006-2040
Property Address	201 ALHAMBRA CIR CORAL GABLES, FL 33134-0000
Owner	EVELYN L GOLDBLOOM TRS & , GOLDBLOOM FAMILY LTD
Mailing Address	201 ALHAMBRA CIRCLE STE 514 CORAL GABLES, FL 33134-5105
Primary Zone	5005 MIXED-USE 3
Primary Land Use	1813 OFFICE BUILDING - MULTISTORY : OFFICE BUILDING
Beds / Baths /Half	0/0/0
Floors	13
Living Units	0
Actual Area	
Living Area	
Adjusted Area	447,478 Sq.Ft
Lot Size	51,762 Sq.Ft
Year Built	1973

ASSESSMENT INFORMATION			
Year	2025	2024	2023
Land Value	\$15,528,600	\$15,528,600	\$14,234,550
Building Value	\$33,071,400	\$31,087,400	\$33,645,450
Extra Feature Value	\$0	\$0	\$0
Market Value	\$48,600,000	\$46,616,000	\$47,880,000
Assessed Value	\$48,600,000	\$46,616,000	\$46,524,500

BENEFITS INFORMATION						
Benefit	Туре	2025 2024	2023			
Non-Homestead Cap	Assessment Reduction	\$	1,355,500			
Note: Not all benefits are applicable to all Taxable Values (i.e. County, School Board, City, Regional).						

SHORT LEGAL DESCRIPTION
CORAL GABLES SEC K PB 8-33
LOTS 15 & 16 LESS BEG 3.21FTW OF
NE COR OF LOT 15 S85FT SWLY
21.21FT E35FT N100FT W20FT TO
POB & LOTS 17 THRU 34 & PORT OF



	A VIII		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1							
TAXABLE VALUE INFORMA	TAXABLE VALUE INFORMATION									
Year	2025	2024	2023							
COUNTY										
Exemption Value	\$0	\$0	\$0							
Taxable Value	\$48,600,000	\$46,616,000	\$46,524,500							
SCHOOL BOARD										
Exemption Value	\$0	\$0	\$0							
Taxable Value	\$48,600,000	\$46,616,000	\$47,880,000							
CITY										
Exemption Value	\$0	\$0	\$0							
Taxable Value	\$48,600,000	\$46,616,000	\$46,524,500							
REGIONAL										
Exemption Value	\$0	\$0	\$0							
Taxable Value	\$48,600,000	\$46,616,000	\$46,524,500							

SALES INFORM	IATION		
Previous Sale	Price	OR Book- Page	Qualification Description
04/01/2008	\$100	26362- 1481	Sales which are disqualified as a result of examination of the deed
01/01/2006	\$0	24213- 0397	Sales which are disqualified as a result of examination of the deed
10/01/2005	\$0	23913- 3881	Sales which are disqualified as a result of examination of the deed
06/01/1998	\$0	00000- 00000	Sales which are disqualified as a result of examination of the deed

The information contained herein is for ad valorem tax assessment purposes only. The Property Appraiser of Miami-Dade County is continually editing and updating the tax roll. This website may not reflect the most current information on record. The Property Appraiser of Miami-Dade County and Miami-Dade County assumes no liability, see full disclaimer and User Agreement at https://www.miamidadepa.gov/pa/disclaimer.page

201 Alhambra Cir – I found a federal tax lien using this address as the home address. However, there is no mailing address and due to the federal shutdown, they are not answering the phone. If the City moves to demolish, the IRS should be served.

Owner (PA and deed and Sunbiz principal and mailing address)

Evelyn L. Goldbloom, Trustee Evelyn L. Goldbloom Revocable Trust Agreement Number 1, dated April 7, 2008 201 Alhambra Circle, Ste 514 Coral Gables, FL 33134-5105

Owner (RA address)

Goldbloom Family, Ltd. c/o Gary Goldbloom Registered Agent 201 Alhambra Circle, Ste 514 Coral Gables, FL 33134-5105 10/7/25, 10:19 AM Search Results



Home Citizen Services Business Services Back to Coral Gabl

Permits and Inspections: Search Results

Logon Help Contact



1 2 3 » >

Permit Search Results

Permit#:	App. Date	Street Address	Туре	Description	Status	Issue Date	Final Date	Fees Due
SE-25-01-6833	01/06/2025	201 ALHAMBRA CIR	SPECIAL EVENTS	CORAL GABLES CHAMBER OF COMMERCE BURGERLISCIOUS EVENT 201 ALHAMBRA CIR	final	01/06/2025	01/06/2025	0.00
CE-23-02-7687	02/06/2023		CODE ENFORCEMENT OFFICER SPECIAL EVENT	CODE ENFORCEMENT OFFICER FEE FOR SPECIAL EVENT BURGERLISCIOUS ON ALHAMBRA CIRCLE 200 BLOCK ON FEBRUARY 9, 2023 HOURS OF MUSIC 5:30PM- 9:30PM	final	02/07/2023	02/07/2023	0.00
FD-22-11-6665	11/18/2022	201 ALHAMBRA CIR	FIRE HYDRANT FLOW TEST	FIRE HYDRANT FLOW TEST FOR PROJECT: 201 ALHAMBRA CIRCLE SUNTRUST PLAZA STE 1200; FLOW HYDRANT #13-02 AT ALHAMBRA CIRCLE & PONCE DE LEON BLVD AND RESIDUAL HYDRANT #09-10 AT ALCAZAR AVENUE & PONCE DE LEON BLVD.	final	11/22/2022	11/22/2022	0.00
FD-22-09-6828	09/29/2022	201 ALHAMBRA CIR	FIRE SPRINKLER SYSTEM	RELOCATION OF 5 SPRINKLER HEADS 14TH FLOOR (TRUIST)	final	11/23/2022	01/31/2023	0.00
PU-21-10-7646	10/21/2021	201 ALHAMBRA CIR	PUBLIC RECORDS SEARCH	Certified copy of plans bl 18063720	final	10/22/2021	10/22/2021	0.00
EX-21-10-7358	10/06/2021	201 ALHAMBRA CIR	PERMIT EXTENSION & RENEWAL	***RENEWAL FOR BL-18-06- 3720 - 30 DAYS*** COMMERCIAL* REPLACE MAIN ENTRANCE DOOR \$21,600	final	10/07/2021	10/07/2021	0.00
ME-21-08-7464	08/05/2021		MECH COMMERCIAL / RESIDENTIAL WORK	*COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR \$371,019.00	final	10/25/2022	01/06/2023	0.00
EL-21-07-8499	07/30/2021		ELEC COMMERCIAL / RESIDENTIAL WORK	*COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR	final	10/21/2022	06/27/2023	0.00
PL-21-07-8295	07/26/2021		PLUMB COMMERCIAL / RESIDENTIAL WORK	CHANGE OF CONTRACTOR TO ENERGOV PERMIT NO.EDEN- 23-05-0095 PLUMBING WORK FOR COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR \$371,019.00	canceled	10/20/2022	05/04/2023	0.00
UP-21-07-7434	07/07/2021		UPFRONT FEE - THIS IS NOT A PERMIT	UPFRONT FEE FOR ***COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR \$371,019.00	final	07/07/2021	07/07/2021	0.00
BL-21-07-7433	07/07/2021	201 ALHAMBRA CIR	INTERIOR ALTERATION ONLY	*COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR (TRUIST) \$371,019.00	final	05/19/2022	09/15/2023	0.00
PW-21-06-8267	06/22/2021	201 ALHAMBRA CIR	SIDEWALK REPLACEMENT PERMIT	REPAIR SIDEWALK - PONCE + ALCAZAR PER PUBLIC WORKS REQUEST	final	06/28/2021	07/12/2021	0.00
PW-21-06-8266	06/22/2021	201 ALHAMBRA CIR	SIDEWALK REPLACEMENT PERMIT	REPAIR SIDEWALK - PONCE + ALCAZAR PER PUBLIC WORKS REQUEST		ty's Ex	06/22/2021 khibit	#3

0/7/25, 10:19 AM				Search Results				
BL-21-03-8031	03/10/2021	201 ALHAMBRA CIR	GENERAL REPAIRS	COMMERCIAL* REPAIRS TO WATER DAMAGED CARPETS, BASEBOARDS, ETC. \$2,500	final	12/15/2021	12/17/2021	0.00
BL-20-10-7018	10/26/2020		SIGNS	COMMERCIAL - REFACE EXISTING SIGN CABINETS (BBT SUNTRUST) \$9737.90	final	03/25/2021	08/10/2021	0.00
FD-20-06-6984	06/24/2020	201 ALHAMBRA CIR	FIRE SPRINKLER SYSTEM	FIRE SPRINKLERS SUITE 104 CORAL GABLES CHAMBER OF COMMERCE	final	08/06/2020	08/21/2020	0.00
EL-20-06-6349	06/09/2020	201 ALHAMBRA CIR	ELEC LOW VOLTAGE SYSTEM	COMM INTERIOR ALTERATIONS SUITE 104 DATA/ CABLING	final	06/12/2020	08/26/2020	0.00
EL-20-05-6795	05/22/2020	201 ALHAMBRA CIR	ELEC COMMERCIAL / RESIDENTIAL WORK	COMM INTERIOR ALTERATIONS **SUITE 104*** CORAL GABLES CHAMBER OF COMMERCE	final	06/17/2020	08/26/2020	0.00
EL-20-04-6693	04/29/2020	201 ALHAMBRA CIR	ELEC LOW VOLTAGE SYSTEM	ADDING DEVICES TO EXISTING FIRE ALARM SYSTEM DUE TO ALTERATIONS	final	05/20/2020	08/27/2020	0.00
FD-20-04-6610	04/27/2020	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	ADDING DEVICES TO EXISTING FIRE ALARM SYSTEM DUE TO ALTERATIONS (#104 CORAL GABLES CHAMBER OF COMMERCE)	final	06/15/2020	09/02/2020	0.00
ME-20-04-6469	04/21/2020		MECH COMMERCIAL / RESIDENTIAL WORK	COMM INTERIOR ALTERATIONS SUITE 104 CORAL GABLES CHAMBER OF CCOMMERCE \$	final	08/21/2020	09/01/2020	0.00
PL-20-04-6321	04/16/2020		PLUMB COMMERCIAL / RESIDENTIAL WORK	PLUMBING WORK FOR COMM INTERIOR ALTERATIONS SUITE 104 \$	final	06/25/2020	09/03/2020	0.00
BL-20-03-7119	03/16/2020	201 ALHAMBRA CIR	INTERIOR ALTERATION ONLY	COMM INTERIOR ALTERATIONS SUITE 104 CORAL GABLES CHAMBER OF COMMERCE \$100,000	final	06/11/2020	02/22/2021	0.00
FD-19-12-4205	12/12/2019	201 ALHAMBRA CIR	FIRE HYDRANT FLOW TEST	FIRE HYDRANT FLOW TEST, PROJECT: SUNTRUST PLAZA, FLOW HYDRANT #13-02 AT ALHAMBRA CIRCLE & PONCE DE LEON AND RESIDUAL HYDRANT #09-10 AT ALCAZAR AVENUE & PONCE DE LEON.	final	12/18/2019	12/18/2019	0.00
EL-18-06-4051	06/22/2018		ELEC COMMERCIAL / RESIDENTIAL WORK	COMMERCIAL* REPLACE MAIN ENTRANCE DOOR	final	07/17/2018	12/04/2018	0.00
BL-18-06-3720	06/15/2018		DOOR/GARAGE DOOR/SHUTTER/WINDOW	COMMERCIAL* REPLACE MAIN ENTRANCE DOOR \$21,600	final	07/17/2018	11/04/2021	0.00
AB-18-06-2994	06/05/2018		BOA COMPLETE (LESS THAN \$75,000)	COMMERCIAL* REPLACE MAIN ENTRANCE DOOR \$21600	final	06/05/2018	11/04/2021	0.00
FD-17-10-1213	10/04/2017	201 ALHAMBRA CIR	FIRE HYDRANT FLOW TEST	FIRE HYDRANT FLOW TEST FLOW HYDRANT #13-02 @ ALAHMBRA CIR & PONCE DE LEON BLVD AND RESIDUAL HYDRANT #09-10 @ ALCAZAR AVE & PONCE DE LEON BLVD	final	10/30/2017	10/30/2017	0.00
PU-17-07-2252	07/26/2017	201 ALHAMBRA CIR	PUBLIC RECORDS SEARCH	REQUEST FOR DUPLICATE PLANS FOR INSPECTIONS ONE TENANT SIGN AND WINDOW SIGNAGE (INLINGUA) \$1,715	final	07/26/2017	07/26/2017	0.00
EX-17-06-2544	06/28/2017	201 ALHAMBRA CIR	PERMIT EXTENSION & RENEWAL	EXTENSION FOR BL-14-02- 1758 / ONE TENANT SIGN AND WINDOW SIGNAGE (INLINGUA) \$1,715	final	07/13/2017	07/13/2017	0.00
EX-16-07-7557	07/27/2016	201 ALHAMBRA CIR	PERMIT EXTENSION & RENEWAL	PERMIT RENEWAL FOR EL-15- 09-4452	final	07/27/2016	07/27/2016	0.00
EL-15-12-4649	12/01/2015		ELEC COMMERCIAL / RESIDENTIAL WORK	ACCESS CONTROL & CCTV SYSTEM	final	12/09/2015	02/17/2016	0.00
EL-15-12-4648	12/01/2015		ELEC LOW VOLTAGE SYSTEM	ACCESS CONTROL & CCTV SYSTEM	canceled		05/23/2016	0.00

10/7/25, 10:19 AM				Search Results				
FD-15-11-6399	11/30/2015	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	ACCESS CONTROL & CCTV SYSTEM # 900	final	12/09/2015	06/28/2016	0.00
EL-15-10-4322	10/01/2015	201 ALHAMBRA CIR	ELEC LOW VOLTAGE SYSTEM	INSTALL ACCESS CONTROL SYSTEM (SUITE 610) LOW VOLT FOR FIRE ALARM	final	12/16/2015	10/21/2022	0.00
FD-15-09-5118	09/30/2015	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	INSTALL ACCESS CONTROL SYSTEM (SUITE 610) \$19,309	issued	11/24/2015		0.00
EL-15-09-4452	09/18/2015	201 ALHAMBRA CIR	ELEC LOW VOLTAGE SYSTEM	INSTALL GENERAL ALARM RELAYS TO EXISITNG FIRE ALARM SYSTEM FOR DOOR RELEASE (SUITE 601)	final	09/21/2015	01/25/2017	0.00
EL-15-09-4451	09/18/2015		ELECTRICAL COMMERCIAL /RESIDENTIAL WORK	INSTALL POWER BOOSTER AND NOTIFICATION DEVICES TO EXISTING FIRE ALARM (9TH FLOOR)	final	09/21/2015	10/22/2015	0.00
FD-15-09-4438	09/17/2015	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	INSTALL GENERAL ALARM RELAYS TO EXISITNG FIRE ALARM SYSTEM FOR DOOR RELEASE (SUITE 601) \$2,318	final	09/21/2015	01/25/2017	0.00
FD-15-09-4437	09/17/2015	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	INSTALL POWER BOOSTER AND NOTIFICATION DEVICES TO EXISTING FIRE ALARM (9TH FLOOR) \$6,456	final	09/21/2015	10/22/2015	0.00
PL-15-09-3935	09/09/2015		PLUMB COMMERCIAL / RESIDENTIAL WORK	PLUMBING WORK FOR KITCHEN	final	09/11/2015	10/29/2015	0.00
RV-15-08-4174	08/05/2015	201 ALHAMBRA CIR	REVISION TO PERMIT	REVISION- ARCHITECTURAL,ELECTRICAL, PLUMBING PAGES	final	08/25/2015	08/25/2015	0.00
FD-15-06-5037	06/11/2015	201 ALHAMBRA CIR	FIRE SPRINKLER SYSTEM	FIRE SPRINKLERS (T.Y. LIN / H.J ROSS) SUITE 900 \$4,500	final	08/06/2015	09/09/2015	0.00
ZN-15-03-5414	03/31/2015	201 ALHAMBRA CIR	PAINT / RESURFACE FL / CLEAN	PAINT EXT BUILDING TRIM BAND (BRONZE) \$10,000	canceled	04/01/2015	09/23/2021	0.00
AB-15-03-5412	03/31/2015		BOA COMPLETE (LESS THAN \$75,000)	PAINT EXT BUILDING TRIM (BRONZE) \$10,000	canceled	03/31/2015	02/19/2023	0.00
PL-15-01-0959	01/22/2015		PLUMB COMMERCIAL / RESIDENTIAL WORK	PLUMBING WORK FOR COMMERICIAL INTERIOR RENOVATIONS SUITE 900	final	04/22/2015	04/23/2015	0.00
EL-15-01-0819	01/21/2015		ELEC COMMERCIAL / RESIDENTIAL WORK	COMMERICIAL INTERIOR RENOVATIONS SUITE 900 72 L.IGHT SOCKETS; 31 ROUGH IN OUTLETS AND 5 COMMERCIAL OUTLETS	final	03/13/2015	12/08/2015	0.00
ME-15-01-0736	01/20/2015		MECH COMMERCIAL / RESIDENTIAL WORK	REPLACE VAV`S AND INSTALL NEW DUCTWORK TO THE SPACE.	final	02/09/2015	09/10/2015	0.00
FD-14-11-3924	11/10/2014	201 ALHAMBRA CIR	FIRE ALARM SYSTEM	INSTALL POWER EXPANDER AND ADDITIONAL NOTIFICATION DEVICES TO EXISTING FIRE ALARM SYSTEM \$8000 10TH FLOOR	final	11/13/2014	12/10/2014	0.00
EL-14-11-3925	11/10/2014	201 ALHAMBRA CIR	ELEC LOW VOLTAGE SYSTEM	INSTALL POWER EXPANDER AND ADDITIONAL NOTIFICATION DEVICES TO EXISTING FIRE ALARM SYSTEM \$8000	final	11/13/2014	12/04/2014	0.00

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).

BLDB-21-11-0119	FBC Building (Commercial)	Signs	Finaled	11/01/2021	04/23/2025	10/25/2024	INSTALL (2) ELECTRICAL SIGNS, (2) EXISTING & (1) ATM FACE	201 ALHAMBRA CIR
BLDB-22-02-0419	FBC Building (Commercial)	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	02/15/2022	09/20/2023	03/24/2023	TENANT IMPROVEMENT SUITE 1200 (12TH FLOOR)	201 ALHAMBRA CIR
BLDB-22-09-1074	FBC Building (Commercial)	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	09/21/2022	04/01/2024	10/04/2023	INTERIOR ALTERATIONS (USI INSURANCE SERVICES) STE#900	201 ALHAMBRA CIR
BLDB-22-09-1100	FBC Building (Commercial)	Interior Build-Ou t/ Interior Altera tion/Remodel	Cancelled	09/29/2022		10/22/2022	PLEASE RESUBMIT WITH PROPER PERMIT NUMBER, UNDER SUBPERMIT AND FIRE. WRONG PERMIT TYPE	201 ALHAMBRA CIR
CHON-23-05-0168	Change of Contractor	Plumbing	Finaled	05/04/2023		05/19/2023	CHANGE OF CONTRACTOR FROM EDEN PERMIT NO. PL-21-07-8295 - PLU MBING WORK FOR COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR 8371,019.00	201 ALHAMBRA CIR
CHON-23-05-0178	Change of Contractor	Building	Cancelled	05/15/2023		05/17/2023	CANCELLED- SEE CHON-23-05-0168 ***CHANGE OF CONTRACTOR FROM EDEN PERMIT NO. BL-21-07-7433 ***COMMERCIAL*INTERIOR ALTERATIO NS 14TH FLOOR (TRUIST) \$371,019.00***	201 ALHAMBRA CIR
EDEN-23-05-0095	EDEN Legacy Permit	Eden Legacy Pl umbing	Finaled	05/04/2023	11/20/2023	07/07/2023	CHANGE OF CONTRACTOR FROM EDEN PERMIT NO. PL-21-07-8295 - PLU MBING WORK FOR COMMERCIAL*INTERIOR ALTERATIONS 14TH FLOOR 8371.019.00	201 ALHAMBRA CIR
ELEC-21-11-0067	Electrical Commercial	New Constructi on	Finaled	11/03/2021	04/21/2025	10/22/2024	INSTALL (2) ELECTRICAL SIGNS, (2) EXISTING & (1) ATM FACE	201 ALHAMBRA CIR
ELEC-22-03-0326	Electrical Commercial	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	03/29/2022	09/13/2023	03/17/2023	TENANT IMPROVEMENT SUITE 1200 (12TH FLOOR) \$	201 ALHAMBRA CIR
ELEC-22-09-0749	Electrical Commercial	Low Voltage	Finaled	09/19/2022	12/27/2023	05/01/2023	DATA CABLE INSTALLATION. MASTER PERMIT: BL-21-07-7433/SUB PER MIT: EL-21-07-8499	201 ALHAMBRA CIR
ELEC-23-01-0979	Electrical Commercial	Low Voltage	Finaled	01/10/2023	08/28/2023	03/01/2023	Run cató to various locations	201 ALHAMBRA CIR
ELEC-23-02-1048	Electrical Commercial	Special Events	Finaled	02/06/2023	08/08/2023	02/10/2023	SPECIAL EVENT - BURGERLICIOUS- DATE OF EVENT 02/09/2023 - SET UP 2PM - (EVENT START TIME:5:30PM - END TIME: 9:30PM)- (1) GENERATOR	201 ALHAMBRA CIR
ELEC-23-02-1063	Electrical Commercial	Low Voltage - Fi re Alarm	Finaled	02/09/2023	08/23/2023	02/24/2023	SUB PERMIT UNDER MASTER BLDB-22-02-0419 TO ADD DEVICES TO AN EXISTING FIRE ALARM SYSTEM	201 ALHAMBRA CIR
ELEC-23-03-1203	Electrical Commercial	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	03/27/2023	03/12/2024	09/14/2023	INTERIOR ALTERATIONS (USI INSURANCE SERVICES) STE#900	201 ALHAMBRA CIR
ELEC-23-04-1240	Electrical Commercial	Low Voltage	Finaled	04/06/2023	02/26/2024	08/30/2023	LV Data, TV, CCTV, WAPs, and Sound Masking	201 ALHAMBRA CIR
ELEC-23-04-1251	Electrical Commercial	Special Events	Finaled	04/10/2023	10/16/2023	04/29/2023	SPECIAL EVENT- SUPERCARS IN THE GABLES - DATE OF EVENT: 4/29/20 23 - 4/30/2023 - Location Description: In the City Beautiful of Coral Gables, Florid aon Alhambra from Ponce de Leon to Lejeune Road (SW 42 Ave.) Da tes of Event: 04/29/2023 - 04/30/2023	201 ALHAMBRA CIR
ELEC-23-04-1298	Electrical Commercial	Low Voltage	Cancelled	04/21/2023		09/29/2023	INTERIOR ALTERATIONS (USI INSURANCE SERVICES) STE#900	201 ALHAMBRA CIR
ELEC-23-05-1323	Electrical Commercial	Low Voltage - Fi re Alarm	Finaled	05/04/2023	11/08/2023	05/12/2023	Add devices to an existing fire alarm system in suite 900	201 ALHAMBRA CIR
ELEC-23-05-1384	Electrical Commercial	Low Voltage	Expired	05/23/2023	12/13/2023		Low Voltage, Access Control and CCTV	201 ALHAMBRA CIR
ELEC-23-08-1586	Electrical Commercial	Low Voltage	Finaled	08/03/2023	03/27/2024	09/29/2023	INTERIOR ALTERATIONS (USI INSURANCE SERVICES) STE#900	201 ALHAMBRA CIR
ELEC-23-08-1661	Electrical Commercial	Low Voltage - Fi re Alarm	Finaled	08/25/2023	03/06/2024	09/08/2023	Electrical-Access Control	201 ALHAMBRA CIR
ELEC-24-01-2117	Electrical Commercial	Other	Finaled	01/25/2024	07/31/2024	02/02/2024	Install three dedicated circuits for existing over counter receptacles	201 ALHAMBRA CIR
ELEC-24-01-2127	Electrical Commercial	Other	Finaled	01/31/2024	12/22/2025	06/25/2025	Replace wire inside switchboard (damaged due to false contact) on 1st F L. Replace damaged fuse socket inside switchboard on 5th FL	201 ALHAMBRA CIR
ELEC-24-02-2134	Electrical Commercial	Special Events	Finaled	02/02/2024	08/01/2024	02/09/2024	SPECIAL EVENT - BURGERLICIOUS- DATE OF EVENT 02/08/2024 - EVENT TIME: 5:30PM - 9:30PM- (1) GENERATOR	201 ALHAMBRA CIR
ELEC-24-03-2216	Electrical Commercial	Low Voltage - Fi re Alarm	Finaled	03/01/2024	04/01/2025	10/03/2024	INSTALL NEW FIRE ALARM SYSTEM THROUGHOUT ENTIRE BUILDING	201 ALHAMBRA CIR
ELEC-25-02-3207	Electrical Commercial	Special Events	Finaled	02/06/2025	08/10/2025	02/18/2025	SPECIAL EVENT - BURGERLICIOUS- DATE OF EVENT 02/13/2025 - EVENT TIME: 5:30PM - 9:30PM- (1) GENERATOR	201 ALHAMBRA CIR
FIRE-22-10-0263	Fire	Fire Sprinkler	Finaled	10/24/2022	07/31/2023	02/01/2023	relocation of 112 sprinkler heads at 12th floor suite 1200	201 ALHAMBRA CIR
FIRE-22-12-0305	Fire	Fire Alarm	Finaled	12/13/2022	09/18/2023	03/20/2023	SUB PERMIT UNDER MASTER BLDB-22-02-0419 TO ADD DEVICES TO AN EXISTING FIRE ALARM SYSTEM	201 ALHAMBRA CIR
FIRE-23-04-0449	Fire	Fire Alarm	Finaled	04/18/2023		09/25/2023	Add devices to an existing fire alarm system in suite 900	201 ALHAMBRA CIR
FIRE-23-05-0468	Fire	Fire Sprinkler	Finaled	05/02/2023		06/29/2023	Relocation of 42 sprinkler heads	201 ALHAMBRA CIR
FIRE-23-07-0578	Fire	Access Control	Finaled	07/26/2023		09/21/2023	Fire-Access Control	201 ALHAMBRA CIR
FIRE-24-01-0855	Fire	Fire Alarm	Issued	01/26/2024			INSTALL NEW FIRE ALARM SYSTEM THROUGHOUT ENTIRE BUILDING	201 ALHAMBRA CIR
MECB-22-03-0141	Mechanical Commercial	Interior Build-Ou t/ Interior Altera tion/Remodel	Cancelled	03/04/2022		01/06/2023	HVAC, Ducting & Air Distribution	201 ALHAMBRA CIR
MECB-22-03-0157	Mechanical Commercial	New Constructi on	Finaled	03/18/2022	09/12/2023	03/16/2023	TENANT IMPROVEMENT SUITE 1200 (12TH FLOOR) \$	201 ALHAMBRA CIR
MECB-22-10-0402	Mechanical Commercial	Other	Approved/P ay Fees	10/13/2022			HVAC, Ducting, Air Distribution	201 ALHAMBRA CIR
MECB-23-04-0539	Mechanical Commercial	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	04/13/2023	01/16/2024	07/20/2023	INTERIOR ALTERATIONS (USI INSURANCE SERVICES) STE#900	201 ALHAMBRA CIR
PEXT-23-05-0148	Permit Extension/ Renewal	Building	Cancelled	05/04/2023		05/09/2023	CREATED IN ERROR	201 ALHAMBRA CIR
PEXT-24-07-1050	Permit Extension/ Renewal	Electrical	Finaled	07/23/2024		08/02/2024	***08/01/2024***Replace wire inside switchboard (damaged due to false contact) on 1st FL. Replace damaged fuse socket inside switchboard on 5 th FL	201 ALHAMBRA CIR
PEXT-24-09-1190	Permit Extension/ Renewal	Building	Finaled	09/10/2024		09/18/2024	****09/12/2024***INSTALL (2) ELECTRICAL SIGNS, (2) EXISTING & (1) A TM FACE	201 ALHAMBRA CIR
PLUB-22-08-0285	Plumbing Commercial	Interior Build-Ou t/ Interior Altera tion/Remodel	Finaled	08/04/2022	08/28/2023	02/27/2023	TENANT IMPROVEMENT SUITE 1200 (12TH FLOOR)	201 ALHAMBRA CIR
PLUB-23-03-0470	Plumbing Commercial	Other	Finaled	03/20/2023	01/15/2024	07/17/2023	Two sink drain and water supply for two kitchen area, Interior Renovation	201 ALHAMBRA CIR
RECT-23-05-0147	Building Recertification	Recertification	Denied	05/04/2023			BUILDING RECERTIFICATION (YEAR BUILT 1973) CRB Case no 23-6907	201 ALHAMBRA CIR
REVR-23-03-0627	Revision to Permit	Commercial	Finaled	03/02/2023		03/07/2023	REVISION- MECHANICAL **TENANT IMPROVEMENT SUITE 1200 (12TH F LOOR)	201 ALHAMBRA CIR
REVR-23-07-1026	Revision to Permit	Commercial	Denied	07/12/2023			Low Voltage, Access Control and CCTV	201 ALHAMBRA CIR



The City of Coral Gables

Development Services Department City Hall 405 Biltmore Way Coral Gables, Florida 33134

April 24, 2013

Evelyn L. Goldblum (TRS) 201 Alhambra Circle, Suite #514 Coral Gables, FL 33134-5105

LETTER OF BUILDING RECERTIFICATION IN ACCORDANCE WITH SECTION 8-11(f) OF THE CODE OF MIAMI-DADE COUNTY

PROPERTY FOLIO: # 03-4108-006-2040 ADDRESS: 201 Alhambra Circle, Coral Gables, FL

Dear Property Owner/Manager:

This Office is in receipt of your structural and electrical report stating that the above referenced building has been examined and found to be structurally and electrically safe for its continued occupancy.

Based on acceptance of this report, we herewith grant this LETTER OF RECERTIFICATION for the above subject premises in accordance with Section 8-11(f) of the Code of Miami-Dade County.

The expiration date of this approval, as stated in said Code, is 10 years from 2013. This recertification letter does not exclude the building from subsequent inspections as deemed necessary by the Building Official, as specified in the Florida Building Code.

As a routine matter, and in order to avoid possible misunderstanding, nothing in this letter should be construed directly, or indirectly as a guarantee of the safety of any portion of this structure. However, based on the term stated in Section 8-11(f) of the Code, continued occupancy of the building will be permitted in accordance with the minimum procedural guidelines for the recertification structural/electrical report on file with this office.

Yours truly,

Building Official

P.O. Box 141549 Coral Gables, Florida 33114-1549 • Phone: (305) 460-5235 • Fax (305) 460-5261



Development Services Department City Hall 405 Biltmore Way Coral Gables, Florida 33134

4/29/2022

EVELYN L GOLDBLOOM TRS & GOLDBLOOM FAMILY LTD 201 ALHAMBRA CIRCLE STE 514 CORAL GABLES, FL 33134-5105

RE: 201 ALHAMBRA CIR **FOLIO** # 341080062040

VIA CERTIFIED MAIL

7021 2720 0001 4958 8769

COURTESY 1-YEAR NOTICE

Notice of Required Inspection for Recertification of 40 Years or Older Building

Dear Property Owner:

Per the Miami-Dade County Property Appraiser's office the above referenced property address will be forty (40) years old, or older, in 2023 having been built in 1973.

In accordance with the Miami-Dade County Code, Chapter 8, Section 8-11(f), a Recertification Report ("Report") must be submitted for this property to the City of Coral Gables in 2023.

The Architect or Engineer may obtain the required Form, "Minimum Inspection Procedural Guidelines for Building Recertification," from the following link: https://www.miamidade.gov/global/economy/building/40-year-recertification.page The Recertification Report fee of \$500.00 and additional document and filing fees shall be submitted to the Development Services Department, 405 Biltmore Way, 3rd Floor, Coral Gables, Florida, 33134.

Please note the Building Recertification Report must be dated 2023.

Thank you for your prompt attention to this matter.

Manuel Z. Lopez, P.E. Building Official



CITY HALL 405 BILTMORE WAY CORAL GABLES, FL 33134

EVELYN L GOLDBLOOM TRS & GOLDBLOOM FAMILY LTD 201 ALHAMBRA CIRCLE STE 514 CORAL GABLES, FL 33134-5105

1/30/2023

VIA CERTIFIED MAIL

7021 1970 0000 4015 6094

RE: 201 ALHAMBRA CIR **FOLIO** # 03-4108-006-2040

Notice of Required Inspection For Recertification of Building

Process Number: TBD

Dear Property Owner:

Per the Miami-Dade County Property Appraiser's office the above referenced property address is thirty (30) years old, or older, having been built in 1973. In accordance with the Miami-Dade County Code, Chapter 8, Section 8-11(f), a qualified individual must inspect said building and a **completed** Recertification Report ("Report") must be submitted by you to this Department within **ninety** (90) calendar days from the date of this letter. A completed Report includes 1) Cover letters stating the structure meets (or does not meet) the electrical and structural requirements for recertification, 2) Building Structural Report, 3) Building Electrical Report, 4) Parking Lot Illumination Standards Form 5) Parking Lot Guardrails Requirements Form, and 6) (For threshold buildings only) Self-qualification letters from the inspecting engineers with accompanying DBPR proof of specialization. Submittal of the Report does not constitute recertification; it must be <u>approved</u> and the Letter of Recertification must be issued by this Department.

Threshold buildings (i.e. buildings greater than 3 stories or greater than 50 ft tall, or with an Assembly Occupancy>5000 s.f. & Occupant load > 500 people) shall be recertified by Structural and Electrical Professional Engineers only. Self-qualification letters will be required with proof of DBPR structural and electrical specialization.

Any buildings that are not threshold buildings may be recertified by any Florida Registered Architect or Professional Engineer and self-qualification letters will not be required.

If no deficiencies are identified, the structure will only be recertified once the reports and forms have been submitted and approved.

If deficiencies are identified, they shall be reported to the Building Official within 10 days, or within 24 hours if there is an immediate danger identified. A completed report shall be submitted to this Department. In addition, a structural and/or electrical affidavit from the inspector will be required, with additional affidavits every 180 days, as needed so that the building can continue to be occupied while repairs are carried out. The Building Official is able to grant an extension of one hundred fifty (150) calendar days from the due date or the date the deficiencies were identified (whichever is sooner) to allow time to obtain the necessary permits and perform the repairs. The structure will only be recertified once a revised report and all required information is submitted and approved, and all required permits are closed.

Proprietary or modified recertification forms from the inspectors will not be accepted. Only current municipal recertification forms will be accepted. The Architect or Engineer shall obtain the required Forms from the following link:

https://www.miamidade.gov/global/economy/building/recertification.page.

If this is your first time using the online system, please register at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/selfservice/CoralGablesFLProd#/register

You can access your online process using the process number provided above at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/SelfService#/myWork?tab=MyPermits

The Recertification Report fee of \$500.00 and additional document and filing fees shall be paid online at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/SelfService#/payinvoice

Failure to submit the required Report within the allowed time will result in **declaring the structure unsafe** and referring the matter to the City's Construction Regulation Board ("Board") without further notice and a \$600.00 administrative fee will be imposed at that time. The Board may impose additional fines of \$250.00 for each day the violation continues, may enter an order of demolition, and may assess all costs of the proceedings along with the cost of demolition and any other required action.

Please contact Douglas Ramirez at <u>dramirez@coralgables.com</u> regarding any questions concerning building recertification. Thank you for your prompt attention to this matter.

Manuel Z. Lopez, P.E.



CITY HALL 405 BILTMORE WAY CORAL GABLES, FL 33134

4/30/2023

VIA CERTIFIED MAIL

7022 2410 0002 9151 5809

EVELYN L GOLDBLOOM TRS & GOLDBLOOM FAMILY LTD 201 ALHAMBRA CIRCLE STE 514 CORAL GABLES, FL. 33134-5105

RE: 201 ALHAMBRA CIR **FOLIO** # 341080062040

Notice of Required Inspection For Recertification of Building – **OVERDUE NOTICE** Process Number **RECT-xx-xxxx**

Dear Property Owner:

In a certified letter dated 1/30/2023, this Department notified you the property referenced above requires Building Recertification pursuant to Miami-Dade County Code, Chapter 8, Section 8-11(f). The letter informed you it was necessary to submit to this Department a completed Report prepared by a qualified individual within ninety (90) calendar days certifying the structure meets the requirements for recertification.

Please be advised the submittal of the Report is overdue and the **structure has been deemed unsafe** due to non-compliance. This may result in the revocation of the Certificate of Occupancy, as well as being subject to other penalties as provided in the Code. A completed Report includes 1) Cover letters stating the structure meets (or does not meet) the electrical and structural requirements for recertification, 2) Building Structural Report, 3) Building Electrical Report, 4) Parking Lot Illumination Standards Form 5) Parking Lot Guardrails Requirements Form, and 6) (For threshold buildings only) Self-qualification letters from the inspecting engineers with accompanying DBPR proof of specialization. Submittal of the Report does not constitute recertification; it must be **approved** and the Letter of Recertification must be issued by this Department.

See original notice for additional information.

Failure to submit the completed Report within thirty (30) calendar days from the date of this letter will result in forwarding the matter to the City's Construction Regulation Board for further review and determination. A \$600.00 administrative fee will be imposed at that time. The Board may impose additional fines of \$250.00 for each day the violation continues, may enter an order of demolition, and may assess all costs of the proceedings along with the cost of demolition and any other required action.

If this is your first time using the online system, please register at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/selfservice/CoralGablesFLProd#/register

You can access your online process using the process number provided above at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/SelfService#/myWork?tab=MyPermits

The Recertification Report fee of \$500.00 <u>and</u> additional document and filing fees shall be paid online at the following link:

https://coralgablesfl-energovpub.tylerhost.net/Apps/SelfService#/payinvoice

Please govern yourself accordingly.

Sincerely,

Manuel Z. Lopez, P.E.

Deputy Building Official

BEFORE THE CONSTRUCTION REGULATION BOARD FOR THE CITY OF CORAL GABLES

CITY OF CORAL GABLES, Petitioner,

Case No. 23-6907 RECT-23-05-0147

VS.

Certified Mail Return Receipt & Via USPS Regular Mail 7020 2450 0001 8406 2038

Evelyn L. Goldbloom, Trustee Evelyn L. Goldbloom Revocable Trust 201 Alhambra Circle, Ste 514 Coral Gables, FL 33134-5105 Respondent.

NOTICE OF INTENT TO LIEN AND HEARING

Date: October 9, 2025

Re: 201 Alhambra Cir., Coral Gables, FL 33134, CORAL GABLES SEC K PB 8-33, LOTS 15 & 16 LESS BEG 3.21FTW OF NE COR OF LOT 15 S85FT SWLY 21.21FT E35FT N100FT W20FT TO POB & LOTS 17 THRU 34 & PORT OF ALLEY LYG WITHIN CLOSED BY ORD 2011-73 BLK 25, and 03-4108-006-2040 ("Property").

On February 20, 2024, the City's Construction Regulation Board entered an order in this matter imposing a deadline for compliance and providing for the accrual of fines for each day that the non-compliance continues and for payment of administrative and investigative costs, as applicable ("Order"). According to our records, the property has not been recertified & you did not comply with the deadline in the Order or pay the costs. Moreover, fines have accrued that also have not been paid. Therefore, the City intends to record a certified copy of the Order in the Public Records of Miami-Dade County, Florida, which will constitute a lien.

The amount currently due is \$149,250.00, which may be accruing additional fines on a daily basis and may include administrative and investigative costs.

Therefore, this matter is set for hearing before the City's Construction Regulation Board ("Board") in the Fairchild Tropical Boardroom, 427 Biltmore Way, Coral Gables, Florida 33134, on October 20, 2025, at 2:00 p.m. The hearing shall be strictly limited to determining whether and when you corrected the code violations and paid the civil penalties and costs, if any, as required by the Order of the Board previously entered in this case. The Board may also issue an order, having the force of law, commanding whatever steps are necessary to bring a violation into compliance, to enforce Article III of Chapter 105, of the City Code, or as otherwise authorized by Section 101-57 of the City Code. Any applicable fines shall continue to accrue while the hearing is pending and, if you are not successful at the hearing, fines will have accrued retroactive to the deadline in the Order. You shall also be liable for the reasonable costs of the administrative hearing, if you are unsuccessful at the hearing.

Please note that, as provided in the Board's Order and notwithstanding the pending hearing, the Building Official may take further enforcement action, to immediately, and without further order from the Board, order that the structure BE VACATED, boarded, secured, and posted (including, but not limited to, requesting the electric utility to terminate service to the Structure) to prevent further

City's Exhibit #6

occupancy and the City may DEMOLISH the Structure. The City may sell as salvage or require the demolition contractor to dispose of the contents of the Structure. The Board may also enter an order of demolition and assess all costs of the proceedings and demolition and other required action for which the City shall have a lien against the Owner and the Property. Until the Structure is recertified in compliance the terms of the Board's Order, the City shall not issue any further development approvals for the Property, including, but not limited to, building permits, unless the development approval is required to comply with the terms of the Board's Order.

You have the right to be represented by an attorney and may present and question witnesses and evidence; however, formal rules of evidence shall not apply. Failure to appear at the hearing will result in the matter being heard in your absence. Please be advised that if someone other than an attorney will be attending the hearing on your behalf, he or she must provide a power of attorney from you at the time of the hearing. Requests for continuance must be made in writing to Analyn Hernandez, Secretary to the Board, at City of Coral Gables, Development Services Department, 427 Biltmore Way, Coral Gables, FL 33134, ahernandez2@coralgables.com, tel: (305) 460-5250. The Development Services Department's hours are Monday through Friday, 7:30 a.m. to 2:30 p.m. and the main number is (305) 460-5245, ext. 0. Your immediate attention to this matter would be appreciated. Please call me to discuss your options regarding fines associated with this case.

Sincerely,

Analyn Hernandez
Analyn Hernandez

Analyn Hernandez
Secretary to the Board

NOTICES

Any person who acts as a lobbyist pursuant to the City of Coral Gables Ordinance No. 2006-11, must register with the City Clerk, prior to engaging in lobbying activities before the city staff, boards, committees and/or the City Commission. A copy of the Ordinance is available in the Office of the City Clerk, City Hall.

Pursuant to Section 286.0105, Florida Statutes, if a person decides to appeal any decision made by the Board, with respect to any matter considered at such hearing or meeting, he or she will need a record of the proceedings, and that, for such purpose, he or she may need to ensure that a verbatim record of the proceedings is made; which record includes the testimony and evidence upon which the appeal is to be based. Although a court reporter usually attends the hearing at the City's cost, the City is not required to provide a transcript of the hearing, which the Respondent may request at the Respondent's cost.

Any person who needs assistance in another language in order to speak during the public hearing or public comment portion of the meeting should contact the City's ADA Coordinator, Raquel Elejabarrieta, Esq., Director of Labor Relations and Risk Management (E-mail: relejabarrieta@coralgables.com, Telephone: 305-722-8686, TTY/TDD: 305-442-1600), at least three (3) business days before the meeting.

Any person with a disability requiring communication assistance (such as a sign language interpreter or other auxiliary aide or service) in order to attend or participate in the meeting should contact the City's ADA Coordinator, Raquel Elejabarrieta, Esq., Director of Labor Relations and Risk Management (E-mail: relejabarrieta@coralgables.com, Telephone: 305-722-8686, TTY/TDD: 305-442-1600), at least three (3) business days before the meeting.

CC:


Goldbloom Family, Ltd. C/O Gary Goldbloom, Registered Agent 201 Alhambra Circle, Ste 514 Coral Gables, FL 33134-5105 7020 2450 0001 8406 2045



CITY OF CORAL GABLES DEVELOPMENT SERVICES DEPARTMENT Affidavit of Posting

Title of Document Posted: Notice of Intent to Lien and Hearing

I, Sebastian Ramos, DO HEREBY SWEAR/AFFIRM THAT
THE AFOREMENTIONED NOTICE WAS PERSONALLY POSTED, BY ME, AT THE ADDRESS OF 201 Alhambra Cir., ON 10/10/28 AT 2!19 pm.
Schastran Ramos Employee's Printed Name Employee's Signature
STATE OF FLORIDA) ss. COUNTY OF MIAMI-DADE)
Sworn to (or affirmed) and subscribed before me by means of physical presence or online notarization, this day of, in the year 2025, by who is personally known to me.
My Commission Expires:
JORGE PINO Notary Public - State of Florida Commission # HH 439405 My Comm. Expires Dec 28, 2027 Bonded through National Notary Assr. Notary Public





16999

Department of the Treasury - Internal Revenue Service

Form 668 (Y)(c)

Notice of Federal Tax Lien

(Rev. February 2004	4)	Notice	or rederal i	ax Lie		
Area:	ESS/SELF EMPL	OVED APEA #3	For Options	al Use by Recording Office		
	ne: (800) 913-6		354	170319		
Code, we are have been as a demand for there is a lie property below.	e giving a notice ssessed against the payment of the in favor of the longing to this t	that taxes (including that taxes (including the following-named the following taxes on all axpayer for the amount of the taxes on all axpayer for the taxes on all axpayer for the taxes on all taxes on	y interest and per axpayer. We hav nains unpaid. The I property and ri unt of these taxo	nalties) e made erefore, ghts to	CFN 2: OR Bk 3143: 05/08/20 HARVEY I	O19RO282139 3 Ps 1547; (1 ps) 019 08:18:26 RUVIN, CLERK OF COURT ADE COUNTY, FLORIDA
Name of Taxp		DECD & EVELYN D LDBLOOM PER REF		MOO		
Residence		MBRA CIR STE 5 ABLES, FL 33134	· ·			
unless notice	e of the lien is refile following such dat	CORMATION: For each do by the date given in case, operate as a certific	olumn (e), this notic	e shall,		
Kind of Tax (a)	Tax Period Ending (b)	Identifying Number (c)	Date of Assessment (d)	Ref	ay for filing e)	Unpaid Balance of Assessment (f)
1040 1040 1040	12/31/2002 12/31/2002 12/31/2011	XXX-XX-6707 XXX-XX-6707 XXX-XX-6707	06/23/2003 03/02/2017 03/02/2017	07/2 04/0	3/2023 1/2027 1/2027	371363.28 491400.99
Place of Filing	County Dade	y Courthouse County , FL 33130			Total	\$ 862764.27
This notice wa	as prepared and s	signed atBA	ALTIMORE, MI)		, on this,
the24t	th day of Apr	ril , 2019.				
Signature	Elivin Olan	Ceong	Title REVENUE	OFFI	CER	23-08-1818

(NOTE: Certificate of officer authorized by law to take acknowledgment is not essential to the validity of Notice of Federal Tax lien Rev. Rul. 71-466, 1971 - 2 C.B. 409)

(954) 991-4028

Part 1 - Kept By Recording Office

City's Exhibit #9

for MR. C.D. BAILEY





15405 NW 7th Avenue Miami, FL 33169 P (305) 663-1970 TheFalconGroup.us

April 26, 2023

City of Coral Gables
Development Services Department
City Hall
405 Biltmore Way
Coral Gables, FL 33134

RE: 201 Alhambra Circle, Coral Gables FL 33134

Folio # 03-4108-006-2040 - 50 Year Electrical Recertification Report

Y:\Clients\Falcon2022\22-1091\001_50 Yr\02_Assessment\Documents\Electrical\L230426-201 Alhambra-Electrical

Report-Cover Letter.docx

Dear Building Official:

The Falcon Group conducted a 50 Year Electrical Recertification of the referenced building in accordance with the requirements of section 8.11(f) of Miami Dade County Code. Please refer to the attached Electrical Recertification Report, the Illumination Letter, and the Thermography Report for this building. In summary, the Electrical Recertification is not approved as electrical repairs are necessary to meet current standards of safety. Please notice that we have not identified any condition that represents an imminent danger to the occupants of the building. Based on our evaluation, the building is electrically safe for its use and present occupancies at the time of our evaluation. Repairs are required and the building may remain occupied during the repairs. Our evaluation was not exhaustive and was based on our visual observations. Latent safety concerns may not have been visible. Further, deficiencies may have become visible or worse since our evaluation.

Please also note, this report is based upon sampling and is not intended to be an all-inclusive, exhaustive list of each location of repair, scope of work or otherwise. It is recommended the Client retain the services of an engineering firm to prepare project scope and specifications that will include proper detailing, materials, bidding forms and project requirements.

As a routine matter, in order to avoid possible misunderstanding, nothing in this report should be construed directly or indirectly as a guarantee for any portion of the structure. To the best of our knowledge and ability, this report represents an accurate appraisal of the present condition of the building based upon evaluation of observed conditions.

Please contact our office for any additional questions at (305) 663-1970.

Respectfully Submitted,

David S. Riddle, PE, FL #76597 Director of West Palm Beach

Dar 8 Riddle

The Falcon Group



City's Exhibit #10



CASE REFERENCE NUMBER:

REGULATORY AND ECONOMIC RESOURCES DEPARTMENT

David S. Riddle

11805 SW 26th Street, Miami, Florida 33175 786-315-2000 Miamidade.gov/building

MINIMUM INSPECTION PROCEDURAL GUIDELINES FOR BUILDING ELECTRICAL RECERTIFICATION

LICENSEE NAME:

	TITLE: PROFESSIONAL ENGINEER, FL #76597
	ADDRESS: 15405 NW 7th Ave. Miami, FL 33169
JURISDICTION NAME:	13403 WW 7th 7WC. Whallin, 12 33103
	SIGNATURE: Day 8 Riddle
*Use separate sheets for additional responses by referencing	the report number.
1. DESCRIPTION OF BUILDING	
a. Name on Title: SunTrust Plaza	
b. Building Street Address: 201 Alhambra Circle, Coral G	ables, FL 33134 Bldg. #:
c. Legal Description: 21.21FT E35FT N100FT W20FT TO POB L	S LESS BEG 3.21FTW OF NE COR OF LOT 15 S85FT SWLY OTS 17 THRU 34 PORT OF ALLEY LYG WITHIN CLOSED OQ FT OR 18160-1529 0698 5(2) COC 26362-1481 04 Attached:
d. Owner's Name: Evelyn L Goldbloom TRS Goldbloom	n Family LTD
e. Owner's Mailing Addresses: 201 Alhambra Circle Ste 51	4 Coral Gables, FL 33134-5105
f. Folio Number of Property on which Building is Located: (03-4108-006-2040
g. Building Code Occupancy Classification: B	
h. Present use: Commercial	
i. General Description of building (overall description, struct	ural systems, special features):
l · · · · · · · · · · · · · · · · · · ·	f (14) storied (level 13 does not count). Five (5) of stories are f the exposed structural areas, the structural system of the mns, beams, and reinforced concrete slabs.
j. Number of Stories: 13 k. Is this a Thro	eshold Building as per 553.71(12) F.S. (Yes/No): YES
I. Provide an aerial of the property identifying the building b	eing certified on a separate sheet. Attached:
, ,	re assumed to be common and may be present in other

to the owner's representative.

2. INSPECTIONS
a. Date of Notice of Required Inspection:
b. Date(s) of actual inspection: 03/27/23 to: 04/24/23
c. Name and qualifications of licensee submitting report:
David S. Riddle P.E. 76597
d. Are Any Electrical Repairs Required? (YES/NO): YES
If required, describe, and indicate acceptance:
Refer to each section for explanation. All items to be repaired in accordance with the latest adopted edition of the NEC.
e. Can the building continue to be occupied while recertification and repair ongoing? (YES/NO): YES
1. Explanation/Conditions:
The issues identified during the inspection do not represent an imminent danger to the occupants of the building.
3. ELECTRICAL SERVICE
J. LELCTRICAL SERVICE
1. MSB1
a. Size: Voltage (480/277) Amperage (3000) Type: Fuses (3000) Breakers ()
b. Phase: Three-phase () Single-phase ()
c. Condition: Good () Fair () Needs repair ())
Comments: Location: Main Electrical room
Repairs are required as follows:
a. Working space clearance violation. See Annex "A", photos #1, and 2.b. Main services must be identified as "Main 1 of 6". See Annex "A", photo #3.
b. Wall services must be identified as Wall 1 of 0 . See Affilex A , photo #3.
2. FIRE Pump ATS (MSB 2)
a. Size: Voltage (480/277) Amperage (1000) Type: Fuses (200) Breakers ()
b. Phase: Three-phase (💿) Single-phase ()
c. Condition: Good () Fair () Needs repair ()
Comments: Location: Main Electrical room
Repairs are required as follows:
Main services must be identified as "Main 2 of 6". See Annex "A", photo #4.
3. 1st ATS BLDG. EM.CKTs (MSB 2)
a. Size: Voltage (480/277) Amperage (1000) Type: Fuses (300) Breakers ()
b. Phase: Three-phase () Single-phase ()
c. Condition: Good () Fair () Needs repair (•)
Comments: Location: Main Electrical room

Main services must be identified as "Main 3 of 6". See Annex "A", photo #4

Repairs are required as follows:

4. Elevator	ΛΤς /N/	SB 2)													
	Itage	(480/277)	Δ	mperage		1000)	Type:	Fuses	1	400	١	Breakers	1		_
b. Phase:	tuge	Three-p		(©	<u>'</u>	· ·	Single-phase			400	,	DICARCIS	'		,
c. Condition:		Good	masc	1)		air				Ne	eds repair	1	•	_
Comments:								ر Nain Elec	trical:	room	110	.cus repair			
Repairs are re	auired	as follows:				_									
Main services			as "Mai	in 4 of 6".	See	Annex "A"	', photo #4.								
							· ·								
5. H1 (MSB	3)														
a. Size: Vo	ltage	(480/277)) A	mperage	(1200)	Type:	Fuses	(200)	Breakers	()
b. Phase:		Three-p	hase	(•)	S	ingle-phase	()						
c. Condition:		Good		()	F	air	()		Ne	eds repair	(•)
Comments:						L	ocation: N	/lain Elec	trical	room					
Repairs are re	quired	as follows:													
Main services	must k	oe identified a	as "Mai	in 5 of 6".	See	Annex "A"	', photo #5.								
6. Chiller ro															
a. Size: Vo	ltage	(480/277)) A	mperage	(1200)	Type:	Fuses	(1200)	Breakers	()
b. Phase:		Three-p	hase	(●)	S	ingle-phase	()						
c. Condition:		Good		()	F	air	()		Ne	eds repair	(•)
Comments:						L	ocation: N	⁄lain Elec	trical	room					
Repairs are re	quired	as follows:													
Main services	must k	oe identified a	as "Mai	in 6 of 6".	See	Annex "A"	', photo #6.								
4. METE	RING	EQUIPM	ENT												
1. Clearance		Good	l ()			Fair ()			Needs	correction	()
Comments:			•	<u> </u>											
None.															
5. ELECT	RIC F	MOOM													
J. LLLCI	MIC I	COIVI													
1. Clearance		Good	1 /	١			Fair (1			Naads	correction	1	•	٦
Comments:	;s.	0000	' (,			raii (,			iveeus	COTTECTION		•	
Repairs are re	auired	as follows:													
1	-	r Handler – El	ectrica	I & teleph	one	room. Jun	ction box mi	issing co	ver. S	ee Anr	nex "A"	, photo #7.			
		r Handler - Ele		-				_				-	8.		
c. Air Handl	er - Ele	ctrical & tele	phone	room. Rig	id co	onduit deta	iched. See A	nnex "A	", pho	oto #9.					
d. Air Handl	er - Ele	ctrical & tele	phone	room. Op	enin	g in junctio	on box. See A	Annex "A	\" <i>,</i> ph	oto #1	0.				

6.	GUTTE	RS											
1.	Location:					Good	(•)	Needs)
2.	Taps and	fill:				Good	(•)	Needs	repai	ir ()
	mments:												
No	ne.												
7.	FLECT	RICAL PANE	ıs										
"•	LLLCI	MEALIANE											
1.	Panel #:	No Label			Location:	Roof, Ele	v M	achir	ne room				
		20.00.			Good	()			Needs repair	-(•)
Cor	mments:		Size:	400 AMPS	Volt:	480/277			Phases:		`	MLO	,
Rep	pairs are re	quired as follows				,					,		
a. '		roper panel ID.											
b.		roper circuit iden	tificatio	n (circuit direct	ory).								
See	Annex "A"	', photo #11.											
	Danal #	Nachine veen	DNII		l a sation.	Doof Ele		ر : حام م					
2.	Panel #:	Machine room	PINL			Roof, Ele	\ \ \	acmi	ie room	Noods ropair			`
Col	mments:		C:	No rating	Good	(((((((((((((((((((()		Dhasas	Needs repair		NALO)
No			Size:	No rating	Volt:	240/120			Phases:	1 Ty	ype:	MLO	
NO	iie.												
3.	Panel #:	No Label			Location:	Roof, Ele	ev M	achir	ne room				
					Good	()			Needs repair	(•)
Cor	nments:		Size:	600 AMPS	Volt:	480/277			Phases:	-	` vpe:	MLO	•
Rep	oairs are re	quired as follows	:			•					, ·		
Mis	ssing prope	r panel ID. See A	nnex "A	", photo #12.									
4.	Panel #:	No Label			Location:	Chiller ro	om						
					Good	()			Needs repair	(•)
	mments:		Size:	225 AMPS	Volt:	208/120			Phases:	3 Ty	ype:	MLO	
		quired as follows			12								
a. b.		roper panel ID. Se roper circuit iden				nnev "A"	nhot	·n #1	1				
υ.	iviissiiig p	roper circuit iden	tiricatio	ii (circuit direct	.01 y j. 3ee A	illiex A,	priot	.0 π1	 .				
5.	Panel #:	EL			Location:	Level 14	. We	st Ai	r Handler	room			
					Good	()			Needs repair	(•)
Cor	mments:		Size:	60 AMPS	Volt:	208/120			Phases:	-	` vpe:	MLO	•
Rep	pairs are re	quired as follows				•					, ·		
		r circuit identifica		rcuit directory)	. See Annex	κ "A", phot	o #1	5.					
6.	Panel #:	MB1				Level 14	. We	st Ai	r Handler				
					Good	()			Needs repair	(•)
()	mments:		Cizo.	100 AM/DS	\/olt·	202/120			Dhacac	2 Tv	vno.	MIO	

a. Missing proper circuit identification (circuit directory).

Repairs are required as follows:

b. Openings in circuit spaces. See Annex "A", photo #16.

7.	Panel #:	LC			Location:	Level 14.	. West A	ir Handler	room			
					Good	(•)		Needs repair	()
Con	nments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Туре:	MLO	
Nor	ne.											
8.	Panel #:	EH			Location:	Level 14.	. West A	ir Handler	room			
					Good	()		Needs repair	(•)
Con	nments:		Size:	100 AMPS	Volt:	480/277		Phases:	3	Type:	MLO	
		quired as follows:										
Mis	sing prope	r circuit identifica	tion (ci	rcuit directory).	See Annex	"A", phot	o #17.					
_	D = 1 #-	Nie Lebel			1	1 1 4 4	\A/+ A		Flactoria of 0 4	l l-		
9.	Panel #:	No Label				Level 14.	. west A	ur Handier	- Electrical & t	eiepn		oom
Cara			<u> </u>	400 41400	Good	(() () () ())	DI.	Needs repair	- (O)
	nments:		Size:	400 AMPS	Volt:	480/277		Phases:	3	Type:	MLO	
кер а.		quired as follows: oper panel ID. Se		v "A" nhoto #1	Q							
b.		oper circuit ident		•		nnex "A". ı	ohoto #	19.				
~.	ооо р	орол оп облетиван.		(0 00 0 00	0. 17. 000 7.		5.1.0 to 1.1					
10.	Panel #:	Н			Location:	Level 14.	. West A	ir Handler	-Electrical-tele	phon	e room	1
					Good	()		Needs repair	(•)
Con	nments:		Size:	225 AMPS	Volt:	480/277	•	Phases:			MLO	,
Rep	airs are red	quired as follows:				,				′'		
a. ·		oper circuit ident		n (circuit direct	ory). See A	nnex "A", ¡	photo #	20.				
b.	Tapping ir	Main lugs. Repa	ir tappi	ng in panel by u	sing listed	tapping co	nnector	rs. See Ann	ex "A", photo	#21.		
11.	Panel #:	L1			Location:	Level 14.	. West A	ir Handler	-Electrical-tele	phon	e room	1
					Good	()		Needs repair	(•)
	nments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
-		quired as follows:				<i>u</i> - u .						
Mis	sing prope	r circuit identifica	tion (ci	rcuit directory).	See Annex	"A", phot	o #22.					
12	Danal #	L2			Location	Lovel 14	\M/oct A	ir Handlar	Floatrical tala	nhon	o room	
12.	Panel #:	LZ				Level 14.	. west A	ur nanuier	-Electrical-tele	-		1
C			<u>c:</u>	400 41400	Good	200/420)	DI.	Needs repair		O)
	nments:			400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
•		quired as follows: oper circuit ident		n (circuit direct	oryl							
a. b.	• • •	"A", photo #23.	liiicatio	ii (circuit directi	ory).							
.	00071111107	. , , photo 1123.										
13.	Panel #:	L3			Location:	Level 14.	. West A	ir Handler	-Electrical-tele	phon	e room	າ
•					Good	()		Needs repair	•	•)
Con	nments:		Size:	400 AMPS	Volt:	208/120	,	Phases:			MLO	,
		quired as follows:				100,120			-	., , ,	20	
		r circuit identifica		rcuit directory).	See Annex	"A", phot	o #24.					
			•	,,								
14.	Panel #:	MB2			Location:	Level 14.	East Ai	r Handler ı	oom			
					Good	()		Needs repair	(•)
Con	nments:		Size:	60 AMPS	Volt:	208/120	-	Phases:			MLO	-
		quired as follows:				•						
-		r circuit identifica		rcuit directory).	See Annex	"A" <u>,</u> phot	o #25.					
								-				

15. Panel #: MB	Location:	Level 12	. East Air	Handler i	room		
	Good	()		Needs repa	ir ()
Comments: Size: 60 AMPS	Volt:	208/120		Phases:		Type:	
Repairs are required as follows:		_00,0				.,,,	0
a. Missing proper circuit identification (circuit direc	tory)						
b. Openings in circuit spaces.	(O) y /.						
See Annex "A", photo #26.							
ocerument it prioto iizoi							
16. Panel #: MB	Location	Level 12	West Air	r Handler	room		
10. Tuncia. IVID	Good	1	1	Tidilaici	Needs repa	ir ()
Comments: Size: 60 AMPS		200/120	,	Dhasas			
0.20. 007	Volt:	208/120		Phases:	3	Type:	MILO
Repairs are required as follows:							
a. Missing proper circuit identification (circuit direc	tory).						
b. Openings in circuit spaces.							
See Annex "A", photo #27.							
47.0.14.16			144 1 41	!!			
17. Panel #: LC		Level 12.	. West Air	r Handler			
	Good	()		Needs repa		(a)
Comments: Size: 400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
Repairs are required as follows:							
Missing proper circuit identification (circuit directory)	. See Anne	κ "A", phot	o #28.				
18. Panel #: No Label	Location	Level 12.	. West Air	r Handler	-Electrical-te	lephon	e room
	Good	()		Needs repa	ir ()
Comments: Size: 400 AMPS	Volt:	480/277		Phases:	3	Type:	MLO
Repairs are required as follows:							
Missing proper panel ID. See Annex "A", photo #29.							
7.							
19. Panel #: H	Location	Level 12	. West Air	r Handler	-Electrical-te	lephon	e room
	Good	()		Needs repa)
Comments: Size: 225 AMPS	Volt:	480/277		Phases:	3	Type:	
Repairs are required as follows:	voit.	400/277		i ilases.	3	Type.	IVILO
a. Missing proper circuit identification (circuit direc	tory) See A	nnev "A"	nhoto #3(n			
b. Tapping in Main lugs. Repair tapping in panel by			•		ex "Δ" nhọt	o #31	
o. Tupping in Main lugs. Repair tupping in paner by	asing nacca	tapping co	, incetors	. See Aiii	ick A, priot	0 #31.	
20. Panel #: L1	Location	Lovel 12	Mast Air	r Handler	-Electrical-te	lenhon	e room
ZU. Fallel #. LI		/	· vvest All	Handlei			
	Good	()		Needs repa)
Comments: Size: 400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
Repairs are required as follows:							
a. Missing proper circuit identification (circuit direc	tory).						
b. Missing 2 screw(s).							
See Annex "A", photo #32.							
21. Panel #: L2	Location	Level 12.	. West Air	r Handler	-Electrical-te	lephon	e room
	Good	()		Needs repa	ir ()
Comments: Size: 400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
Repairs are required as follows:							
Missing proper circuit identification (circuit directory)	. See Anne	κ "A", phot	o #33.				

Good (●) Needs repair () Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO											
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO None. 23. Panel #: MB	22. Panel #:	L3			Location:	Level 12.	. West	Air Handler	-Electrical-te	ephon	e room
None. Location: Level 11. East Air Handler-Electrical-telephone room Good Needs repair ()					Good	(●)		Needs repa)
23. Panel #: MB	Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
Good () Needs repair (None.										
Good () Needs repair (
Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #34. 24. Panel #: 11L-4 Location: Level 11. East Air Handler-Electrical-telephone room Good () Needs repair (23. Panel #:	MB				Level 11	. East A	Air Handler-		-	
Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #34. 24. Panel #: 11L-4						()		Needs repa		
Missing proper circuit identification (circuit directory). See Annex "A", photo #34. 24. Panel #: 11L-4				60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
24. Panel #: 11L-4	•	•				"- "					
Good () Needs repair (Missing prope	r circuit identifica	ition (ci	rcuit directory). See Annex	k "A", phot	0 #34.				
Good () Needs repair (24 Danal #	111 /			Location	Lovel 11	Foot /	Vir Handlar	Floatrical to	lonbon	
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MCB Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #35. 25. Panel #: 11L-5 Location: Level 11. West Air Handler-Electrical-telephone room Good (24. Panei #:	11L-4				Level 11	East A	air Handier-			
Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #35. 25. Panel #: 11L-5						()		·		
Missing proper circuit identification (circuit directory): See Annex "A", photo #35. 25. Panel #: 11L-5				400 AMPS	Volt:	208/120		Phases:	3	Type:	MCB
25. Panel #: 11L-5 Location: Level 11. West Air Handler-Electrical-telephone room Good (-	•			. C A	. ((A))lt	- 425				
Good (Missing prope	r circuit identifica	ition (ci	rcuit directory). See Annex	("A", pnot	0 #35.				
Good (25 Panel #:	111 E			Location	Lovol 11	Most	Air Handle	r Floctrical t		no room
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO None. 26. Panel #: 11L-6 Location: Level 11. West Air Handler-Electrical-telephone room Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO None. 27. Panel #: MB2 Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #36. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Needs repair ()	23. Fallel #.	111-3					. vvest	All Hallule		•	100111
None. Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO	Commonts		C!	400 41400)	Discourse)
26. Panel #: 11L-6 Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO None. 27. Panel #: MB2 Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC Cocation: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (♠) Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (♠) Needs repair (♠) Needs repair (♠) Needs repair (♠) Needs repair (♠) Needs repair (♠) Needs repair (♠)			Size:	400 AMPS	voit:	208/120		Phases:	3	Type:	MLO
Good (none.										
Good (26 Panel #:	111 6			Location	Lovol 11	Most	Air Handle	r Floctrical t		no room
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO None. 27. Panel #: MB2 Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	20. Fallel #.	111-0					. vvest	All Hallule			۱ ۱۰۰۰۱۱۱
None. 27. Panel #: MB2 Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Needs repa	Commonts		C:	400 41400)	Dhasas)
27. Panel #: MB2 Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:			Size:	400 AIVIPS	voit:	208/120		Phases:	3	Type:	IVILU
Good () Needs repair (None.										
Good () Needs repair (27 Panel #:	MR2			Location:	Lovel 11	Most	Air Handle	r-Electrical-t		ne room
Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair ()) Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair ()) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	27. Fallel #.	IVIDZ				/	vvest	All Hallule			
Repairs are required as follows: a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC	Commonts		C!	COANADC		200/420)	Discourse			
a. Missing proper circuit identification (circuit directory). b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC		auired as fallaus		60 AIVIPS	voit:	208/120		Phases:	3	Type:	MLO
b. Openings in circuit spaces. See Annex "A", photo #36. 28. Panel #: LC	•	•		n (circuit direc	tory						
See Annex "A", photo #36. 28. Panel #: LC Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Needs repair () Needs repair () Needs repair () Needs repair () Needs repair () Needs repair () Repairs are required as follows:			liiicalio	iii (circuit direc	tory).						
28. Panel #: LC Location: Level 11. West Air Handler-Electrical-telephone room											
Good () Needs repair (<u> </u>	, p									
Good () Needs repair (28. Panel #:	LC			Location:	Level 11	. West	Air Handle	r-Electrical-t	elephor	ne room
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:						()				
Repairs are required as follows: Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	Comments:		Size.	400 ΔΜΡς		208/120	,	Phases:	<u> </u>		
Missing proper circuit identification (circuit directory). See Annex "A", photo #37. 29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair (•) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:		guired as follows:		-OU AIVII J	voit.	200/120		1 110303.	5	iype.	IVILO
29. Panel #: No Label Location: Level 11. West Air Handler-Electrical-telephone room Good () Needs repair () Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	-	•		rcuit directory). See Annes	«"A", nhọt	o #37				
Good () Needs repair (•) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	оргорс			- I all all colory	,. 500 / 111110/	, p.100					
Good () Needs repair (•) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:	29. Panel #:	No Label			Location:	Level 11	. West	Air Handle	r-Electrical-t	elephor	ne room
Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:						()				
Repairs are required as follows:	Comments:		Sizo	400 AMPS		/80/277	,	Dhacac	·	•	
·		quired as follows:		-UU AIVIF3	voit.	+00/2//		riidses.	J	Type.	IVILO
	•	•		" nhoto #32							

	H		Location:	Level 11.	. West Air	⁻ Handler	r-Electrical-te	lephon	e room	
			Good	()		Needs repai	ir ()	
Comments:	Size:	225 AMPS	Volt:	208/120	F	Phases:	3	Type:	MLO	
Repairs are requ	uired as follows:									
Missing proper of	circuit identification (c	rcuit directory).	See Annex	ι "A", photo	o #39.					
31. Panel #: L	L1		Location:	Level 11	. West Air	⁻ Handler	r-Electrical-te	lephon	e room	
			Good	()		Needs repai	ir ()	
Comments:	Size:	400 AMPS	Volt:	208/120	F	Phases:	3	Type:	MLO	
Repairs are requ	uired as follows:									
Missing proper of	circuit identification (c	rcuit directory).	See Annex	c "A", photo	o #40.					
32. Panel #: L	L2		Location:	Level 11	. West Air	⁻ Handler	r-Electrical-te	lephon	e room	
			Good	()		Needs repai	ir (
Comments:	Size:	400 AMPS	Volt:	208/120	F	Phases:	3	Type:	MLO	
Repairs are requ										
Missing proper of	circuit identification (c	rcuit directory).	See Annex	("A", photo	o #41.					
33. Panel #: L	L3		Location:	Level 11.	. West Air	Handler	r-Electrical-te			
			Good	()		Needs repai		()	
Comments:	Size:	400 AMPS	Volt:	208/120	F	Phases:	3	Type:	MLO	
Repairs are requ										
Missing proper of	circuit identification (c	rcuit directory).	See Annex	("A", photo	o #42.					
34. Panel #: 1	MB		Location:	Level 10	. West Air	⁻ Handler	r-Electrical-te			
			Good	()		Needs repai	ir ()	
Comments:	Size:	60 AMPS		Level 10. (208/120)	Handler Phases:	Needs repai)	
Comments: Repairs are requ	Size: uired as follows:		Good Volt:	(208/120) F		Needs repai	ir ()	
Comments: Repairs are requ	Size:		Good Volt:	(208/120) F		Needs repai	ir ()	
Comments: Repairs are requ Missing proper o	Size: uired as follows: circuit identification (c		Good Volt: See Annex	(208/120 « "A", photo) F D #43.	Phases:	Needs repairs	ir (Type:	●) MLO	
Comments: Repairs are requ Missing proper o	Size: uired as follows:		Good Volt: See Annex Location:	(208/120 « "A", photo) F D #43.	Phases:	Needs repaid	ir (Type:	MLO e room	
Comments: Repairs are requ Missing proper of	Size: uired as follows: circuit identification (c	rcuit directory).	Good Volt: See Annex Location: Good	(208/120 ("A", photo Level 10.) F D #43. . West Air	Phases: - Handler	Needs repair 3 r-Electrical-te	ir (Type: elephon	●) MLO e room ●)	
Comments: Repairs are requ Missing proper of 35. Panel #: L	Size: uired as follows: circuit identification (c LC Size:	rcuit directory).	Good Volt: See Annex Location:	(208/120 « "A", photo) F D #43. . West Air	Phases:	Needs repaid	ir (Type:	●) MLO e room ●)	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ	Size: uired as follows: circuit identification (c LC Size: uired as follows:	400 AMPS	Good Volt: See Annex Location: Good Volt:	(208/120 ("A", photo Level 10 (208/120) F #43. . West Air)	Phases: - Handler	Needs repair 3 r-Electrical-te	ir (Type: elephon	●) MLO e room ●)	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ	Size: uired as follows: circuit identification (c LC Size:	400 AMPS	Good Volt: See Annex Location: Good Volt:	(208/120 ("A", photo Level 10 (208/120) F #43. . West Air)	Phases: - Handler	Needs repair 3 r-Electrical-te	ir (Type: elephon	●) MLO e room ●)	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c	400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex	(208/120 ("A", photo Level 10 (208/120 ("A", photo)	Phases: Handler Phases:	Needs repair 3 r-Electrical-te Needs repair 3	ir (Type: elephon ir (Type:	e room number of the state of	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of	Size: uired as follows: circuit identification (c LC Size: uired as follows:	400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex Location:	(208/120 ("A", photo Level 10 (208/120 ("A", photo)	Phases: Handler Phases:	Needs repair 3 r-Electrical-te Needs repair 3	ir (Type: elephon ir (Type:	e room number of the company of the	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c	400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex Location: Good	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo ()) #43 West Air) F	Phases: Handler Phases:	Needs repair 3 r-Electrical-te Needs repair 3 r-Electrical-te Needs repair	ir (Type: elephon ir (Type:	e room number of the company of the	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments:	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size:	400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex Location:	(208/120 ("A", photo Level 10 (208/120 ("A", photo) #43 West Air) F	Phases: Handler Phases:	Needs repair 3 r-Electrical-te Needs repair 3 r-Electrical-te Needs repair	ir (Type: elephon ir (Type:	e room number of the company of the	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Repairs are requested from the second term of the se	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows:	400 AMPS frcuit directory).	Good Volt: See Annex Location: Good Volt: See Annex Location: Good	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo ()) #43 West Air) F	Phases: Handler Phases:	Needs repair 3 r-Electrical-te Needs repair 3 r-Electrical-te Needs repair	ir (Type: elephon ir (Type:	e room number of the company of the	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Repairs are requested from the second term of the se	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size:	400 AMPS frcuit directory).	Good Volt: See Annex Location: Good Volt: See Annex Location: Good	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo ()) #43 West Air) F	Phases: Handler Phases:	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs	ir (Type: elephon ir (Type:	e room number of the company of the	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Missing proper of	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows: panel ID. See Annex "A	400 AMPS frcuit directory).	Good Volt: See Annex Location: Good Volt: See Annex Location: Good Volt:	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo (480/277)	Phases: Handler Handler	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs 3	elephonir (Type:	e room room	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Missing proper of	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows:	400 AMPS frcuit directory).	Good Volt: See Annex Location: Good Volt: See Annex Location: Good Volt: Location:	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo (480/277)	Phases: Handler Handler	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs 3	ir (Type: elephon ir (Type: elephon ir (Type:	e room room room mlo	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Missing proper prop	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows: panel ID. See Annex "A	400 AMPS frcuit directory). 400 AMPS 400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo (480/277))	Phases: Handler Phases: Handler	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs 3	ir (Type: elephon ir (Type: elephon ir (Type:	e room e room o) MLO eroom o) MLO	
Comments: Repairs are required. Missing proper of the state of the sta	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows: panel ID. See Annex "A H	400 AMPS 400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: See Annex Location: Good Volt: Location:	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo (480/277)	Phases: Handler Handler	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs 3	ir (Type: elephon ir (Type: elephon ir (Type:	e room e room o) MLO eroom o) MLO	
Comments: Repairs are requ Missing proper of 35. Panel #: L Comments: Repairs are requ Missing proper of 36. Panel #: N Comments: Repairs are requ Missing proper prop	Size: uired as follows: circuit identification (c LC Size: uired as follows: circuit identification (c No Label Size: uired as follows: panel ID. See Annex "A H	400 AMPS frcuit directory). 400 AMPS 400 AMPS 7, photo #45.	Good Volt: See Annex Location: Good Volt: See Annex Location: Good Volt: Location: Good Volt:	(208/120 c "A", photo (208/120 c "A", photo (208/120 c "A", photo (480/277 c 480/277)	Phases: Handler Phases: Handler	Needs repairs 7-Electrical-te Needs repairs 3 7-Electrical-te Needs repairs 3	ir (Type: elephon ir (Type: elephon ir (Type:	e room e room o) MLO eroom o) MLO	

38. Panel #:	L2			Location:	Level 10	. West Air	Handler	-Electrical-tel	ephon	e roor	n
				Good	()		Needs repair	. (•)
Comments:		Size:	400 AMPS	Volt:	208/120	Р	hases:	3	Туре:	MLO	
-	quired as follows:										
Missing proper	r circuit identifica	tion (ci	cuit directory).	See Annex	"A", phot	o #47.					
20 5 1"								<u></u>			
39. Panel #:	L1			Location:	Level 10	. West Air	Handler	-Electrical-tel			n .
C				Good	()		Needs repair	<u> </u>	<u> </u>)
Comments:		Size:	400 AMPS	Volt:	208/120	Р	hases:	3	Type:	MLO	
•	quired as follows: r circuit identifica		cuit directory)	Soo Annov	"A" phot	o #40					
iviissiiig propei	circuit identifica	ition (ci	cuit un ectory).	See Alliex	A , prioti	0 #40.					
40. Panel #:	L3			Location:	Level 10	. West Air	Handler	-Electrical-tel	ephon	e roor	n
				Good	()		Needs repair		•)
Comments:		Size:	No rating	Volt:	208/120	<u>,</u> Р	hases:		Type:		,
	quired as follows:		.		_00,0				.,,,	0	
•	r circuit identifica		cuit directory).	See Annex	"A", phot	o #49.					
41. Panel #:	MB			Location:	Level 10.	East Air H	landler r	oom			
				Good	()		Needs repair	- (\odot)
Comments:		Size:	60 AMPS	Volt:	208/120	P	hases:	3	Type:	MLO	
Repairs are red	quired as follows:										
Missing proper	r circuit identifica	tion (ci	cuit directory).	See Annex	"A", phot	o #50.					
42. Panel #:	MB			Location:	Level 9.	West Air F	Handler-I	Electrical-tele	phone	room	
	MB			Location: Good	(West Air F	Handler-I	Electrical-tele Needs repair		room)
Comments:		Size:	60 AMPS		Level 9. (208/120)	Handler-I	Needs repair		•)
Comments: Repairs are rec	quired as follows:			Good Volt:	(208/120) P		Needs repair	. (•	
Comments: Repairs are rec				Good Volt:	(208/120) P		Needs repair	. (•)
Comments: Repairs are rec Missing proper	quired as follows: r circuit identifica			Good Volt: See Annex	(208/120 "A", photo) P o #51.	hases:	Needs repair	Type:	MLO)
Comments: Repairs are rec	quired as follows:			Good Volt: See Annex Location:	(208/120 "A", photo Level 9.) P o #51.	hases:	Needs repair 3 Electrical-tele	Type:	MLO)
Comments: Repairs are rec Missing proper 43. Panel #:	quired as follows: r circuit identifica	ition (ci	cuit directory).	Good Volt: See Annex Location: Good	(208/120 "A", photo Level 9. (•) P to #51. West Air H	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair	Type:	MLO room)
Comments: Repairs are rec Missing proper 43. Panel #: Comments:	quired as follows: r circuit identifica			Good Volt: See Annex Location:	(208/120 "A", photo Level 9.) P to #51. West Air H	hases:	Needs repair 3 Electrical-tele Needs repair	Type:	MLO room)
Comments: Repairs are rec Missing proper 43. Panel #:	quired as follows: r circuit identifica	ition (ci	cuit directory).	Good Volt: See Annex Location: Good	(208/120 "A", photo Level 9. (•) P to #51. West Air H	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair	Type:	MLO room)
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None.	quired as follows: r circuit identifica LC	ition (ci	cuit directory).	Good Volt: See Annex Location: Good Volt:	(208/120 "A", photo Level 9. () p #51. West Air H) P	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3	phone (MLO room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments:	quired as follows: r circuit identifica	ition (ci	cuit directory).	Good Volt: See Annex Location: Good Volt: Location:	(208/120 "A", photo Level 9. () p #51. West Air H) P	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3	phone Type:	MLO MLO	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #:	quired as follows: r circuit identifica LC	Size:	rcuit directory). 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 "A", photo Level 9. (© 208/120 Level 9.) Po #51. West Air H) P West Air H	Phases: Handler-I Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #:	quired as follows: r circuit identifica LC No Label	Size:	cuit directory).	Good Volt: See Annex Location: Good Volt: Location:	(208/120 "A", photo Level 9. () Po #51. West Air H) P West Air H	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec	quired as follows: r circuit identifica LC No Label	Size:	rcuit directory). 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 "A", photo Level 9. (© 208/120 Level 9.) Po #51. West Air H) P West Air H	Phases: Handler-I Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr	quired as follows: r circuit identifica LC No Label	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 "A", photo Level 9. (© 208/120 Level 9.) Po #51. West Air H) P West Air H	Phases: Handler-I Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr	quired as follows: r circuit identifica LC No Label quired as follows: roper panel ID. roper circuit iden	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 "A", photo Level 9. (© 208/120 Level 9.) Po #51. West Air H) P West Air H	Phases: Handler-I Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr b. Missing pr	quired as follows: r circuit identifica LC No Label quired as follows: roper panel ID. roper circuit iden	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 "A", photo Level 9. (© 208/120 Level 9.) Po #51. West Air H) P West Air H	Phases: Handler-I Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room room room	
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr b. Missing pr	quired as follows: r circuit identifica LC No Label quired as follows: roper panel ID. roper circuit iden	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good	(208/120 208/120 Level 9. (© 208/120 Level 9. (480/277	Po #51. West Air H) P West Air H)	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair	phone Type:	MLO room MLO room MLO	.)
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr b. Missing pr See Annex "A"	quired as follows: r circuit identifica LC No Label quired as follows: roper panel ID. roper circuit iden; , photo #52.	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good Volt:	(208/120 208/120 Level 9. (© 208/120 Level 9. (480/277	Po #51. West Air H) P West Air H)	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair 3	phone (Type:	MLO room MLO room MLO	.)
Comments: Repairs are rec Missing proper 43. Panel #: Comments: None. 44. Panel #: Comments: Repairs are rec a. Missing pr b. Missing pr See Annex "A"	quired as follows: r circuit identifica LC No Label quired as follows: roper panel ID. roper circuit iden; , photo #52.	Size:	400 AMPS 400 AMPS	Good Volt: See Annex Location: Good Volt: Location: Good Volt:	(208/120 208/120 Level 9. (© 208/120 Level 9. (480/277	Po #51. West Air H) P West Air H) P	Phases: Handler-I	Needs repair 3 Electrical-tele Needs repair 3 Electrical-tele Needs repair 3	phone (Type:	MLO Proom MLO MLO	.)

Missing proper circuit identification (circuit directory). See Annex "A", photo #53.

Good (●) Needs repair ()
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO
None.
47. Panel #: L2 Location: Level 9. West Air Handler-Electrical-telephone room.
Good (●) Needs repair ()
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO
None.
TOTAL
48. Panel #: L3 Location: Level 9 West. Air Handler - Electrical & telephone room.
·
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO
Repairs are required as follows:
Missing proper circuit identification (circuit directory). See Annex "A", photo #54.
40 Danel Hr. MD. Legation: Legation Legation and Air Handley record
49. Panel #: MB Location: Level 9. East Air Handler room
Good () Needs repair (●)
Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO
Repairs are required as follows:
Missing proper circuit identification (circuit directory).
Openings in circuit spaces.
See Annex "A", photo #55.
50. Panel #: MB1 Location: Level 8. West Air Handler-Electrical-telephone room.
Good () Needs repair (⑥)
Comments: Size: 60 AMPS Volt: 208/120 Phases: 3 Type: MLO
Repairs are required as follows:
a. Missing proper circuit identification (circuit directory).
b. Openings in circuit spaces.
See Annex "A", photo #56.
51. Panel #: LC Location: Level 8. West Air Handler-Electrical-telephone room.
Good () Needs repair (●)
Comments: Size: 400 AMPS Volt: 208/120 Phases: 3 Type: MLO
Repairs are required as follows:
Missing proper circuit identification (circuit directory). See Annex "A", photo #57.
Missing proper circuit identification (circuit directory). See Annex "A", photo #57.
Missing proper circuit identification (circuit directory). See Annex "A", photo #57. 52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room.
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room.
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair (•)
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair (• •) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows:
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair (●) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows: Missing proper panel ID. See Annex "A", photo #58.
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair ()) Comments: Size: 400 AMPS Repairs are required as follows: Missing proper panel ID. See Annex "A", photo #58. Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Location: Level 8. West Air Handler-Electrical-telephone room.
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair ()) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows: Missing proper panel ID. See Annex "A", photo #58. 53. Panel #: H Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair ())
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair () Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows: Missing proper panel ID. See Annex "A", photo #58. 53. Panel #: H Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair () Needs
52. Panel #: No Label Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair ()) Comments: Size: 400 AMPS Volt: 480/277 Phases: 3 Type: MLO Repairs are required as follows: Missing proper panel ID. See Annex "A", photo #58. 53. Panel #: H Location: Level 8. West Air Handler-Electrical-telephone room. Good () Needs repair ())

54. Panel #:	L1			Location:	Level 8.	West Air	Handler-	Electrical-te	lephone	e room.
				Good	()		Needs repa	air ()
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
Repairs are re	quired as follow	ws:								
a. Missing p	roper circuit id	entificatio	n (circuit direc	tory).						
o. Missing 2	screw(s).									
See Annex "A	", photo #60.									
55. Panel #:	L2			Location:	Level 8	Mast Air	· Handler-	Electrical-te	lenhone	room
JJ. Tallel #.	LZ			Good		\	Tianulei			1
Comments:		C:	400 41400		((((((((((((((((((((,	Dhasas	Needs repa) NALO
		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	IVILO
None.										
56. Panel #:	L3			Location:	Level 8.	West Air	· Handler-	Electrical-te	lephone	e room.
				Good	()		Needs repa)
Comments:		Size:	400 AMPS	Volt:	208/120	,	Phases:	3		MLO
	equired as follow			3 0101	_00,120			-	.,,,	5
-	roper circuit id		n (circuit direc	torv). See A	nnex "A".	photo #6	1.			
	in enclosure. Se		•		,					
- 1 0			,,,							
7. Panel #:	LC1			Location:	Level 8.	East Air I	landler ro	om		
				Good	()		Needs repa	air ()
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO
-	quired as follow									
Missing prope	er circuit identif	fication (ci	rcuit directory	. See Annex	("A", phot	o #63.				
	Natabal			Lasatian	Lavel 0		la a dia a a			
58. Panel #:	No Label				Level 8.	Last Air F	landier ro		/	O 1
				Good	()		Needs repa		()
Comments:		Size:		Volt:	208/120		Phases:		Type:	
Repairs are re	quired as follow	A/C :								
•					A ((A)	"lt	U.C. A			
•	er panel ID and		oper circuit di	rectory. See	Annex "A'	", photo	#64.			
Missing prope			oper circuit di					Electrical-te	lephone	e room
Missing prope	er panel ID and		oper circuit di	Location:				Electrical-te		
Missing prope		missing pr		Location: Good	Level 7.		· Handler-	Needs repa	air ()
Missing prope 59. Panel #: Comments:	MB	missing pr	oper circuit di	Location:					air (
Missing prope 59. Panel #: Comments: Repairs are re	MB	missing pr Size: ws:	60 AMPS	Location: Good Volt:	Level 7.		· Handler-	Needs repa	air ()
Missing prope 59. Panel #: Comments: Repairs are re a. Missing p	MB equired as follow	Size: ws: entificatio	60 AMPS	Location: Good Volt:	Level 7.		· Handler-	Needs repa	air ()
Missing prope 59. Panel #: Comments: Repairs are re a. Missing po. Openings	MB equired as followeroper circuit ide	Size: ws: entificatio	60 AMPS	Location: Good Volt:	Level 7.		· Handler-	Needs repa	air ()
Missing prope 59. Panel #: Comments: Repairs are re a. Missing po. Openings	MB equired as followeroper circuit ide	Size: ws: entificatio	60 AMPS	Location: Good Volt:	Level 7.		· Handler-	Needs repa	air ()
Missing property of the Missin	MB equired as followeroper circuit ide	Size: ws: entificatio	60 AMPS	Location: Good Volt:	Level 7. (208/120	West Air	Handler- Phases:	Needs repa	Type:	●) MLO
Missing prope 59. Panel #: Comments: Repairs are re a. Missing p b. Openings See Annex "A	MB equired as follower oper circuit id in circuit space ", photo #65.	Size: ws: entificatio	60 AMPS	Location: Good Volt: tory).	Level 7. (208/120	West Air	Handler- Phases:	Needs repa	Type:	●) MLO
Missing prope 59. Panel #: Comments: Repairs are re a. Missing p	MB equired as follower oper circuit id in circuit space ", photo #65.	Size: ws: entificatio	60 AMPS	Location: Good Volt: tory).	Level 7. (208/120 Level 7.	West Air	Handler- Phases:	Needs repa	air (Type: lephone	●) MLO

61. Panel #:	No Label			Location:	Level 7.	West Ai	r Handler-	-Electrical-tele	ephone	room	
				Good	()		Needs repai		•)
a. Missing p	quired as follows: roper panel ID. roper circuit identi	Size: ficatio	400 AMPS	Volt: ory).	480/277	·	Phases:	3	Type:		•
62. Panel #:	ш			Location:	Lovel 7	\Most Ai	r Handler	Electrical-tele	nhone	room	
62. Panei #:	Н			Good	Level 7.	vvest Ai	r nanuier-	Needs repai	•	• 100III	1
Comments:		Size:	225 AMPS	Volt:	208/120	,	Phases:	3	Type:		,
Repairs are re a. Missing p	quired as follows: roper circuit identi n Main lugs. Repair	ficatio	n (circuit direct	ory). See A	nnex "A",	-	67.		,,		
63. Panel #:	L1			Location:	Level 7.	West Ai	r Handler-	Electrical-tele	ephone	room	
				Good	()		Needs repai	r (•)
-	quired as follows: roper circuit identi	Size: ficatio	400 AMPS n (circuit direct	Volt: ory). See A	208/120 nnex "A",	photo #(Phases: 69.	3	Type:	MLO	
64. Panel #:				Location:	Level 7	West Ai	r Handler-	Electrical-tele	enhone	room	
on ranerm				Good	()	· · · · · · · · · · · · · · · · · · ·	Needs repai		•)
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	•	Type:		<u>'</u>
-	quired as follows: er circuit identificati	ion (ci	rcuit directory).	See Annex	κ "A", phot	o #70.					
65. Panel #:	L3			Location:	Level 7.	West Ai	r Handler-	Electrical-tele	ephone	room	
				Good	()		Needs repai	-	•)
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:		,
a. Missing p	quired as follows: roper circuit identi- in circuit spaces. ", photo #71.	ficatio	n (circuit direct								
66. Panel #:	No Label			Location:	Level 7.	West Ai	r Handler-	Electrical-tele	ephone	room	
				Good	()		Needs repai	r (•)
a. Missing pb. Missing pc. Missing 4See Annex "A"	quired as follows: roper panel ID. See roper circuit identifes screw(s).	ficatio	n (circuit direct	ory).	208/120		Phases:	3	Type:	MLO	
67. Panel #:	MB2			Location:	Level 7.	East Air	Handler ro	oom			
				Good	()		Needs repai	r (•)
Comments:		Size:	60 AMPS	Volt:	208/120	•	Phases:	3	Type:		

Missing proper circuit identification (circuit directory). See Annex "A", photo #75.

Repairs are required as follows:

	anel #:	6L			Location:	Level 6.	West Air H	andler-	Electrical-tele	ephone	room	
					Good	()		Needs repai	r ()	
Comm	nents:		Size:	No rating	Volt:	208/120	Pl	hases:	3	Type:	MLO	
Repair	rs are re	quired as follows	s:									
		roper panel ID. S		•								
b. N	/lissing p	roper circuit idei	<u>ntificatio</u>	n (circuit directo	ory). See Ar	າnex "A", ເ	photo #77.					
60 D	land #ı	MB1			Locations	Lovel	Most Air II	اعمالمما	Electrical-tele		room	
09. P	anel #:	INIBI			Location: Good	Level 6.	vvest Air n	lanuler-		•		
Comm	nents:		Size:	60 AMPS		208/120	<i>)</i>	hases:	Needs repai	Type:	<u> </u>	
		quired as follows		OU AIVIPS	voit:	208/120	P	nases:	3	Type:	IVILO	
-		roper circuit idei		n (circuit direct	orv) See Ar	nnex "A" i	nhoto #78					
		ing above panel					p11010 11701					
		<u> </u>		,								
70. P	anel #:	LC			Location:	Level 6.	West Air H	andler-	Electrical-tele	ephone	room	
					Good	()		Needs repai	r ()	
Comm	nents:		Size:	400 AMPS	Volt:	208/120	Pl	hases:	3	Type:	MLO	
Repair	rs are re	quired as follows	s:									
		ing above panel		-								
		roper circuit idei		n (circuit directe	ory).							
		in circuit spaces	•									
See Al	nnex A	', photo #81.										
71. P	anel #:	No Label			Location:	Level 6.	West Air H	andler-	Electrical-tele	enhone	room	
7 2	41101 111				Good	1)	- Idilaici	Needs repai)	
Comm	nents:		Size:	400 AMPS		480/277	Pi	hases:	· · · · · · · · · · · · · · · · · · ·	Type:		
		quired as follows		1007.11.11		100,277	• •		J	.,,,	20	
		roper panel ID. S		x "A", photo #8	2.							
b. N	/lissing p	roper circuit idei	ntificatio	n (circuit direct	ory). See Ar	າnex "A", ເ	photo #83.					
72. P	anel #:	6-H			Location:	Level 6.	West Air H	andler-	Electrical-tele		room	
					Good	()		Needs repai)	
Comm			Size:	225 AMPS	Volt:	480/277	Pl	hases:	3	Type:	MLO	
-		quired as follows	: :									
a. Missing proper circuit identification (circuit directory). See Annex "A", photo #84.												
		•		•		-			ov "A" photo	- #OE		
		roper circuit idei 1 Main lugs. Rep		•		-			ex "A", photo	o #85.		
b. Ta	apping i	n Main lugs. Rep		•	sing listed t	tapping co	nnectors. S	See Ann	• •		room	
b. Ta		•		•		tapping co	nnectors. S	See Ann	Electrical-tele	ephone		
73. P	apping in	n Main lugs. Rep	air tappi	ng in panel by u	Location:	Level 6.	West Air H	See Ann andler-	Electrical-tele Needs repai	ephone r ()	
73. Pa	rapping in ranel #:	Main lugs. Rep	air tappi	•	Location:	tapping co	West Air H	See Ann	Electrical-tele	ephone)	
73. Pa	apping in anel #: nents: rs are re	n Main lugs. Rep	Size:	ng in panel by u	Location: Good Volt:	Level 6.	West Air H	See Ann andler-	Electrical-tele Needs repai	ephone r ()	
73. Pa	apping in anel #: nents: rs are re	L3 quired as follows	Size:	ng in panel by u	Location: Good Volt:	Level 6.	West Air H	See Ann andler-	Electrical-tele Needs repai	ephone r ()	
73. Pa	apping in anel #: nents: rs are re	L3 quired as follows	Size:	ng in panel by u	Location: Good Volt:	Level 6. (208/120 "A", phot	West Air H) Pl o #86.	andler-	Electrical-tele Needs repai	ephone r (Type:	●) MLO	
73. Pa	apping in anel #: nents: rs are re ng prope	L3 quired as follows r circuit identific	Size:	ng in panel by u	Location: Good Volt: See Annex	Level 6. (208/120 "A", phot	West Air H) Pl o #86.	andler-	Electrical-tele Needs repai	ephone r (Type:	●) MLO	
73. Pa	apping in anel #: nents: rs are re ng prope	L3 quired as follows r circuit identific	Size:	ng in panel by u	Location: Good Volt: See Annex Location: Good	Level 6. (208/120 "A", phot	West Air H) P o #86. West Air H)	andler-	Electrical-tele Needs repai 3 Electrical-tele Needs repai	ephone r (Type:	MLO room o	
73. Pa	ranel #: nents: rs are re ng prope ranel #:	L3 quired as follows r circuit identific	Size: s: sation (ci	ng in panel by u 400 AMPS rcuit directory).	Location: Good Volt: See Annex Location: Good	Level 6. (208/120 "A", phot Level 6. (West Air H) P o #86. West Air H)	See Ann landler-l hases:	Electrical-tele Needs repai 3 Electrical-tele Needs repai	ephone r (Type: ephone r (MLO room o	
73. Para Commercial Missir Commercial Repairs Repairs a. Missir Repairs a. Missir Commercial Repairs a. Missir Repairs a	rapping in ranel #: nents: rs are re ng prope ranel #: nents: rs are re re/issing p	L3 quired as follows r circuit identific	Size: sation (ci	400 AMPS 400 AMPS 400 AMPS	Location: Good Volt: See Annex Location: Good Volt:	Level 6. (208/120 "A", phot Level 6. (West Air H) P o #86. West Air H)	See Ann landler-l hases:	Electrical-tele Needs repai 3 Electrical-tele Needs repai	ephone r (Type: ephone r (MLO room o	

75. Panel #:	L1			Location:	Level 6.	West Air	Handler-	Electrical-tel	ephone	e room	1
				Good	()		Needs repa	ir (•)
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
· ·	quired as follows										
	roper circuit ide	ntificatio	n (circuit direct	cory).							
b. Missing 3											
	in circuit spaces	•									
See Annex "A'	, μποιο #66.										
76. Panel #:	MB			Location:	Level 6.	East Air H	andler ro	oom.			
				Good	()		Needs repa	ir (•)
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
Repairs are re	quired as follows	5:									
-	r circuit identific		rcuit directory)	. See Annex	« "A", phot	to #89.					
77. Panel #:	EL			Location:	Level 5.	West Air	Handler-	Electrical-tel	ephone	room	1
				Good	()		Needs repa	ir (•)
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
Repairs are re	quired as follows	s:									
Missing prope	r circuit identific	ation (ci	rcuit directory)	. See Anne	«"A", phot	to #90.					
78. Panel #:	MB2			Location:	Level 5.	West Air	Handler-	Electrical-tel	ephone	room	1
				Good	()		Needs repa	ir (•)
Comments:		Size:	100 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
Repairs are re	quired as follows	s:									
Missing prope	r circuit identific	ation (ci	rcuit directory)	. See Annex	«"A", phot	to #91.					
79. Panel #:	No Label			Location:	Level 5.	West Air	Handler-	Electrical-tel	ephone	room)
				Good	()		Needs repa	ir (\odot)
Comments:		Size:	225 AMPS	Volt:	208/120		Phases:	3	Type:	MCB	
Repairs are re	quired as follows	s:									
	roper panel ID. S										
b. Missing p	roper circuit ide	ntificatio	n (circuit direct	ory). See A	nnex "A",	photo #9	3.				
80. Panel #:	LC			Location:	Level 5.	West Air	Handler-	Electrical-tel	ephone	room	1
				Good	()		Needs repa	ir (•)
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
Repairs are re	quired as follows	s:									
Missing prope	r circuit identific	ation (ci	rcuit directory)	. See Annex	κ "A", phot	to #94.					
81. Panel #:	EH			Location:	Level 5.	West Air	Handler-	Electrical-tel	ephone	room	1
· · · · · · · · · · · · · · · · · · ·				Good	()		Needs repa	ir (•)
Comments:		Size:	100 AMPS	Volt:	480/277		Phases:	3	Type:		
Repairs are re	quired as follows				•						
-	r circuit identific		rcuit directory)	. See Annex	«"A", phot	to #95.					

82. Panel #: No Label Location: Level 5. West Air Handler-Electrical-telephone room											
				Good	()		Needs repair	(•)
Comments:		Size:	600 AMPS	Volt:	480/277		Phases:	3 Ty	pe:	MLO	
Repairs are red	quired as follows:										
• • • • • • • • • • • • • • • • • • • •	oper panel ID.										
	oper circuit iden	tificatio	n (circuit direct	ory).							
See Annex "A"	, photo #96.										
!!!											
83. Panel #:	SH			Location:	Level 5.	West Ai	r Handler-	Electrical-teleph	one		,
				Good	()		Needs repair	(•)
Comments:		Size:	225 AMPS	Volt:	480/277		Phases:	3 Ty	pe:	MLO	
	quired as follows:				"."						
Missing prope	r circuit identifica	ition (ci	rcuit directory).	See Annex	« "A", phot	to #97.					
84. Panel #:	Н			Location:	Level 5.	West Air	· Handler i	room			
<u> </u>				Good	()		Needs repair	(•)
Comments:		Size:	225 AMPS	Volt:	480/277		Phases:	· · · · · · · · · · · · · · · · · · ·	ne:	MLO	,
	quired as follows:		2237111113	• • • • • • • • • • • • • • • • • • • •	100,277		i nasesi	.,	PC.		
•	circuit identifica		rcuit directory).	See Annex	κ "A", phot	to #98.					
01 1		•	,,		/ 1						
85. Panel #:	L1			Location:	Level 5.	West Air	Handler r	room			
				Good	()		Needs repair	(•)
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3 Ty	pe:	MLO	
Repairs are red	quired as follows:										
Missing prope	r circuit identifica	ition (ci	rcuit directory).	See Annex	د "A", phot	to #99.					
86. Panel #:	L2			Location:	Level 5.	West Air	Handler r	room			
				Good	(⊚)		Needs repair	()
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3 Ty	pe:	MLO	
None.											
87. Panel #:	L3			Location:	Level 5.	West Air	Handler r	room			
				Good	(⊚)		Needs repair	()
Comments:		Size:	400 AMPS	Volt:	208/120		Phases:	3 Ty	pe:	MLO	
None.											
88. Panel #:	MB				Level 5.	East Air	Handler ro	oom			
				Good	()		Needs repair	(•)
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3 Ty	pe:	MLO	
•	quired as follows:										
Missing proper	r circuit identifica	ition (ci	rcuit directory).	See Annex	κ "A", phot	to #100.					

00 Danel #.	C			Lasakian	. Laval 1	N4a:a Ela					
89. Panel #:	S				Level 1.	iviaili Eie	ectrical roc				,
_				Good	()		Needs repair		•)
Comments:		Size:	No rating	Volt:	208/120		Phases:	3	Type:	MCB	
=	quired as follows	:									
	roper panel ID.										
b. Missing 2											
_	space clearance v	iolation	•								
	", photo #101.		/ · · · · · · ·	,							
	roper circuit ider		n (circuit directi	ory).							
	in circuit spaces.										
See Annex "A	", photo #102.										
90. Panel #:	H1			Location	Level 1.	Main Ele	etrical roo	.m			
90. Pallel #.	пт			Good	Level 1.	1	ctricarroc		. /		1
Comments		C:·	225 ANADS		400/277)	Dhasas	Needs repair		<u> </u>	1
Comments:		Size:	225 AMPS	Volt:	480/277		Phases:	3	Type:	IVILO	
	quired as follows			C A	. ((A))l	- 4402					
iviissing prope	er circuit identific	ation (ci	rcuit directory).	See Annex	K "A", pnot	0 #103.					
04 5 14											
91. Panel #:	L1				Level 1.	Main Ele	ectrical roc				
				Good	()		Needs repair	. (•)
Comments:		Size:	225 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
•	quired as follows										
Missing prope	er circuit identific	ation (ci	rcuit directory).	See Annex	κ "A", phot	o #104,	and 105.				
92. Panel #:	MB			Location:	Level 1.	Main Ele	ectrical roc	om			
				Good	(•)		Needs repair	- ()
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
None.											
93. Panel #:	No Label			Location:	Level 1.	Main Ele	ectrical roc	om			
				Good	()		Needs repair	. (•)
Comments:		Size:	600 AMPS	Volt:	480/277		Phases:		Type:		,
	quired as follows		00071111113	voic.	400/277		i ilases.	3	iypc.	14120	
-	roper panel ID. S		y "Δ" nhoto #1	06							
• .	roper circuit ider		• •		nnex "A"	nhoto #	107				
			(0 00 0 00	0. 17. 0007	ex 71)	p					
94. Panel #:	EH1			Location	Level 1.	Main Fle	ectrical roc	nm			
54. Tunern.	2112			Good	1	1	-ctricarroc	Needs repair	. 1	•	1
Comments:		Cizor	100 AMPS		480/277	,	Phases:			•	,
	autional an fallauti	Size:	100 AIVIPS	Volt:	480/277		Priases:	3	Type:		
	quired as follows		n /aireuit direct	om/) Coo A	nnov "A"	nhata #	100				
	roper circuit ider space clearance v		•			photo #	108.				
b. Working	space clearance v	ioiation	. See Allilex A	, piloto #1	09.						
OF Danel #	El 1			Location	Lovel 1	Main Ele	strical roo				
95. Panel #:	EL1				Level 1.	Maill Ele	ectrical roc		,		`
				Good)		Needs repair		•)
Comments:		Size:	100 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
•	quired as follows		المستقلم عنديم	C A:	. "A"l ·						
IVUSSING DYNNA	er circuit identific	ation (Cl	rcuit airectory).	see Annex	к A, pnot	O #11U.					

	Α			Location	Lovol 2	Main Ela	ctrical roc	m. Parking ga	rago c	torage	
96. Panel #:	А				Level 5.	\	ctricarroc				\
Camananta		6:	100 1110	Good	()	51	Needs repai		<u> </u>)
Comments:		Size:	100 AMPS	Volt:	480/277		Phases:	3	Type:	MLO	
-	quired as follows:		/ - :				111				
• .	roper circuit iden space clearance vi		•	• •		pnoto #1	111.				
b. Working s	space clearance vi	ioiation	. See Allilex A	, piloto #1.	12.						
07 Daniel #.	Natabal			l a sabian.	Lavral 2	N4a::- Fla		na Daulina a		.	
97. Panel #:	No Label				Level 3.	,	ctrical roc	m. Parking ga			`
				Good)		Needs repai		•)
Comments:		Size:	225 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
-	quired as follows:										
	roper panel ID.										
_	space clearance vi	iolation	•								
See Annex "A"	•	.:£:: _									
	roper circuit iden in circuit spaces.	tificatio	n (circuit direct	ory).							
	•										
e. Missing 2 See Annex "A"											
Jee Alliex A	, prioto #114.										
98. Panel #:	No Label			Location:	Level 3	Main Fle	ctrical roc	om. Parking ga	arage s	torage	
36. Tallet #.	NO Label			Good	/	1	ctricarroc				1
Camananana			60.44406		1 200 /400)		Needs repai		<u> </u>)
Comments:		Size:	60 AMPS	Volt:	208/120		Phases:	3	Type:	MLO	
-	quired as follows:			4.5							
	roper panel ID. Se		-				110				
b. Missing p	roper circuit iden	tilicatio	n (circuit airect	ory). See A	nnex A,	prioto #1	110.				
99. Panel #:	Н			Location	Level 1.	Suita 100	า				
33. Tullet #.				Good	(•	1		Needs repai	r /		1
Comments:		Ciro	2EO ANADO			,	Dhasası			NALO	,
		Size:	250 AMPS	Volt:	480/277		Phases:	3	Type:	IVILO	
None.											
100 Danel #	1										
100.Panel #:	L			Locations	Lovel 1	Cuito 100	<u> </u>				
					Level 1.	Suite 100)				,
_				Location: Good	(•	Suite 100	0	Needs repai	r ()
Comments:		Size:	225 AMPS			Suite 100	Phases:		r (Type:	MLO)
Comments: None.		Size:	225 AMPS	Good	(•	Suite 100				MLO)
None.		Size:	225 AMPS	Good Volt:	(⊚ 208/120)	Phases:			MLO)
	A	Size:	225 AMPS	Good Volt:	(•)	Phases:			MLO)
None.		Size:	225 AMPS	Good Volt:	(⊚ 208/120)	Phases:		Type:	MLO)
None.		Size:	225 AMPS No rating	Good Volt: Location:	(⊚ 208/120)	Phases:	3	Type:	•)
None. 101.Panel #: Comments:		Size:		Good Volt: Location: Good	(© 208/120 Level 1.)	Phases:	Needs repai	Type:	•)
None. 101.Panel #: Comments: Repairs are re	A	Size:	No rating	Good Volt: Location: Good Volt:	(• 208/120 Level 1. (208/120) Truist Ba	Phases:	Needs repai	Type: r (Type:	•)
None. 101.Panel #: Comments: Repairs are re	A quired as follows:	Size:	No rating	Good Volt: Location: Good Volt:	(• 208/120 Level 1. (208/120) Truist Ba	Phases:	Needs repai	Type: r (Type:	•)
None. 101.Panel #: Comments: Repairs are re	A quired as follows:	Size:	No rating	Good Volt: Location: Good Volt:	Level 1. (208/120 Level 1. (208/120 ents. See A) Truist Ba) nnex "A"	Phases: nk Phases: ', photos #	Needs repai	Type: r (Type:	•)
None. 101.Panel #: Comments: Repairs are re Electrical close	A quired as follows: ets must be kept o	Size:	No rating	Good Volt: Location: Good Volt: eign eleme	Level 1. (208/120 Level 1. (208/120 ents. See A) Truist Ba) nnex "A"	Phases: nk Phases: ', photos #	Needs repai	Type: r (Type:	•)
None. 101.Panel #: Comments: Repairs are re Electrical close	A quired as follows: ets must be kept o	Size:	No rating ad free from for	Good Volt: Location: Good Volt: reign eleme Location: Good	Level 1. (208/120 nts. See A) Truist Ba) nnex "A"	Phases: nk Phases: ', photos #	Needs repai 3 #117, and 118	Type: r (Type:	● MCB)
None. 101.Panel #: Comments: Repairs are re Electrical close 102.Panel #: Comments:	A quired as follows: ets must be kept o	Size:	No rating	Good Volt: Location: Good Volt: eign eleme Location:	Level 1. (208/120 Level 1. (208/120 ents. See A) Truist Ba) nnex "A"	Phases: nk Phases: ', photos #	Needs repai 3 \$117, and 118	Type: r (Type:	● MCB)

103	3.Panel #:	No label				Location	: Level 8.	Uni	t No.	802					
						Good	()			Needs	repair (()	
Cor	nments:		Size:	No	rating	Volt:	208/120			Phases:	3	Туре	e: ſ	MLO	
Rep		quired as follow													
а.	• .	roper circuit id		•		• • •		, pho	oto #	119.					
b.	Working s	space clearance	e violatior	ı. See	e Annex "	'A", pnoto #1	.20.								
													_		
8.	BRAN	CH CIRCUI	TS												
1.	Identified	:	Yes	()	Must be i	dentified	(•)					
2.	Conducto	rs:	Good	()	Dete	eriorated	()	Мι	ust be repla	ace	d ()
	mments:														
		s must be iden					-				to				
		PANEL" section	•	ic id	entificati	on requireme	ents for ea	ch p	oanel.						
		quired as follow		ii+ch	missing I	D Coo Anno	, "A" nhat	#1	121						
a. b.		lin tower. Disc West Air Hand			_		-			ccina ID S	See Anne	ov "Δ" nho	nto	#122	
c.		West Air Hand			-					_					
d.		est Air Handle			-					_		-			
e.		est Air Handle			•					-					
					•										
0	CROLL	NDING OF	CED\//	^E											
9.	GROU	NDING OF	SERVI	CE											
1.			Good		(a) \	No	ode Donaii	<u> </u>	,	١					
	mments:		Good	()	INC	eds Repair	1	(,					
No															
110	110.														
40	CDOLL	NIDING OF	FOLUS	N 4 F	· NIT										
10.	GROU	NDING OF	EQUIP	IVIE	:N I										
	- 1								, ,	. ,					
1.	Condition		Good	()	Ne	eds Repair	r	(@))					
	nments:														
		quired as follov erator room. F		ام میں م	connect	ian Caa Ann	ov."^" nh.	o+o :	#1 2F						
a.	-	lerator room. F lest Air Handle		Juna	connect	ion. see Ann	ex A, pric	010 1	#125.	•					
b.		former ground		ction	n is nainte	ed See Anne	x "A" nho	to #	126						
c.		ater missing gr							120.						
d.		est Air Handle				-			paint	ted. See A	nnex "A	", photo #:	128	. .	
11	CEDVII	CE CONDII	IT / DA	CEV	MAVC										
11.	SERVI	CE CONDU	II / KA	CE	WAIS										
1	Condition		Casi	,	(a) \	K! -	ode Derest	<u> </u>	1	1			—		
1.	Condition		Good	()	INE	eds Repair		()					
No	nments:														
INO															

12. GENERAL CONDUIT / RACEWAYS												
		•										
1. Con	dition	Good	(•)	Needs Repair	()				
Commer	ts:				-	•	-	-				
None.												
13. W	IRE AND CABLES	S										
1. Con	dition	Good	(\odot)	Needs Repair	()				
Commer	ts:											
None.												
14. BU	JSWAYS											
1. Con	dition	Good	(•)	Needs Repair	()				
Commer	its:				,	•	`	,				
None.												
15 TL	IERMOGRAPHY	INICDE	-CT		I DECI	IIIT						
15. 11	IERIVIOGRAPHI	IIIJPL	.C I	IUI	N NES	OLI						
Commer	tc.											
	mography Report.											
occ mer	mography report.											
16. OT	THER CONDUCT	ORS										
1. Con	dition	Good	(•)	Repairs required	()				
Commer	its:											
None.												

17. TYPE OF WIRING METHODS

1.	Conduit Raceways Rigid:	Good (●)	Needs Repair	()	N/A	()
2.	Conduit PVC:	Good (⊚)	Needs Repair	()	N/A	()
3.	NM Cable:	Good ()	Needs Repair	()	N/A	(•)
4.	Other:	Good ()	Needs Repair	(•)	N/A	()
	a. Other Wiring (Specify):	EMT Conduit									

Comments:

Repairs are required as follows:

- a. Level 14. East Hallway. Water fountains missing GFCI protection and missing cover. See Annex "A", photo #129.
- b. Level 12. East Hallway. Water fountain missing GFCI protection. See Annex "A", photo #130.
- c. Level 11. East Hallway. Water fountain missing GFCI protection. See Annex "A", photo #131.
- d. Unit No.1401, Kitchen. Receptacles missing GFCI protection (2 receptacles). See Annex "A", photo #132.
- e. Unit No.802, Kitchen. Receptacles missing GFCI protection (1 receptacle). See Annex "A", photo 133.
- f. Unit No.703, Kitchen. Receptacles missing GFCI protection (2 receptacles). See Annex "A", photo #134.
- g. Unit No.703, Kitchen. Receptacle detached. See Annex "A", photo #135.
- h. Unit No.702, Kitchen. Receptacle missing GFCI protection. See Annex "A", photo #136.
- i. Unit No.1100, Kitchen. Water fountain missing GFCI protection. See Annex "A", photo #137.
- j. Unit No.701-711, Kitchen. Water fountain missing GFCI protection. See Annex "A", photo #138.
- Unit No.1205, Kichen. Receptacle located less than 6 feet from the sink missing GFCI protection. See Annex "A", photo #139.
- I. Unit No.701-711, Kitchen. Receptacle located less than 6 feet from the sink missing GFCI protection. See Annex "A", photo #140
- m. Unit No.501, Kitchen. Receptacle located less than 6 feet from the sink missing GFCI protection. See Annex "A", photo #141.
- n. Fire pump room and domestic water pumps. Lamp conduit detached. See Annex "A", photo #142.
- o. Chiller room. Water heater circulation pump flex conduit detached. See Annex "A", photo #143.
- p. Roof, Grounding wire disconnected. See Annex "A", photo #144.

5.	Conduit Raceways Rigid:	Good (⊚)	Needs Repair	()	N/A	()
6.	Conduit PVC:	Good (⊚)	Needs Repair	()	N/A	()
7.	NM Cable:	Good ()	Needs Repair	()	N/A	(•)
8.	Other:	Good ()	Needs Repair	()	N/A	()
	b. Other Wiring (Specify):	EMT Conduit								

Comments:

Repairs are required as follows:

- a. Level 12. East Air Handler. Junction box missing cover. See Annex "A", photo #145.
- b. Level 12. West Air Handler. Junction box missing cover. See Annex "A", photo #146.
- c. Level 11. West Air Handler Electrical & telephone room. Junction box missing cover, and the Fire alarm device is hanging. See Annex "A", photo #147.
- d. Level 10. West Air Handler Electrical & telephone room. Junction box missing cover. See Annex "A", photo #148.
- e. Level 10. East Air Handler Electrical & telephone room. Transformers 120/24v missing cover. See Annex "A", photo #149.
- f. Level 8. West Air Handler Electrical & telephone room. Control box missing cover. See Annex "A", photo #150.
- g. Level 7. West Air Handler Electrical & telephone room. Junction box missing cover. See Annex "A", photo #151.
- h. Level 6. West Air Handler Electrical & telephone room. Junction box and control box missing cover. See Annex "A", photo #152.
- i. Level 5. West Air Handler Electrical & telephone room. Opening in 15kva Transformer. See Annex "A", photo #153.
- j. Air Handler Electrical & telephone room. Flex conduit detached. See Annex "A", photo #154.

18. EMERGENCY	LIGHTING										
1. Condition	Good	(•)	Needs Repair	- ()	N/A	(<u> </u>
Comments:					- recas repair				,	`	
None.											
19. BUILDING EG	RESS ILLUI	MII	NAT	TION							
1. Condition	Good			1	Needs Repair			1	N/A	1	١
Comments:	Good	Ι.	•	1	Neeus Repair			,	IN/A		,
None.											
20. FIRE ALARM	SYSTEM										
1. Condition	Good			1	Needs Repair	1	•	1	N/A	1	1
Comments:	3004				Necus Nepuli			,	IVA		,
Repairs are required as	follows:										
Level 11. West Air Hand	dler - Electrical	& t	eleph	one roc	m. Fire alarm device	is ha	angin	g. See Anr	nex "A", photo #:	147.	
21. SMOKE DETE	CTORS										
1. Condition	Good			1	Noods Ponsir			1	N/A		1
Comments:	Good		•)	Needs Repair)	IN/A	(,
None.											
22. EXIT LIGHTS											
1. Condition	Good	()	Needs Repair	(•)	N/A	()
Comments:											
Repairs are required as					***						
Unit No.703, Office Area	a. Exit sign not	wor	king.	See Anı	nex "A", photo #155.						
23. EMERGENCY	GENERATO	OR									
1. Condition	Good	1	•	١	Needs Repair	1		1	N/A		١
Comments:	3000	(•	,	iveeus nepall	(,	IN/A		
None.											

24.	WIRING IN O	PEN C	OR U	IND	ER (COVE	R PARI	KING G	ARAGE	ARE	AS					
1.	Condition	Good	(•)	Req	uires Ado	litional Illu	mination	()	N/A	()
	nments:															
Noi	ne.															
25.	OPEN OR UN	DER C	COVI	ER P	PARI	KING	GARA	GE AND	EGRES	SIL	LUM	INAT	ION			
1	Condition	Caad	,		١	Dan	ر د د د د د د د د د د د د د د د د د د د	الله مما الل		,		٠,	NI/A			١
1.	nments:	Good	()	кеф	uires Add	litional Illu	mination	(•)	N/A	()
	Illumination letter.															
000	mammation retter.															
26	SWIMMING I		\A/IE		2											
20.	3WIIWIIWIIWG I	PUUL	VVIF	VIIV	J											
1.	Condition		Good	1 ()	Ne	eds Repai	r ()			N/A	(•)
	nments:			`		,							,			
Noi	ne.															
27.	WIRING TO N	ЛЕСН	ANIC	CAL	EQI	JIPM	ENT									
1.	Condition		Good	l (•)	Ne	eds Repai	r ()			N/A	()
	nments:															
No	ne.															
28.	ADDITIONAL	COM	MEI	NTS												
Noi	ne.															

Annex "A"

Site Photographs





Photo # 1. Item 3.1.a is depicted.

Photo # 2. Item 3.1.a is depicted.



Photo # 3. Item 3.1.b is depicted.



Photo # 4. Items 3.2, 3.3, and 3.4 are depicted.





Photo # 5. Item 3.5 is depicted.

Photo # 6. Item 3.6 is depicted.




Photo # 7. Item 5.a is depicted.



Photo #8. Item 5.b is depicted.



Photo # 9. Item 5.c is depicted.



Photo # 10. Item 5.d is depicted.



Photo # 11. Items 7.1.a, and 7.1.b are depicted.



Photo # 12. Item 7.2 is depicted.



Photo # 13. Item 7.3 is depicted.



Photo # 14. Items 7.4.a, and 7.4.b are depicted.



Photo # 15. Item 7.5 is depicted.



Photo # 16. Item 7.6 is depicted.





Photo # 17. Item 7.8 is depicted.

Photo # 18. Item 7.9.a is depicted.



Photo # 19. Item 7.9.b is depicted.



Photo # 20. Item 7.10.a is depicted.





Photo # 21. Item 7.10.b is depicted.

Photo # 22. Item 7.11 is depicted.



Photo # 23. Item 7.12 is depicted.



Photo # 24. Item 7.13 is depicted.



Photo # 25. Item 7.14 is depicted.



Photo # 26. Items 7.15.a, and 7.15.b are depicted.



Photo # 27. Items 7.16.a, and 7.16.b are depicted.



Photo # 28. Item 7.17 is depicted.



Photo # 29. Item 7.18 is depicted.



Photo # 30. Item 7.19.a is depicted.



Photo # 31. Item 7.19.b is depicted.



Photo #32. Items 7.20.a, and 7.20.b are depicted.



Photo # 33. Items 7.21 is depicted.



Photo # 34. Item 7.23 is depicted.



Photo # 35. Item 7.24 is depicted.



Photo #36. Items 7.27.a, and 7.27.b are depicted.





Photo # 37. Item 7.28 is depicted.

Photo # 38. Item 7.29 is depicted.



Photo # 39. Item 7.30 is depicted.



Photo # 40. Item 7.31 is depicted.



Photo # 41. Item 7.32 is depicted.



Photo # 42. Item 7.33 is depicted.



Photo # 43. Item 7.34 is depicted.



Photo # 44. Item 7.35 is depicted.



Photo # 45. Item 7.36 is depicted.



Photo # 46. Item 7.37 is depicted.



Photo # 47. Item 7.38 is depicted.



Photo # 48. Item 7.39 is depicted.



Photo # 49. Item 7.40 is depicted.



Photo # 50. Item 7.41 is depicted.



Photo # 51. Item 7.42 is depicted.



Photo # 52. Items 7.44.a, and 7.44.b are depicted.



Photo # 53. Item 7.45 is depicted.



Photo # 54. Item 7.48 is depicted.



Photo #55. Items 7.49.a, and 7.49.b are depicted.



Photo #56. Items 7.50.a, and 7.50.b are depicted.





Photo # 57. Item 7.51 is depicted.

Photo # 58. Item 7.52 is depicted.



Photo # 59. Item 7.53 is depicted.



Photo # 60. Items 7.54.a, and 7.54.b are depicted.



Photo # 61. Items 7.56.a is depicted.



Photo # 62. Item 7.56.b is depicted.



Photo # 63. Item 7.57 is depicted.



Photo # 64. Item 7.58 is depicted.



Photo # 65. Items 7.59.a and 7.59.b are depicted.



Photo # 66. Items 7.61.a, and 7.61.b are depicted.



Photo # 67. Item 7.62.a is depicted.



Photo # 68. Item 7.62.b is depicted.



Photo # 69. Item 7.63 is depicted.



Photo # 70. Item 7.64 is depicted.



Photo #71. Items 7.65.a, and 7.65.b are depicted.



Photo # 72. Item 7.66.a is depicted.



Photo # 73. Items 7.66.b and 7.66.c are depicted.



Photo # 74. Item 7.66.d is depicted.



Photo # 75. Items 7.67 is depicted.



Photo # 76. Item 7.68.a is depicted.



Photo # 77. Item 7.68b is depicted.



Photo # 78. Item 7.69.a is depicted.



Photo # 79. Item 7.69.b is depicted.



Photo #80. Item 7.70.a is depicted.





Photo #81. Items 7.70.b and 7.70.c are depicted.

Photo #82. Item 7.71.a is depicted.



Photo #83. Item 7.71.b is depicted.



Photo #84. Item 7.72.a is depicted.



Photo #85. Item 7.72.b is depicted.



Photo #86. Item 7.73 is depicted.



Photo #87. Items 7.74.a and 7.74.b are depicted.



Photo # 88. Items 7.75.a, 7.75.b and 7.75.c are depicted.



Photo #89. Item 7.76 is depicted.



Photo # 90. Item 7.77 is depicted.



Photo # 91. Items 7.78 is depicted.



Photo # 92. Item 7.79.a is depicted.





Photo # 93. Item 7.79.b is depicted.

Photo # 94. Item 7.80 is depicted.



Photo # 95. Items 7.81 is depicted.



Photo # 96. Items 7.82.a, and 7.82.b are depicted.



Photo # 97. Item 7.83 is depicted.



Photo # 98. Item 7.84 is depicted.



Photo # 99. Item 7.85 is depicted.



Photo # 100. Item 7.88 is depicted.



Photo # 101. Items 7.89.a, 7.89.b, and 7.89.c are depicted.



Photo # 102. Items 7.89.d, and 7.89.e are depicted.



Photo # 103. Item 7.90 is depicted.



Photo # 104. Item 7.91 is depicted.



Photo # 105. Item 7.91 is depicted.



Photo # 106. Item 7.93.a is depicted.



Photo # 107. Item 7.93.b is depicted.



Photo # 108. Item 7.94.a is depicted.



Photo # 109. Item 7.94.b is depicted.



Photo # 110. Item 7.95 is depicted.



Photo # 111. Item 7.96.a is depicted.



Photo # 112. Items 7.96.b is depicted.



Photo # 113. Items 7.97.a and 7.97.b are depicted.



Photo # 114. Items7.97.c, 7.97.d, and 7.97.e are depicted.



Photo # 115. Item 7.98.a is depicted.



Photo # 116. Item 7.98.b is depicted.



Photo # 117. Items 7.101, and 7.102 are depicted.



Photo # 118. Items 7.101, and 7.102 are depicted.



Photo # 119. Item 7.103.a is depicted.



Photo # 120. Item 7.103.b is depicted.




Photo # 121. Item 8.a is depicted.



Photo # 122. Item 8.b is depicted.



Photo # 123. Item 8.d is depicted.



Photo # 124. Items 8.e is depicted.






Photo # 125. Item 10.a is depicted.

Photo # 126. Item 10.b is depicted.





Photo # 127. Item 10.c is depicted.

Photo # 128. Item 10.d is depicted.





Photo # 129. Item 17.1.a is depicted.

Photo # 130. Item 17.1.b is depicted.








Photo # 132. Item 17.1.d is depicted.





Photo # 133. Item 17.1.e is depicted.

Photo # 134. Item 17.1.f is depicted.





Photo # 135. Item 17.1.g is depicted.

Photo # 136. Item 17.1.h is depicted.



Photo # 137. Item 17.1.i is depicted.



Photo # 138. Item 17.1.j is depicted.



Photo # 139. Item 17.1.k is depicted.



Photo # 140. Item 17.1.l is depicted.






Photo # 141. Item 17.1.m is depicted.

Photo # 142. Item 17.1.n is depicted.








Photo # 144. Item 17.1.p is depicted.



Photo # 145. Item 17.2.a is depicted.



Photo # 146. Item 17.2.b is depicted.



Photo # 147. Item 17.2.c is depicted.



Photo # 148. Item 17.2.d is depicted.





Photo # 149. Item 17.2.e is depicted.

Photo # 150. Item 17.2.f is depicted.








Photo # 152. Item 17.2.h is depicted.



Photo # 153. Item 17.2.i is depicted.



Photo # 154. Item 17.2.j is depicted.




Photo # 155. Item 22.a is depicted.

Annex "A"

Site Photographs

Darl 8 Riddle





Photo # 1. Item 3.1.a is depicted.

Photo # 2. Item 3.1.a is depicted.



Photo # 3. Item 3.1.b is depicted.



Photo # 4. Items 3.2, 3.3, and 3.4 are depicted.





Photo # 5. Item 3.5 is depicted.

Photo # 6. Item 3.6 is depicted.




Photo # 7. Item 5.a is depicted.



Photo #8. Item 5.b is depicted.



Photo # 9. Item 5.c is depicted.



Photo # 10. Item 5.d is depicted.



Photo # 11. Items 7.1.a, and 7.1.b are depicted.



Photo # 12. Item 7.2 is depicted.



Photo # 13. Item 7.3 is depicted.



Photo # 14. Items 7.4.a, and 7.4.b are depicted.



Photo # 15. Item 7.5 is depicted.



Photo # 16. Item 7.6 is depicted.





Photo # 17. Item 7.8 is depicted.

Photo # 18. Item 7.9.a is depicted.



Photo # 19. Item 7.9.b is depicted.



Photo # 20. Item 7.10.a is depicted.





Photo # 21. Item 7.10.b is depicted.

Photo # 22. Item 7.11 is depicted.



Photo # 23. Item 7.12 is depicted.



Photo # 24. Item 7.13 is depicted.




Photo # 25. Item 7.14 is depicted.



Photo # 26. Items 7.15.a, and 7.15.b are depicted.



Photo # 27. Items 7.16.a, and 7.16.b are depicted.



Photo # 28. Item 7.17 is depicted.



Photo # 29. Item 7.18 is depicted.



Photo # 30. Item 7.19.a is depicted.



Photo # 31. Item 7.19.b is depicted.



Photo #32. Items 7.20.a, and 7.20.b are depicted.



Photo # 33. Items 7.21 is depicted.



Photo # 34. Item 7.23 is depicted.



Photo # 35. Item 7.24 is depicted.



Photo #36. Items 7.27.a, and 7.27.b are depicted.





Photo # 37. Item 7.28 is depicted.

Photo # 38. Item 7.29 is depicted.



Photo # 39. Item 7.30 is depicted.



Photo # 40. Item 7.31 is depicted.



Photo # 41. Item 7.32 is depicted.



Photo # 42. Item 7.33 is depicted.



Photo # 43. Item 7.34 is depicted.



Photo # 44. Item 7.35 is depicted.



Photo # 45. Item 7.36 is depicted.



Photo # 46. Item 7.37 is depicted.



Photo # 47. Item 7.38 is depicted.



Photo # 48. Item 7.39 is depicted.



Photo # 49. Item 7.40 is depicted.



Photo # 50. Item 7.41 is depicted.



Photo # 51. Item 7.42 is depicted.



Photo # 52. Items 7.44.a, and 7.44.b are depicted.



Photo # 53. Item 7.45 is depicted.



Photo # 54. Item 7.48 is depicted.



Photo #55. Items 7.49.a, and 7.49.b are depicted.



Photo #56. Items 7.50.a, and 7.50.b are depicted.





Photo # 57. Item 7.51 is depicted.

Photo # 58. Item 7.52 is depicted.



Photo # 59. Item 7.53 is depicted.



Photo # 60. Items 7.54.a, and 7.54.b are depicted.



Photo # 61. Items 7.56.a is depicted.



Photo # 62. Item 7.56.b is depicted.



Photo # 63. Item 7.57 is depicted.



Photo # 64. Item 7.58 is depicted.



Photo # 65. Items 7.59.a and 7.59.b are depicted.




Photo # 66. Items 7.61.a, and 7.61.b are depicted.



Photo # 67. Item 7.62.a is depicted.



Photo # 68. Item 7.62.b is depicted.



Photo # 69. Item 7.63 is depicted.



Photo # 70. Item 7.64 is depicted.



Photo #71. Items 7.65.a, and 7.65.b are depicted.



Photo # 72. Item 7.66.a is depicted.



Photo # 73. Items 7.66.b and 7.66.c are depicted.



Photo # 74. Item 7.66.d is depicted.



Photo # 75. Items 7.67 is depicted.



Photo # 76. Item 7.68.a is depicted.



Photo # 77. Item 7.68b is depicted.



Photo # 78. Item 7.69.a is depicted.



Photo # 79. Item 7.69.b is depicted.



Photo #80. Item 7.70.a is depicted.





Photo #81. Items 7.70.b and 7.70.c are depicted.

Photo #82. Item 7.71.a is depicted.



Photo #83. Item 7.71.b is depicted.



Photo #84. Item 7.72.a is depicted.



Photo #85. Item 7.72.b is depicted.



Photo #86. Item 7.73 is depicted.



Photo #87. Items 7.74.a and 7.74.b are depicted.



Photo # 88. Items 7.75.a, 7.75.b and 7.75.c are depicted.



Photo #89. Item 7.76 is depicted.



Photo # 90. Item 7.77 is depicted.



Photo # 91. Items 7.78 is depicted.



Photo # 92. Item 7.79.a is depicted.





Photo # 93. Item 7.79.b is depicted.

Photo # 94. Item 7.80 is depicted.



Photo # 95. Items 7.81 is depicted.



Photo # 96. Item 7.82.a is depicted.





Photo # 97. Item 7.82.b is depicted.

Photo # 98. Item 7.83 is depicted.



Photo # 99. Item 7.84 is depicted.



Photo # 100. Item 7.85 is depicted.



Photo # 101. Items 7.89.a, 7.89.b, and 7.89.c are depicted.



Photo # 102. Items 7.89.d, and 7.89.e are depicted.



Photo # 103. Item 7.90 is depicted.



Photo # 104. Item 7.91 is depicted.



Photo # 105. Item 7.91 is depicted.



Photo # 106. Item 7.93.a is depicted.



Photo # 107. Item 7.93.b is depicted.



Photo # 108. Item 7.94.a is depicted.



Photo # 109. Item 7.94.b is depicted.



Photo # 110. Item 7.95 is depicted.



Photo # 111. Item 7.96.a is depicted.



Photo # 112. Items 7.96.b is depicted.



Photo # 113. Items 7.97.a and 7.97.b are depicted.



Photo # 114. Items7.97.c, 7.97.d, and 7.97.e are depicted.



Photo # 115. Item 7.98.a is depicted.



Photo # 116. Item 7.98.b is depicted.



Photo # 117. Items 7.101, and 7.102 are depicted.



Photo # 118. Items 7.101, and 7.102 are depicted.



Photo # 119. Item 7.103.a is depicted.



Photo # 120. Item 7.103.b is depicted.




Photo # 121. Item 8.a is depicted.



Photo # 122. Item 8.b is depicted.



Photo # 123. Item 8.d is depicted.



Photo # 124. Items 8.e is depicted.






Photo # 125. Item 10.a is depicted.

Photo # 126. Item 10.b is depicted.





Photo # 127. Item 10.c is depicted.

Photo # 128. Item 10.d is depicted.





Photo # 129. Item 17.1.a is depicted.

Photo # 130. Item 17.1.b is depicted.








Photo # 132. Item 17.1.d is depicted.





Photo # 133. Item 17.1.e is depicted.

Photo # 134. Item 17.1.f is depicted.





Photo # 135. Item 17.1.g is depicted.

Photo # 136. Item 17.1.h is depicted.



Photo # 137. Item 17.1.i is depicted.



Photo # 138. Item 17.1.j is depicted.



Photo # 139. Item 17.1.l is depicted.



Photo # 140. Item 17.1.m is depicted.






Photo # 141. Item 17.1.n is depicted.

Photo # 142. Item 17.1.0 is depicted.



Photo # 143. Item 17.1.p is depicted.



Photo # 144. Item 17.2.a is depicted.





Photo # 145. Item 17.2.b is depicted.

Photo # 146. Item 17.2.c is depicted.








Photo # 148. Item 17.2.e is depicted.





Photo # 149. Item 17.2.f is depicted.

Photo # 150. Item 17.2.g is depicted.



Photo # 151. Item 17.2.h is depicted.



Photo # 152. Item 17.2.i is depicted.






Photo # 153. Item 17.2.j is depicted.

Photo # 154. Item 22.a is depicted.



City of Coral Gables Development Services Department

NOTICE TO BUILDING OFFICIAL

Form A.1

For the use of Private Providence	der	Florida Statutes	§553.791(4)	Rev. 10-01-2014	
Project Name / Address: 751 N Greenway	y Dr				
Plan number:			_ Phased Per	mit? □ Yes ☑ No	
Project address: 751 NGreenway Dr		Parcel tax ID:	03-410	8-001-4080	
Services to be provided (select one):	sonly	□Plans Rev	iew and Inspe	ections*	
*Pursuant to FS Section 553.791(2): If this notice app at his or her discretion, that the private provider be us			y, the Building	g Official has the authority to requ	uir
I,entered into a contract with the Private Provider firm	the fee didentified be	owner of the pro low to conduct	perty referer the services ir	nced above, hereby affirm that I had indicated above.	ıav
Private Provider Firm: ARC Private Prov					
Private Provider (Qualifier for the Firm): Jose R	amos				
Florida License or Registration number:	1115				
Address: 7414 SW 48 ST Miami F	33155)			
Telephone: 305.501.4788 Fax:		_ rick@	@arcpriv	ateprovider.com	

I have elected to use one or more Private Providers to provide building code plans review and/or inspection services for the building or structure that is the subject of the enclosed permit application, as authorized by Section 553.791, Florida Statutes. I understand that the local Building Official may not review the plans submitted or perform the required building inspections to determine compliance with the applicable codes, except to the extent specified in said law. Instead, plans review and/or required building inspections will be performed by licensed or certified personnel identified in the application. The law requires minimum insurance requirements for such personnel, but I understand that I may require more insurance to protect my interests.

By executing this form, I acknowledge that I have made inquiry regarding the competence of the licensed or certified personnel and the level of their insurance and am satisfied that my interests are adequately protected. I agree to indemnify, defend, and hold harmless the local government, the local Building Official, and their building code enforcement personnel from any and all claims arising from my use of these licensed or certified personnel to perform building code inspection services with respect to the building or structure that is the subject of the enclosed permit application.

I understand that the Building Official retains authority to review plans, make required inspections, and enforce the applicable codes within his or her charge pursuant to the standards established by Section 553.791, Florida Statutes. If I make any changes to the listed Private Providers, I shall, within one (1) business day after any change, update this Notice to reflect such changes. The building plans review and/or inspection services provided by the Private Provider are limited to compliance with the Florida Building Code and do not include review for compliance with fire safety, land use, environmental or other codes.

The following attachments are provided as required by Section 553.791, Florida Statutes:

Signature of Notary:

- 1. Qualification statements and/or resumes of the Private Provider and all duly authorized representatives.
- 2. Proof of insurance for professional and comprehensive liability in the amount of \$1 million per occurrence and \$2 million in the aggregate for any project with a construction cost of \$5 million or less, and \$2 million per occurrence and \$4 million in the aggregate for any project with a construction cost of over \$5 million, relating to all services performed as a private provider. Said insurance includes tail coverage (Extended Reporting Period) for a minimum of five (5) years subsequent to the performance of building code inspection services. For detailed, current requirements refer to FS Section 553.791(16).

Please notarize using the appropriate section below: Individual By: Alaborature (Signature) Print name: ADAM HLAVATY 751 North Greenway Drive, Coral Gables, FL Telephone: 2196140947 STATE OF FL COUNTY OF MTANT DABefore me, this 29 day of 01, 2024, personally appeared ADAM HLAVATY who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Signature of Notary: Notary public stamp: **Corporation** Print Corporation Name: ___ (signature) Print name: ______lts: _____ _____Telephone: ____ Address: __ STATE OF ______ COUNTY OF ______ Before me, this ____day of ______, 20_____, personally appeared _, on behalf of the stated corporation, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: ____ Print Name Notary Stamp: Signature of Notary: Partnership Print Partnership Name: ____ (signature) Print name: ______ Its: _____ Telephone: ____ STATE OF ______ COUNTY OF ______ Before me, this ____day of _____, 20____, personally appeared _ partner/agent on behalf of the partnership, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Print Name ____ Notary Stamp:



City of Coral Gables Development Services Department

NOTICE TO BUILDING OFFICIAL

Form A.1

For the use of Private Providence	der	Florida Statutes	§553.791(4)	Rev. 10-01-2014	
Project Name / Address: 751 N Greenway	y Dr				
Plan number:			_ Phased Per	mit? □ Yes ☑ No	
Project address: 751 NGreenway Dr		Parcel tax ID:	03-410	8-001-4080	
Services to be provided (select one):	sonly	□Plans Rev	iew and Inspe	ections*	
*Pursuant to FS Section 553.791(2): If this notice app at his or her discretion, that the private provider be us			y, the Building	g Official has the authority to requ	uir
I,entered into a contract with the Private Provider firm	the fee didentified be	owner of the pro low to conduct	perty referer the services ir	nced above, hereby affirm that I had indicated above.	ıav
Private Provider Firm: ARC Private Prov					
Private Provider (Qualifier for the Firm): Jose R	amos				
Florida License or Registration number:	1115				
Address: 7414 SW 48 ST Miami F	33155)			
Telephone: 305.501.4788 Fax:		_ rick@	@arcpriv	ateprovider.com	

I have elected to use one or more Private Providers to provide building code plans review and/or inspection services for the building or structure that is the subject of the enclosed permit application, as authorized by Section 553.791, Florida Statutes. I understand that the local Building Official may not review the plans submitted or perform the required building inspections to determine compliance with the applicable codes, except to the extent specified in said law. Instead, plans review and/or required building inspections will be performed by licensed or certified personnel identified in the application. The law requires minimum insurance requirements for such personnel, but I understand that I may require more insurance to protect my interests.

By executing this form, I acknowledge that I have made inquiry regarding the competence of the licensed or certified personnel and the level of their insurance and am satisfied that my interests are adequately protected. I agree to indemnify, defend, and hold harmless the local government, the local Building Official, and their building code enforcement personnel from any and all claims arising from my use of these licensed or certified personnel to perform building code inspection services with respect to the building or structure that is the subject of the enclosed permit application.

I understand that the Building Official retains authority to review plans, make required inspections, and enforce the applicable codes within his or her charge pursuant to the standards established by Section 553.791, Florida Statutes. If I make any changes to the listed Private Providers, I shall, within one (1) business day after any change, update this Notice to reflect such changes. The building plans review and/or inspection services provided by the Private Provider are limited to compliance with the Florida Building Code and do not include review for compliance with fire safety, land use, environmental or other codes.

The following attachments are provided as required by Section 553.791, Florida Statutes:

Signature of Notary:

- 1. Qualification statements and/or resumes of the Private Provider and all duly authorized representatives.
- 2. Proof of insurance for professional and comprehensive liability in the amount of \$1 million per occurrence and \$2 million in the aggregate for any project with a construction cost of \$5 million or less, and \$2 million per occurrence and \$4 million in the aggregate for any project with a construction cost of over \$5 million, relating to all services performed as a private provider. Said insurance includes tail coverage (Extended Reporting Period) for a minimum of five (5) years subsequent to the performance of building code inspection services. For detailed, current requirements refer to FS Section 553.791(16).

Please notarize using the appropriate section below: Individual By: Alaborature (Signature) Print name: ADAM HLAVATY 751 North Greenway Drive, Coral Gables, FL Telephone: 2196140947 STATE OF FL COUNTY OF MTANT DABefore me, this 29 day of 01, 2024, personally appeared ADAM HLAVATY who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Signature of Notary: Notary public stamp: **Corporation** Print Corporation Name: ___ (signature) Print name: ______ Its: ______ _____Telephone: ____ Address: __ STATE OF ______ COUNTY OF ______ Before me, this ____day of ______, 20_____, personally appeared _, on behalf of the stated corporation, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: ____ Print Name Notary Stamp: Signature of Notary: Partnership Print Partnership Name: ____ (signature) Print name: ______ Its: _____ Telephone: ____ STATE OF ______ COUNTY OF ______ Before me, this ____day of _____, 20____, personally appeared _ partner/agent on behalf of the partnership, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Print Name ____ Notary Stamp:



City of Coral Gables Development Services Department

NOTICE TO BUILDING OFFICIAL

Form A.1

For the use of Private Providence	der	Florida Statutes	§553.791(4)	Rev. 10-01-2014	
Project Name / Address: 751 N Greenway	y Dr				
Plan number:			_ Phased Per	mit? □ Yes ☑ No	
Project address: 751 NGreenway Dr		Parcel tax ID:	03-410	8-001-4080	
Services to be provided (select one):	sonly	□Plans Rev	iew and Inspe	ections*	
*Pursuant to FS Section 553.791(2): If this notice app at his or her discretion, that the private provider be us			y, the Building	g Official has the authority to requ	uir
I,entered into a contract with the Private Provider firm	the fee didentified be	owner of the pro low to conduct	perty referer the services ir	nced above, hereby affirm that I had indicated above.	ıav
Private Provider Firm: ARC Private Prov					
Private Provider (Qualifier for the Firm): Jose R	amos				
Florida License or Registration number:	1115				
Address: 7414 SW 48 ST Miami F	33155)			
Telephone: 305.501.4788 Fax:		_ rick@	@arcpriv	ateprovider.com	

I have elected to use one or more Private Providers to provide building code plans review and/or inspection services for the building or structure that is the subject of the enclosed permit application, as authorized by Section 553.791, Florida Statutes. I understand that the local Building Official may not review the plans submitted or perform the required building inspections to determine compliance with the applicable codes, except to the extent specified in said law. Instead, plans review and/or required building inspections will be performed by licensed or certified personnel identified in the application. The law requires minimum insurance requirements for such personnel, but I understand that I may require more insurance to protect my interests.

By executing this form, I acknowledge that I have made inquiry regarding the competence of the licensed or certified personnel and the level of their insurance and am satisfied that my interests are adequately protected. I agree to indemnify, defend, and hold harmless the local government, the local Building Official, and their building code enforcement personnel from any and all claims arising from my use of these licensed or certified personnel to perform building code inspection services with respect to the building or structure that is the subject of the enclosed permit application.

I understand that the Building Official retains authority to review plans, make required inspections, and enforce the applicable codes within his or her charge pursuant to the standards established by Section 553.791, Florida Statutes. If I make any changes to the listed Private Providers, I shall, within one (1) business day after any change, update this Notice to reflect such changes. The building plans review and/or inspection services provided by the Private Provider are limited to compliance with the Florida Building Code and do not include review for compliance with fire safety, land use, environmental or other codes.

The following attachments are provided as required by Section 553.791, Florida Statutes:

Signature of Notary:

- 1. Qualification statements and/or resumes of the Private Provider and all duly authorized representatives.
- 2. Proof of insurance for professional and comprehensive liability in the amount of \$1 million per occurrence and \$2 million in the aggregate for any project with a construction cost of \$5 million or less, and \$2 million per occurrence and \$4 million in the aggregate for any project with a construction cost of over \$5 million, relating to all services performed as a private provider. Said insurance includes tail coverage (Extended Reporting Period) for a minimum of five (5) years subsequent to the performance of building code inspection services. For detailed, current requirements refer to FS Section 553.791(16).

Please notarize using the appropriate section below: Individual By: Alaborature (Signature) Print name: ADAM HLAVATY 751 North Greenway Drive, Coral Gables, FL Telephone: 2196140947 STATE OF FL COUNTY OF MTANT DABefore me, this 29 day of 01, 2024, personally appeared ADAM HLAVATY who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Signature of Notary: Notary public stamp: **Corporation** Print Corporation Name: ___ (signature) Print name: ______ Its: ______ _____Telephone: ____ Address: __ STATE OF ______ COUNTY OF ______ Before me, this ____day of ______, 20_____, personally appeared _, on behalf of the stated corporation, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: ____ Print Name Notary Stamp: Signature of Notary: Partnership Print Partnership Name: ____ (signature) Print name: ______ Its: _____ Telephone: ____ STATE OF ______ COUNTY OF ______ Before me, this ____day of _____, 20____, personally appeared _ partner/agent on behalf of the partnership, who executed the foregoing instrument, and acknowledged before me that same was executed for the purposes therein expressed. Personally known or Produced Identification Type of ID produced: Print Name ____ Notary Stamp:



Regulatory and Economic Resources

11805 SW 26th Street Miami, Florida 33175-2474 786-315-2000

miamidade.gov/building

CERTIFICATION OF COMPLIANCE WITH PARKING LOT ILLUMINATION STANDARDS IN CHAPTER 8C-3 OF THE CODE OF MIAMI-DADE COUNTY

Date	e:			
Case	e No	FYear		
Prop	pertyAddress:_		, Bldg.	No.:, Sq. Ft.:
Folio	o Number:			
Build	ding Description	n:		
1.	I am a Florida	registered professional	engineer	architect with an active license.
2.		at AM the above referenced building		red the level of illumination in the parking
3.	Maximum	foot candle		
	Minimum	foot candle		
	Maximum to I	Minimum Ratio:	, fo	ot candle
4.	minimumstan			meets does not meet the e building as established in Section 8C-3
	_	Dat 8 Ridds	2	
	9	Signature and Seal of Profes	sional	Print Name Engineer or Architect

ARCHITECTS

RESERVE
SPECIALISTS



15405 NW 7th Avenue Miami, FL 33169 **P** (305) 663-1970 **TheFalconGroup.us**

April 5, 2023

City of Coral Gables
Development Services Department
City Hall
405 Biltmore Way
Coral Gables, FL 33134

RE: 201 Alhambra Circle, Coral Gables FL 33134

Folio # 03-4108-006-2040 - 50 Year Structural Recertification Report Y:\Clients\Falcon2022\22-1091\001_50 Yr\L230415 50- Structural Report 201 Alhambra.Docx

Dear Building Official:

Per your request, The Falcon Group (Falcon) conducted a 50-year structural recertification of the SunTrust Plaza at 201 Alhambra Circle, Coral Gables, FL 33134, consistent with the requirements of the City of Miami and Miami-Dade County Code Section 8-11(f) 50 Year Minimum Inspection Procedural Guidelines for Building's Structural Recertification. Please refer to the attached copies of the structural 50-year recertification report for the SunTrust Plaza property. In summary, in accordance with the above Miami-Dade County guidelines and regulations, concrete repairs are required at the parking garage and roof areas of the property.

Visual examinations of the building were conducted at representative locations of reinforced concrete beams, columns, reinforced concrete slabs, and masonry walls from the ground floor, parking garage, roof areas, and interior space. Some areas were noted with isolated concrete deficiencies. The observed concrete deficiencies are progressive in nature and must be properly repaired.

Additionally, the concrete slabs and beams in the parking garage show minor and/or isolated concrete deterioration. Falcon recommends addressing all existing concrete deficiencies and protecting the concrete from chemical reactions in these areas to avoid further deterioration of the structural components.

Falcon's evaluation of the roof revealed signs of minor deterioration of the roofing system. The observed conditions appear reasonable based on the age of the roofing membrane. Overall, the existing roofing system appears to be in fair condition. Falcon recommends periodic maintenance in order to mitigate/avoid water intrusion issues.

During the evaluation, a curtain wall system was observed covering the exterior of the office building tower and no broken glass panels or water intrusion was observed. Overall, the curtain wall system appears to be in good to fair condition. It is important to address any deficiencies with the curtain wall system to ensure the watertightness of the building envelope.

The painted surface finish of the parking garage appears to be fair to good condition. Although it is not a structural item, painting and filling small (hairline / fine) cracks (if any) will extend the life of the structures.

Based on our inspection findings, the deficiencies in the structural elements observed at the time of our inspections did not warrant a change in the pattern of occupancy and the damages noted were considered "Less than Substantial." We have not identified any condition that represents an imminent danger to the occupants of the building.

Please note that this report is based upon sampling and is not intended to be an all-inclusive, exhaustive list of each location of repair, scope of work, or otherwise. Falcon has advised that repairs of the noted deficiencies should be implemented on the entire property, including the areas where Falcon has not performed the inspections, but these conditions might exist.

As a routine matter, in order to avoid possible misunderstandings, nothing in this report should be construed directly or indirectly as a guarantee of any portion of the structure. To the best of our knowledge and ability, this report represents an accurate appraisal of the present condition of the building based upon evaluation of observed conditions, to the extent reasonably possible.

Falcon recommends that the building should have an updated inspection performed every 8-10 years. In the event of a hurricane, flood, or other significant disaster upon or around the building, an updated inspection should also be performed.

Should you have any questions, please feel free to contact our office at (305) 663-1970.

Respectfully Submitted,

Esther Calle, P.E., FL #80400

Annex "A"

Full Legal Description

CORAL GABLES SEC K PB 8-33

LOTS 15 & 16 LESS BEG 3.21FTW OF

NE COR OF LOT 15 S85FT SWLY

21.21FT E35FT N100FT W20FT TO

POB & LOTS 17 THRU 34 & PORT OF

ALLEY LYG WITHIN CLOSED BY ORD

2011-73 BLK 25


LOT SIZE 51762 SQ FT

OR 18160-1529 0698 5(2)

COC 26362-1481 04 2008 5

Annex "B"

Aerial of the Property Identifying the Building Being Certified



Annex "C"

Site Photographs






Photo # 1. South elevation.

Photo # 2. East elevation.









Photo # 4. West elevation.





Photo # 5. Concrete spalling and exposed corroded rebar at roof (Generator Room).

Photo # 6. Concrete spalling at roof (Generator Room).








Photo #8. Concrete spalling at parking garage.






Photo # 9. Concrete spalling at ceiling of parking garage.

Photo # 10. Concrete spalling at joist beam of parking garage.





Photo # 11. Concrete spalling at ceiling of parking garage.

Photo # 12. Concrete spalling at ceiling of parking garage.





Photo # 13. Concrete spalling at column of parking garage.

Photo # 14. Concrete crack at ceiling of parking garage.








Photo # 16. Concrete spalling at slab edge of parking garage.






Photo # 17. Peeling paint at base of column.

Photo # 18. Paint peeling at roof parapet wall.








Photo # 20. Paint peeling at column.





Photo # 21. Stucco delaminating at parking garage.

Photo # 22. Stucco crack at parking garage.








Photo # 24. Delaminated/de-bonded stucco at roof.





Photo # 25. Concrete spalling at slab edge of parking garage.

Photo # 26. Concrete crack at ceiling of parking garage.








Photo # 28. Previously patched area at parking garage ceiling.





Photo # 29. Previously patched area at parking garage ceiling.

Photo # 30. Previously repaired areas at beam of parking garage.





Photo # 31. Existing gravel Built-Up-Roof (BUR) system.

Photo # 32. Photo # 31. Existing gravel BUR system.





Photo # 33. Cooling tower located at roof.

Photo # 34. Typical roof drain.





Photo # 35. Parapet wall along the perimeter of roof.

Photo # 36. Cooling tower supports.





Photo # 37. Overflow scuppers at roof.

Photo # 38. Ponding water and biological growth at roof under cooling tower.








Photo # 40. Expansion joint between tower and parking garage.






Photo # 41. Reinforced concrete stairs.

Photo # 42. Reinforced concrete stairs.








Photo # 44. Elevator mechanical room.





Photo # 45. Close-up view of elevator sheave beam.

Photo # 46. Close-up view of elevator sheave beam.









Photo # 48. Close-up view of storefronts at lobby of the building.





Photo # 49. Overall view of curtain wall anchors.

Photo # 50. Overall view of curtain wall anchors.








Photo # 52. Window sealant exhibiting typical dry condition.



REGULATORY AND ECONOMIC RESOURCES DEPARTMENT

11805 SW 26th Street, Miami, Florida 33175 786-315-2000 Miamidade.gov/building

MINIMUM INSPECTION PROCEDURAL GUIDELINES FOR BUILDING STRUCTURAL RECERTIFICATION

CASE REFERENCE NUMBER:	LICENSEE NAME: Esther Calle	
	TITLE: Professional Engineer	
JURISDICTION NAME:	ADDRESS: 15405 NW 7th Avenue, Miami, FL 33169	
	SIGNATURE:	
Use separate sheets for additional response	es by referencing the report number.	
1. DESCRIPTION OF BUILDING	, , ,	
a. Name on Title: SunTrust Plaza		
b. Building Street Address: 201 Alhambra	Circle, Coral Gables, FL 33134 Bldg. #: 1	
c. Legal Description: See Annex A	Attached:	
d. Owner's Name: Evelyn L Goldbloom TRS & Goldbloom Family LTD		
e. Owner's Mailing Address: 201 Alham	bra Circle Ste 514 Coral Gablers, FL 33134-5105	
f. Folio Number of Property on which Building	g is Located: 03-4108-006-2040	
g. Building Code Occupancy Classification: ${\bf B}$		
h. Present Use: Commercial		
i. General Description of building (overall des	cription, structural systems, special features):	
201 Alhambra is comprised of fourteen (14) storied (level 13 does not count). Five (5) of stories are		
used for parking garages. Based on visual	assessment of the exposed structural areas, the structural	
system of the building appears to be made	of reinforced concrete columns, beams, and reinforced concrete slabs.	
j. Number of Stories: 13 k.	Is this a Threshold Building as per 553.71(12) F.S. (Yes/No): Yes	
I. Provide an aerial of the property identifying the building being certified on a separate sheet. Attached:		
m. Additional Comments:		
The building was built in 1973. It currer	ntly has 34 suites, with the first floor being comprised of the	
lobby, the Coral Gables Chamber of Commerce, and a bank.		

04/22R1.1

n. Additions to original structure:
- N/A
o. Total Actual Building Area of all floors: Approx. 447,478 S.F.
2. INSPECTIONS
a. Date of Notice of Required Inspection:
b. Date(s) of actual inspection: 3/27/2023 & 03/28/2023
c. Name. license number, discipline of practice, and qualifications of licensee submitting report:
Esther Calle. P.E./S.I. 80400. Professional Engineer. (Structural) Threshold Inspector Limited
d. Description of laboratory or other formal testing, if required, rather than manual or visual procedures:
- No laboratory testing requested.
e. Are Any Structural Repairs Required? (YES/NO): Yes
1. If required, describe, and indicate acceptance:
The exterior envelope of the building, parking garage, and roof exhibit signs of delaminated stucco,
concrete spalling, corroded metals embedded in the structure, and paint failure. There are also isolated
instances of minor concrete spalling at some equipments rooms. The extend of damages is fair.
f. Can the building continue to be occupied while recertification and repairs are ongoing? (YES/NO): Yes
1. Explanation/Conditions:
Based on Falcon's inspection findings, the deficiencies observed in the structural elements did not
warrant a change in the state of occupancy since the damages that were found are considered "Less
than Substantial" with only minor structural repairs being required.
g. Is it recommended that the building be vacated? (YES/NO): No
h. Has the property record been researched for violations or unsafe cases? (YES/NO): No
1. Explanation/Comments:
Property management stated to Falcon that no violations have been posted for the building.

3.	SUPPORTING DATA	
a.	Annex. A	Additional sheets of written data
b.	Annex C.	Photographs provided (where required <u>plus each building elevation</u>)
c.	Annex B.	Drawings or sketches (aerial, site, footprint, etc.)
d.	N/A	Test reports

4. FOUNDATION
a. Describe the building foundation:
Not visible during inspection.
b. Is wood in contact or near soil? (Yes/No): No
c. Signs of differential settlement? (Yes/No): No
d. Describe any cracks or separation in the walls, columns, or beams that signal differential settlement:
N/A
e. Is water drained away from the foundation? (Yes/No): No
f. Is there additional sub-soil investigation required? (Yes/No): No
1. Describe:
-N/A

5. PRESENT CONDITION OF OVERALL STRUCTURE	
a. General alignment: (Note: good, fair, poor, explain if significant)	PROVIDE PHOTO
1. Bulging: Not observed	
2. Settlement: Not observed	
3. Deflections: Not observed	
4. Expansion: Not observed	
5. Contraction: Not observed	

b. Portion showing distress: (Note, beams, columns, structural walls, floor, roofs, other)	PROVIDE PHOTO
Concrete was observed cracked with spalled pieces in the parking garage area and ro	of. See Annex C.
c. Surface conditions: Describe general conditions of finishes, cracking, spalling, peeling, signs of moisture penetration and stains.	PROVIDE PHOTO
Evidence of cracked, delaminated, and de-bonded stucco was noted at several locations on the	
exterior walls, parapet walls, and slab edge throughout the parking garage and roof. The exterior walls on the	
building exhibited coating deficiencies such as paint chalking and peeling. See Annex C.	
d. Cracks: Note location in significant members. Identify crack size as HAIRLINE if barely discernible; FINE if less than 1 mm in width; MEDIUM if between 1- and 2-mm width; WIDE if over 2 mm.	PROVIDE PHOTO
There are some fine to medium cracks at the concrete slab of the parking garage and	roof parapet
wall. See Annex C.	
e. General extent of deterioration: Cracking or spalling of concrete or masonry, oxidation of metals; rot or borer attack in wood.	PROVIDE PHOTO
Isolated areas on the exterior (Parking Garage) and interior (Generato Room) of the building were	
noted with concrete cracking and spalling. The damages are not considered substantial structural	
dEficiencies. In general, the buildings were observed to be in fair conditions. See Annex C.	
f. Previous patching or repairs (Provide description and identify location):	PROVIDE PHOTO
Concrete slab and beams at the parking garage show multiple areas previously patched and	l concrete
crack repairs. See Annex C.	
g. Nature of present loading: (Indicate residential, commercial, storage, other - estimate magnitude fo	r each level)
Commercial	
h. Signs of overloading? (Yes/No): No	
1. Describe:	
N/A	

6. MASONRY BEARING WALL: (Indicate good, fair, poor on appropriate lines) PROVIDE PHOTO
a. Concrete masonry units: Good with isolated cracked areas. See Annex C.
b. Clay tile or terra cota units: N/A
c. Reinforced concrete tie columns: Good. See Annex C.
d. Reinforced concrete tie beams: Good. See Annex C.
e. Lintel: Good.
f. Other type bond beams: N/A PROVIDE PHOTO
g. Exterior masonry finishes (choose those that apply):
1. Stucco: In fair condition with cracked, delaminated, and de-bonded stucco at roof and parking garage
2. Veneer: N/A
3. Paint only: N/A
4. Other (describe):
N/A
h. Interior masonry finishes (choose those that apply): PROVIDE PHOTO
1. Vapor barrier: Not Visible
2. Furring and plaster: X
3. Paneling: N/A
4. Paint only: N/A
5. Other (describe):
N/A
i. Cracks: PROVIDE PHOTO
1. Location (note beams, columns, other): Noted throughout. See Annex C.
2. Description:
Cracks were observed at concrete slab of the garage area
j. Spalling PROVIDE PHOTO
1. Location (note beams, columns, other): Noted through. See Annex C.
2. Description:
Some spalling noted at parking garage area and in generator room at roof.

k. Rebar corrosion (indicate on lines 1-4):	PROVIDE PHOTO
1. None visible:	
2. Minor (patching will suffice):	
3. Significant (but patching will suffice): Patching repairs will suffice to address the conditions at the column	nns, beams, and slabs.
4. Significant (structural repairs required) N/A	
I. Samples chipped out for examination in spalled areas (Yes/No): No	
1. Yes – describe color, texture, aggregate, general quality:	
N/A	
7. FLOOR AND ROOF SYSTEM	
a. Roof (Must provide)	
1. Describe (roof shape, type roof covering, type roof deck, framing system, condition):	PROVIDE PHOTO
Flat roof reinforced concrete slab with gravel Built-Up-Roof (BUR) System in fair condi	tion. See Annex
C.	
Note water tanks, cooling towers, air conditioning equipment, signs, other heavy equipment and condition of supports:	PROVIDE PHOTO
Cooling tower was noted with some corrosion on the frames of equipment; supports are in good	
condition. See Annex C.	
3. Describe roof drainage system, main and overflow, and indicate condition:	PROVIDE PHOTO
Roof drainage system consists of floor drains with overflow scuppers. They are in fair of	condition. See
Annex C.	
4. Describe parapet build and current conditions:	PROVIDE PHOTO
Roof parapet walls are a combination of CMU walls and tie beams with signs of stucco	cracks.
5. Describe mansard build and current conditions:	PROVIDE PHOTO
N/A	

6. Describe roofing membrane/covering and current conditions:	PROVIDE PHOTO
The roof is covered by a gravel Built-Up-Roof (BUR) system with a mechanically anchored metal	
counter-flashing strip and parapet wall. The roofing membrane is in fair condition. However ponding water and biological gro	owth were noted. See
Describe any roof framing member with obvious overloading, overstress, deterioration or excessive deflection:	PROVIDE PHOTO
N/A	
8. Note any expansion joints and condition:	PROVIDE PHOTO
There are expansion joints between the tower and parking garage. They are in fair condition. S	ee
Annex C.	
b. Floor system(s):	
 Describe the floor system at each level, framing, material, typical spans and indicate condition: 	PROVIDE PHOTO
The floor structural system is composed of reinforced concrete slabs supported by a combination of	
concrete beams, concrete columns, and shear walls. The observed structural elements are in good	
condition. See Annex C.	
2. Balconies: Indicate location, framing system, material, and condition:	PROVIDE PHOTO
N/A	
3. Stairs and escalators: indicate location, framing system, material, and condition:	PROVIDE PHOTO
Two reinforced concrete stairs located at east and west elevation. They are in good condition. Se	ee
Annex C.	
4. Ramps: indicate location, framing type, material, and condition:	PROVIDE PHOTO
The ramp is located inside the parking garage, providing access from ground level to the parking levels. The	
structural system is composed of reinforced concrete slabs supported by a combination of beams and concrete columns. The in fair condition but some concrete cracks were noted. See Annex C.	ramps were observed
5. Guardrails: describe type, material, and condition:	PROVIDE PHOTO
Metal railings at the roof stairwell. They are in good condition. See Annex C.	
c. Inspection – note exposed areas available for inspection, and where it was found necessary to open inspection of typical framing members.	ceilings, etc. for
No covered structural elements were inspected. Inspections was limited to visual observations of	
accessible elements only.	

8. STEEL FRAMING SYSTEM	
a. Description of system at each level:	PROVIDE PHOTO
N/A	
b. Steel members: describe condition of paint and degree of corrosion:	PROVIDE PHOTO
N/A	
c. Steel connections: describe type and condition:	PROVIDE PHOTO
N/A	
d. Concrete or other fireproofing: note any cracking or spalling of encased member and note where any covering was removed for inspection:	PROVIDE PHOTO
N/A	
e. Identify any steel framing member with obvious overloading, overstress, deterioration, or excessive deflection (provide location):	PROVIDE PHOTO
N/A	
f. Elevator sheave beams and connections, and machine floor beams: note condition:	PROVIDE PHOTO
Elevator beams are in fair condition without visible signs of distress. See Annex C.	

a. Full description of concrete structural framing system: The structural system of the building is a combination of concrete columns, beams, shear walls, and reinforced concrete slabs. Foundations are not visible. See Annex C. b. Cracking 1. Significant or Not significant: Not Significant 2. Location and description of members affected and type cracking: Concrete slabs and beams at parking garage. See Annex C.

Page **8** of **13**

c. General condition	
Overall, the building structure was observed to be in good condition.	
d. Rebar corrosion – check appropriate line	
1. None visible:	
2. Location and description of members affected and type cracking: PROVIDE PHOTO)
Columns/beams, and concrete slabs located in the parking garage. See Annex C.	
3. Significant but patching will suffice: PROVIDE PHOTO)
Patching repairs will suffice to address the conditions at the columns, beams, and slabs.	
4. Significant: structural repairs required (describe): PROVIDE PHOTO)
N/A	
e. Samples chipped out in spall areas:	
1. No: PROVIDE PHOTO)
2. Yes, describe color, texture, aggregate, general quality:	
N/A	
f. Identify any concrete framing member with obvious overloading, overstress, deterioration, or excessive deflection: PROVIDE PHOTO)
N/A	
10. WINDOWS, STOREFRONTS, CURTAINWALLS AND EXTERIOR DOORS	
a. Windows/Storefronts/Curtainwalls PROVIDE PHOTO)
 Type (Wood, steel, aluminum, vinyl, jalousie, single hung, double hung, casement, awning, pivoted, fixed, other): 	
The tower has an impact fenestration system. The fenestration system is comprised of curtain wall	
and aluminum storefront at the lobby level. See Annex C.	
2. Anchorage: type and condition of fasteners and latches:	
Curtain wall and storefronts are anchored with brackets and bolts to the structure. They were observed	
to be in fair condition, but some corrosion was noted. See Annex C.	

3. Sealant: type and condition of perimeter sealant and at mullions:

Caulking (metal to stucco and metal to metal transitions) were observed to be in working condition. See Annex C

4. Interiors seals: type and condition at operable vents:

N/A

5. General condition:

Overall, the paint coating of the fenestration appears to be in fair condition. The storefront frames at the

ground level appear to be in fair condition with some localized deficiencies. Aditionally, sealant was noted to be in working condition; no water intrusion was reported.

6. Describe any repairs needed:

The glazing system is under an annual maintenance plan

- b. Structural Glazing on the exterior envelope of Threshold Buildings (Yes/No): Yes
 - Previous Inspection Date: Not provided
 - 2. Description of Curtain Wall Structural Glazing and adhesive sealant:

Based on the limited visual inspection of the curtain wall system, it appears to be in fair conditions. The

majority of anchors on the tower were covered, and so they were only observed in the parking garage

area. Some corrosion was noted. The sealant was observed to be in working condition. See Annex C.

3. Describe Condition of System:

System was noted to be in fair condition. See Annex C.

c. Exterior Doors PROVIDE PHOTO

1. Type (Wood, Steel, Aluminum, Sliding Glass Door, other):

The doors in the common areas are composed of aluminum frame and glass panels. Outswing doors

were observed at deck and lobby levels.

2. Anchorage: type and condition of fasteners and latches:

The doors are anchored with fasteners to the structure. They were observed to be in working condition.

3. Sealant: type and condition of sealant:

Sealants (metal to stucco, metal to metal, and glass to metal transitions) were observed to be in

working condition.

Overall, the paint coating of the fenestration appears to be in fair condition. The door frames at the lobby	
level appear to be in fair condition with some localized deficiencies. Additionally, sealant was noted to be in working condit reported.	ion; No water intrusion was
5. Describe any repairs needed:	
Proper surface preparation and painting of the frames, and replacement of the deteriorate	ed sealants and
corroded anchors.	
11. WOOD FRAMING	
a. Fully describe wood framing system:	PROVIDE PHOTO
N/A	
b. Indicate the condition of the following:	PROVIDE PHOTO
1. Walls:	
N/A	
2. Floors:	
N/A	
3. Roof member, roof trusses:	
N/A	
c. Note metal connectors (i.e., angles, plates, bolts, split pintles, other, and note condition):	PROVIDE PHOTO

d. Joints: note if well fitted and still closed:

N/A

N/A

4. General condition:

PROVIDE PHOTO

	_	
e. Drainage: note accumulations of moisture	PROVIDE PHOTO	
N/A		
f. Ventilation: note any concealed spaces not ventilated:	PROVIDE PHOTO	
N/A		
g. Note any concealed spaces opened for inspection:	PROVIDE PHOTO	
N/A		
h. Identify any wood framing member with obvious overloading, overstress, deterioration, or excessing deflection):	PROVIDE PHOTO	
N/A		
12. BUILDING FAÇADE INSPECTION (Threshold Buildings)	PROVIDE PHOTO	
a. Identify and describe the exterior walls and appurtenances on all sides of the building. (Cladding ty appliques, etc.)	/pe, corbels, precast	
The facade of the building is composed of Glass Curtain Wall, and CMU beams and columns with		
smooth stucco finish in the parking garage area. See Annex C.		

b. Identify the attachment type of each appurtenance type (mechanically attached or adhered):

The curtain wall is mechanically attached. Stucco is adhered at the Facade of the parking garage.

c. Indicate the condition of each appurtenance (distress, settlement, splitting, bulging, cracking, loosening of metal anchors and supports, water entry, movement of lintel or shelf angles, or other defects):

Cracked, delaminated, and de-bonded stucco was noted at several locations on columns/beams and

walls of the parking garage and roof.

13. SPECIAL OR UNUSUAL FEATURES IN THE BUILDING	PROVIDE PHOTO
a. Identify and describe any special or unusual feature (i.e. cable suspended structures, tensile fabric roof, lar sculptures, chimneys, porte-cochere, retaining walls, seawalls, etc.)	
N/A	
b. Indicate condition of the special feature, its supports, and connections:	
N/A	

Reset Form





15405 NW 7th Avenue Miami, FL 33169

P (305) 663-1970 TheFalconGroup.us

THERMAL IMAGE REPORT

Client		
Name	201 Alhambra Circle	
Site	201 Alhambra Circle, Coral Gables, FL 33134	
Insp. Date	04/24/2023	

Inspection			
Name	The Falcon Group 15405 NW 7th Avenue Miami, FL 33169		
Thermographer	Juan Tovar		
Sign	04.26.2023.		
Certification No.	271643		
E-mail	jtovar@thefalcongroup.us		
Phone	305-6631970 Ext 736, 786-718-7380		



The analysis criterion of the failure of the component due to temperature difference is based on the ANSI/ NETA MTS standard / NFPA 70B, where the temperature of a component with possible failure is compared with a similar reference component under the same load conditions.

Temperature Differences of 1°C to 3°C	Indicate possible deficiency and warrant investigation		
Temperature Differences of 4°C to 15°C	Indicate deficiency; repairs should be made as time permits		
Temperature Differences of 16°C and above	Indicate major deficiency; repairs should be made immediately		

SUMARY

Equipment	File name	Page number	Maximum temp.	Condition
400A No ID Switchboard	FLIR2124.jpg	5	28.2 °C	NORMAL
ATS	FLIR2110.jpg	6	46.3 °C	NORMAL
600A No ID Switchboard	FLIR2106.jpg	7	26.3 °C	NORMAL
Chiller #1	FLIR2090.jpg	8	99.1 °C	NORMAL
MCC (Right side)	FLIR2016.jpg	9	53.1 °C	NORMAL
MCC (Right side)	FLIR2026.jpg	10	58.6 °C	DEFICIENCY
MCC (Right side)	FLIR2040.jpg	11	29.1 °C	NORMAL
MCC (Left side)	FLIR2050.jpg	12	53.1 °C	NORMAL
MCC (Left side)	FLIR2066.jpg	13	37.8 °C	NORMAL
MB1	FLIR0944.jpg	14	23.1 °C	NORMAL
LC	FLIR0954.jpg	15	34.7 °C	NORMAL
EH	FLIR0968.jpg	16	32.3 °C	NORMAL
No ID Switchboard	FLIR0972.jpg	17	33.3 °C	NORMAL
No ID Switchboard	FLIR0976.jpg	18	36.6 °C	DEFICIENCY
No ID Switchboard	FLIR0984.jpg	19	32.0 °C	DEFICIENCY
Н	FLIR0992.jpg	20	31.8 °C	NORMAL
L1	FLIR1002.jpg	21	29.8 °C	NORMAL
L2	FLIR1010.jpg	22	29.3 °C	NORMAL
L3	FLIR1018.jpg	23	27.4 °C	NORMAL
Busway Tap box	FLIR1024.jpg	24	28.5 °C	NORMAL
MB	FLIR1034.jpg	25	21.7 °C	NORMAL
LC	FLIR1088.jpg	26	27.4 °C	NORMAL
No ID Switchboard	FLIR1038.jpg	27	31.3 °C	NORMAL
Н	FLIR1078.jpg	28	30.3 °C	NORMAL
L1	FLIR1050.jpg	29	29.7 °C	NORMAL
L2	FLIR1062.jpg	30	28.4 °C	NORMAL
L3	FLIR1068.jpg	31	31.4 °C	NORMAL
11L-4	FLIR1098.jpg	32	25.6 °C	NORMAL
11L-4 Panelboard	FLIR1102.jpg	33	23.9 °C	NORMAL
11L-5	FLIR1110.jpg	34	24.1 °C	NORMAL
11L-5 Panelboard	FLIR1112.jpg	35	24.7 °C	NORMAL
11L-6	FLIR1118.jpg	36	24.6 °C	NORMAL
LC	FLIR1124.jpg	37	32.6 °C	NORMAL
LC Panelboard	FLIR1128.jpg	38	27.4 °C	POSSIBLE DEFICIENCY
No ID Switchboard	FLIR1132.jpg	39	30.9 °C	NORMAL
Н	FLIR1158.jpg	40	30.6 °C	NORMAL
L1	FLIR1170.jpg	41	41.9 °C	NORMAL
L2	FLIR1180.jpg	42	27.5 °C	NORMAL
L3	FLIR1184.jpg	43	29.7 °C	NORMAL
LC	FLIR1196.jpg	44	24.4 °C	NORMAL
No ID Switchboard	FLIR1210.jpg	45	53.1 °C	NORMAL

Equipment	File name	Page number	Maximum temp.	Condition
No ID Switchboard	FLIR1216.jpg	46	46.9 °C	DEFICIENCY
No ID Switchboard	FLIR1222.jpg	47	58.2 °C	DEFICIENCY
н	FLIR1228.jpg	48	27.1 °C	NORMAL
L2	FLIR1236.jpg	49	30.9 °C	NORMAL
L1	FLIR1252.jpg	50	31.1 °C	NORMAL
L3	FLIR1258.jpg	51	32.9 °C	NORMAL
LC	FLIR1282.jpg	52	29.9 °C	NORMAL
No ID Switchboard	FLIR1292.jpg	53	25.0 °C	NORMAL
н	FLIR1332.jpg	54	33.2 °C	NORMAL
L1	FLIR1302.jpg	55	27.5 °C	NORMAL
L2	FLIR1308.jpg	56	24.5 °C	NORMAL
L3	FLIR1324.jpg	57	25.0 °C	NORMAL
LC	FLIR1340.jpg	58	30.8 °C	NORMAL
No ID Switchboard	FLIR1346.jpg	59	46.7 °C	NORMAL
No ID Switchboard	FLIR1352.jpg	60	59.6 °C	MAJOR DEFICIENCY
н	FLIR1360.jpg	61	33.8 °C	NORMAL
L1	FLIR1378.jpg	62	28.6 °C	NORMAL
L2	FLIR1382.jpg	63	32.4 °C	NORMAL
L3	FLIR1396.jpg	64	27.2 °C	NORMAL
BUSWAY	FLIR1404.jpg	65	35.2 °C	NORMAL
LC1	FLIR1420.jpg	66	21.3 °C	NORMAL
No ID Panelboard	FLIR1428.jpg	67	21.9 °C	NORMAL
No ID Control Panel	FLIR1436.jpg	68	36.3 °C	NORMAL
LC	FLIR1446.jpg	69	31.8 °C	NORMAL
No ID Switchboard	FLIR1448.jpg	70	30.2 °C	NORMAL
No ID Switchboard	FLIR1450.jpg	71	29.9 °C	NORMAL
н	FLIR1462.jpg	72	33.9 °C	NORMAL
L1	FLIR1478.jpg	73	32.1 °C	NORMAL
L1 Panelboard	FLIR1490.jpg	74	37.0 °C	DEFICIENCY
L2	FLIR1500.jpg	75	32.9 °C	NORMAL
L3	FLIR1510.jpg	76	33.4 °C	NORMAL
No ID Panelboard	FLIR1524.jpg	77	34.0 °C	POSSIBLE DEFICIENCY
6L	FLIR1540.jpg	78	23.5 °C	NORMAL
MB	FLIR1548.jpg	79	24.9 °C	DEFICIENCY
LC	FLIR1558.jpg	80	30.9 °C	NORMAL
No ID Switchboard	FLIR1576.jpg	81	34.4 °C	NORMAL
112.5KVA Transformer	FLIR1564.jpg	82	100.8 °C	NORMAL
6-H	FLIR1590.jpg	83	31.6 °C	NORMAL
L3	FLIR1602.jpg	84	28.7 °C	NORMAL
L2	FLIR1616.jpg	85	28.9 °C	NORMAL
L1	FLIR1626.jpg	86	28.8 °C	NORMAL
No ID Panelboard	FLIR1650.jpg	87	28.2 °C	NORMAL
No ID Panelboard	FLIR1660.jpg	88	23.8 °C	NORMAL
LC	FLIR1664.jpg	89	24.0 °C	NORMAL

Equipment	File name	Page number	Maximum temp.	Condition
No ID Switchboard	FLIR1688.jpg	92	33.8 °C	NORMAL
No ID Switchboard	FLIR1748.jpg	93	25.7 °C	DEFICIENCY
No ID Switchboard	FLIR1696.jpg	94	34.2 °C	DEFICIENCY
SH	FLIR1708.jpg	95	27.3 °C	NORMAL
н	FLIR1714.jpg	96	25.7 °C	NORMAL
L1	FLIR1724.jpg	97	35.8 °C	NORMAL
L2	FLIR1736.jpg	98	36.8 °C	NORMAL
L3	FLIR1774.jpg	99	26.2 °C	NORMAL
L3 Panelboard	FLIR1780.jpg	100	27.0 °C	DEFICIENCY
A	FLIR1762.jpg	101	97.3 °C	NORMAL
No ID Panelboard	FLIR1788.jpg	102	64.7 °C	NORMAL
50KVA Transformer	FLIR1796.jpg	103	38.4 °C	NORMAL
MSB1	FLIR1816.jpg	104	34.9 °C	NORMAL
MSB1	FLIR1822.jpg	105	67.0 °C	NORMAL
MSB2	FLIR1826.jpg	106	67.2 °C	NORMAL
MSB2	FLIR1836.jpg	107	38.2 °C	NORMAL
MSB2	FLIR1846.jpg	108	35.9 °C	MAJOR DEFICIENCY
MSB2	FLIR1844.jpg	109	35.3 °C	DEFICIENCY
MSB3	FLIR1870.jpg	110	78.3 °C	NORMAL
MSB3	FLIR1872.jpg	111	43.8 °C	NORMAL
MSB3	FLIR1886.jpg	112	45.6 °C	MAJOR DEFICIENCY
MSB3	FLIR1902.jpg	113	36.8 °C	DEFICIENCY
MSB3	FLIR1908.jpg	114	98.6 °C	NORMAL
S	FLIR1916.jpg	115	37.0 °C	NORMAL
T-2	FLIR2138.jpg	116	34.2 °C	NORMAL
H1	FLIR1930.jpg	117	107.5 °C	NORMAL
Delta 10th Fl	FLIR1936.jpg	118	49.6 °C	NORMAL
T-1	FLIR1962.jpg	119	56.0 °C	NORMAL
L1	FLIR1978.jpg	120	44.8 °C	NORMAL
ATS 1st floor	FLIR1986.jpg	121	34.7 °C	NORMAL
No ID Switchboard	FLIR1984.jpg	122	45.1 °C	NORMAL
No ID Switchboard	FLIR1992.jpg	123	34.5 °C	NORMAL
No ID Switchboard	FLIR1996.jpg	124	36.0 °C	DEFICIENCY
EH1	FLIR1992.jpg	123	34.5 °C	NORMAL
EH1	FLIR1996.jpg	124	36.0 °C	POSSIBLE DEFICIENCY



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Elevator Machine room
Equipment 400A No ID Switchboard
Component 400A No ID Switchboard

Thermogram index

File name FLIR2124.jpg

Condition NORMAL





Measurements

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			




201 Alhambra Circle, Coral Gables

04/24/2023 Date

Location Roof. Generator room

ATS Equipment ATS Component Thermogram index 2

File name FLIR2110.jpg Condition NORMAL





Measurements

Sp1	27.1 °C
Sp2	27.2 °C
Sp3	27.3 °C
Bx1	
Max	46.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	24.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Roof. Generator room


Equipment 600A No ID Switchboard

Component 600A No ID Switchboard

Thermogram index

File name FLIR2106.jpg

Condition NORMAL





Measurements

Sp1	25.6 °C
Sp2	25.4 °C
Sp3	25.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	24.0 °C

Problem:

Note: No Power.		

None.			




201 Alhambra Circle, Coral Gables

04/24/2023 Date Location Chiller room Chiller #1 Equipment Control panel Component

Thermogram index

File name FLIR2090.jpg Condition

NORMAL





Measurements

Sp1	41.1 °C
Sp2	39.5 °C
Sp3	41.4 °C
Sp4	97.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	25.0 °C

Problem:

None.			

None.		



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Roof. Chiller room
Equipment MCC (Right side)
Component MCC (Right side)

Thermogram index 5

File name FLIR2016.jpg

Condition NORMAL





Measurements

Bx2	
Max	53.1 °C
Вх3	
Max	50.6 °C
Bx1	

44.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	25.0 °C

Problem:

Max

Possible deficiency in circuit CHW PUMP #1.

Recomendation:

See details in thermogram #6.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Roof. Chiller room Equipment MCC (Right side)

Component Switch: CHW PUMP #1

Thermogram index 6

File name FLIR2026.jpg
Condition DEFICIENCY





Measurements

Sp1	58.6 °C
Sp2	51.1 °C
Sp3	52.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	25.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #1.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuse holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Roof. Chiller room Equipment MCC (Right side)

Component Bus bar

Thermogram index

File name FLIR2040.jpg

Condition NORMAL





Measurements

Sp1 28.7 °C

Sp2 28.6 °C

Parameters

Emissivity 0.95
Distance 1.00 m
Atmospheric temp. 25.0 °C

Problem:

None.

Recomendation:

None.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Roof. Chiller room
Equipment MCC (Left side)
Component MCC (Left side)

Thermogram index

File name FLIR2050.jpg

Condition NORMAL





Measurements

Bx2	
Max	49.1 °C
Bx3	
Max	53.1 °C
Bx1	
Max	50.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Roof. Chiller room Equipment MCC (Left side)

Component Bus bar

Thermogram index 9

File name FLIR2066.jpg

Condition NORMAL





Measurements

Sp1	26.1 °C
Sp2	26.2 °C
Sp3	26.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	25.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment ME

Component Panelboard

Thermogram index 10

File name FLIR0944.jpg

Condition NORMAL





Measurements

Sp1	21.3 °C
Sp2	21.2 °C
Sp3	21.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room

Equipment L0

Component Panelboard

Thermogram index 11

File name FLIR0954.jpg

Condition NORMAL





Measurements

Sp1	21.3 °C
Sp2	21.4 °C
Sp3	21.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment E

Component Panelboard

Thermogram index 12

File name FLIR0968.jpg

Condition NORMAL





Measurements

Sp1	22.8 °C
Sp2	23.2 °C
Sp3	22.8 °C
Bx1	
Max	32.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Possible hot spot in circuit breaker #9.

Recomendation:

See details on next Thermogram.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room

Equipment No ID Switchboard

Component Switchboard

Thermogram index 13

File name FLIR0972.jpg

Condition NORMAL





Measurements

Bx2	
Max	28.6 °C
Вх3	
Max	30.1 °C
Bx1	
Max	33.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Possible hot spot in circuit #1, and circuit #6.

Recomendation:

See details in thermograms #14, and 15.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component Switch / Circuit #1

Thermogram index 14

File name FLIR0976.jpg
Condition DEFICIENCY



33.8 °C

33.1 -31.7 -

30.2 -

28.7 -

27.3 -

25.8 -

25.1 °C



Measurements

Sp1	30.3 °C
Sp2	36.6 °C
Sp3	31.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #2.

Recomendation:

-De-energize and remove the fuses.

-Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).

-Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuse holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component Switch / Circuit #6

Thermogram index | 15

File name FLIR0984.jpg
Condition DEFICIENCY





30.5 -

29.5 -

28.4 -

27.4 -

26.3 -

25.3 -

24.8 °C



Measurements

Sp1	32.0 °C
Sp2	28.6 °C
Sp3	27.1 °C

Amperage Measurement

L1	12.6 Amp
L2	32.5 Amp
L3	14.4 Amp

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #1.

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuse holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment

Component Panelboard

Thermogram index 16

File name FLIR0992.jpg

Condition NORMAL





Measurements

Sp1	27.2 °C
Sp2	26.8 °C
Bx2	
Max	30.1 °C
Bx1	
Max	30.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment L:

Component Panelboard

Thermogram index | 17

File name FLIR1002.jpg

Condition NORMAL





Measurements

Sp1	25.9 °C
Sp2	25.9 °C
Sp3	25.7 °C
Sp4	26.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.				



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 18

File name FLIR1010.jpg

Condition NORMAL





Measurements

Sp1	25.3 °C		
Sp2	25.2 °C		

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 14. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 19

File name FLIR1018.jpg

Condition NORMAL





Measurements

Sp1	25.5 °C
Sp2	25.6 °C
Sp3	27.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 14. West air handler-electrical & telephone room


Equipment Busway Tap box
Component Busway Tap box

Thermogram index 20

File name FLIR1024.jpg

Condition NORMAL





Measurements

Sp1	27.2 °C
Sp2	27.9 °C
Sp3	27.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	l
	l
	l
	l
	l
	l

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment M

Component Panelboard

Thermogram index 21

File name FLIR1034.jpg

Condition NORMAL





Measurements

Sp1	19.7 °C
Sp2	19.6 °C
Sp3	20.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment LO

Component Panelboard

Thermogram index 22

File name FLIR1088.jpg

Condition NORMAL





Measurements

Sp1 20.8 °C

Sp2 20.5 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment No ID

Component Switchboard

Thermogram index 23

File name FLIR1038.jpg

Condition NORMAL





Measurements

Bx2	
Max	26.8 °C
Bx1	
Max	31 3 ℃

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	
	l

None.			
1			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment

Component Panelboard

Thermogram index 24

File name FLIR1078.jpg

Condition NORMAL





Measurements

Sp1	24.5 °C
Sp2	24.5 °C
Sp3	24.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment L

Component Panelboard

Thermogram index 25

File name FLIR1050.jpg

Condition NORMAL





Measurements

Bx2	
Max	29.2 °C
ВхЗ	
Max	29.3 °C
Bx1	
Max	29.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	l
	l
	l
	l
	l
	l

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 26

File name FLIR1062.jpg

Condition NORMAL





Measurements

Sp1	24.6 °C
Sp2	24.8 °C
Sp3	24.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 12. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 27

File name FLIR1068.jpg

Condition NORMAL





Measurements

Bx2	
Max	27.7 °C
Bx1	
Max	31.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 12. West air handler-electrical & telephone room

Equipment 11L-4
Component Panelboard

Thermogram index 28

File name FLIR1098.jpg

Condition NORMAL





Measurements

Sp1	20.4 °C
Sp2	20.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 11. West air handler-electrical & telephone room

Equipment 11L-4 Panelboard

Component Main CB
Thermogram index 29

File name FLIR1102.jpg

Condition NORMAL





Measurements

Sp1	20.5 °C
Sp2	20.9 °C
Sp3	20.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 11. West air handler-electrical & telephone room

Equipment 11L-5 Component Panelboard

Thermogram index 30

File name FLIR1110.jpg

Condition NORMAL





Measurements

Sp1	20.7 °C
Sp2	20.3 °C
Sp3	21.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 11. West air handler-electrical & telephone room

Equipment 11L-5 Panelboard Component Bus Connect

Thermogram index 31

File name FLIR1112.jpg

Condition NORMAL





Measurements

Sp1	20.3 °C
Sp2	21.1 °C
Sp3	20.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 11. West air handler-electrical & telephone room

Equipment 11L-6 Component Panelboard

Thermogram index 32

File name FLIR1118.jpg

Condition NORMAL





Measurements

Sp1	20.4 °C
Sp2	20.3 °C
Sp3	24.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room


Equipment LC

Component Panelboard

Thermogram index 33

File name FLIR1124.jpg

Condition NORMAL





Measurements

Sp1 22.4 °C

Bx2

Max 21.4 °C

Parameters

Emissivity 0.95
Distance 1.00 m
Atmospheric temp. 20.0 °C

Problem:

Possible deficiency en CB #1.

Recomendation:

See details in thermogram #34



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room

Equipment LC Panelboard

Component CB #1
Thermogram index 34

File name FLIR1128.jpg

Condition POSSIBLE DEFICIENCY





Measurements

Sp1	27.4 °C
Sp2	22.4 °C
Sp3	22.2 °C

Amperage Measurement

L1	20.8 Amp
L2	1.8 Amp
L3	7.7 Amp

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Circuit breaker #1. A temperature differential is observed between lines 1 and 2-3, The amperage measurement indicates a current unbalance in the load.

Recomendation:

-Ensure all three-phase loading is balanced.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 11. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component No ID Switchboard

Thermogram index 35

File name FLIR1132.jpg

Condition NORMAL





Measurements

Bx2	
Max	30.9 °C
Bx1	
Max	30.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.		



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room


Equipment

Component Panelboard

Thermogram index 36

File name FLIR1158.jpg

Condition NORMAL





Measurements

 Sp1
 25.4 °C

 Sp2
 25.4 °C

 Bx1
 27.0 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room


Equipment L:


Component Panelboard

Thermogram index 37

File name FLIR1170.jpg

Condition NORMAL





Measurements

Sp3	38.7 °C
Sp1	25.6 °C
Sp2	25.7 °C
Bx1	
Max	29.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 38

File name FLIR1180.jpg

Condition NORMAL





Measurements

Sp1	26.3 °C
Sp2	26.8 °C
Sp3	26.2 °C
Bx1	
Max	27.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 11. West air handler-electrical & telephone room

Equipment L3


Component Panelboard

Thermogram index 39

File name FLIR1184.jpg

Condition NORMAL





Measurements

Sp1	26.2 °C
Sp2	26.1 °C
Bx1	
Max	28.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room


Equipment LC

Component Panelboard

Thermogram index 40

File name FLIR1196.jpg

Condition NORMAL





Measurements

Sp1	18.7 °C
Sp2	19.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component No ID Switchboard

Thermogram index 41

File name FLIR1210.jpg

Condition NORMAL





Measurements

BX2	
Max	53.1 °C
Bx1	
Max	40.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Possibles deficiencies in Circuits #1 and 2.

Recomendation:

See details in thermogram #42, and 43.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room


Equipment No ID Switchboard

Component Panelboard

Thermogram index 42

File name FLIR1216.jpg

Condition DEFICIENCY





Measurements

Sp1	46.7 °C
Sp2	36.3 °C
Sp3	36.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #3.

Recomendation:

-De-energize and remove the fuses.

-Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).

-Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuse holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 10. West air handler-electrical & telephone room

Equipment No ID Switchboard

Component Panelboard

Thermogram index 43

File name FLIR1222.jpg
Condition DEFICIENCY





Measurements

Sp1	58.2 °C	
Sp2	46.7 °C	
Sp3	52.4 °C	

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #1.

Recomendation:

-Ensure all three-phase loading is balanced.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room


Equipment

Component Panelboard

Thermogram index 44

File name FLIR1228.jpg

Condition NORMAL





Measurements

 Sp1
 24.7 °C

 Sp2
 25.1 °C

 Bx1
 25.1 °C

27.1 °C

Parameters

Emissivity 0.95
Distance 1.00 m
Atmospheric temp. 20.0 °C

Problem:

Max

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 45

File name FLIR1236.jpg

Condition NORMAL





Measurements

	25.6 °C
Sp2	25.6 °C
Bx1	
Max	30.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room

Equipment L1

Component Panelboard

Thermogram index 46

File name FLIR1252.jpg

Condition NORMAL





Measurements

Sp1	25.2 °C
Sp2	25.0 °C
Sp3	24.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 10. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 47

File name FLIR1258.jpg

Condition NORMAL





Measurements

Sp1	25.6 °C
Sp2	25.5 °C
Bx1	
Max	32.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 9. West air handler-electrical & telephone room


Equipment LO

Component Panelboard

Thermogram index 48

File name FLIR1282.jpg

Condition NORMAL





Measurements

Sp1	20.6 °C
Sp2	20.7 °C
Sp3	20.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	l
	l
	l
	l
	l
	l

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 9. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component No ID Switchboard

Thermogram index 49

File name FLIR1292.jpg

Condition NORMAL





Measurements

Bx2		
Max	24.9 °C	
Bx1		
Max	25.0 °C	

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 9. West air handler-electrical & telephone room


Equipment

Component Panelboard

Thermogram index 50

File name FLIR1332.jpg

Condition NORMAL





Measurements

Sp1	24.7 °C
Sp2	25.2 °C
Bx1	
Max	33.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 9. West air handler-electrical & telephone room


Equipment L:


Component Panelboard

Thermogram index 51

File name FLIR1302.jpg

Condition NORMAL





Measurements

Sp1	24.6 °C
Sp2	24.6 °C
Sp3	24.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 9. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 52

File name FLIR1308.jpg

Condition NORMAL





Measurements

Sp1	23.8 °C
Sp2	23.7 °C
Sp3	23.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 9. West air handler-electrical & telephone room

Equipment L3

Component Panelboard

Thermogram index 53

File name FLIR1324.jpg

Condition NORMAL





Measurements

Sp1	23.9 °C
Sp2	23.9 °C
Sp3	23.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room


Equipment LC

Component Panelboard

Thermogram index 54

File name FLIR1340.jpg

Condition NORMAL





Measurements

Sp1 22.4 °C

Sp2 22.1 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.

Recomendation:

None.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room


Equipment No ID Switchboard

Panelboard Component

Thermogram index 55

File name FLIR1346.jpg

Condition NORMAL





Measurements

Sp1 25.3 °C Sp2 25.7 °C Bx1

Max

46.7 °C

Parameters

0.95 Emissivity Distance 1.00 m 20.0 °C Atmospheric temp.

Problem:

Deficiency in circuit #1.

Recomendation:

See details in thermogram #56.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 8. West air handler-electrical & telephone room

Equipment No ID Switchboard

Component Circuit #1
Thermogram index 56

File name FLIR1352.jpg

Condition MAJOR DEFICIENCY





Measurements

Sp1	40.3 °C
Sp2	59.6 °C
Sp3	41.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holders #1 and 2.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Check internal blades and perform maintenance.
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuses holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room

Equipment


Component Panelboard

Thermogram index 57

File name

FLIR1360.jpg

Condition NORMAL





Measurements

Sp1	26.0 °C
Sp2	27.1 °C
Sp3	26.7 °C
Bx1	
Max	31.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room


Equipment L:

Component Panelboard

Thermogram index 58

File name FLIR1378.jpg

Condition NORMAL





Measurements

Sp1	27.1 °C
Sp2	27.3 °C
Sp3	27.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room

Equipment L


Component Panelboard

Thermogram index 59

File name FLIR1382.jpg

Condition NORMAL





Measurements

Sp1	25.7 °C
Sp2	25.7 °C
Bx2	
Max	29.9 °C
Bx1	
Max	32.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 60

File name FLIR1396.jpg

Condition NORMAL





Measurements

Sp1	25.3 °C
Sp2	25.6 °C
Sp3	25.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 8. West air handler-electrical & telephone room

Equipment Busway
Component Busway joint

Thermogram index 61

File name FLIR1404.jpg

Condition NORMAL





Measurements

Sp1	34.9 °C
Sp2	32.0 °C
Sp3	30.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. East air handler-electrical & telephone room


Equipment LC1

Component Panelboard

Thermogram index 62

File name FLIR1420.jpg

Condition NORMAL





Measurements

Sp1	19.8 °C
Sp2	20.5 °C
Sp3	19.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 8. East air handler-electrical & telephone room

Equipment No ID Panelboard Component Panelboard

Thermogram index 63

File name FLIR1428.jpg

Condition NORMAL





Measurements

Sp1	19.7 °C
Sn2	10 0 ℃

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 8. East air handler-electrical & telephone room


Equipment No ID Control Panel

Component Contactors

Thermogram index 64

File name FLIR1436.jpg

Condition NORMAL





Measurements

Bx1Max 36.3 °C

Bx2

Max 31.8 °C

Parameters

Emissivity 0.95

Distance 1.00 m

Atmospheric temp. 20.0 °C

Problem:

None.

None.



201 Alhambra Circle, Coral Gables

04/24/2023 Date

Location Level 7. West air handler-electrical & telephone room

Equipment LC

Component Panelboard

Thermogram index 65

File name FLIR1446.jpg

Condition NORMAL





Measurements

Sp1 22.3 °C

Sp2 21.4 °C

Parameters

Atmospheric temp.

0.95 Emissivity Distance 1.00 m 20.0 °C

Problem:

None.

Recomendation:

None.



201 Alhambra Circle, Coral Gables

04/24/2023

Location Level 7. West air handler-electrical & telephone room


Equipment No ID Switchboard

Component Busbar Thermogram index 66

Date

File name FLIR1448.jpg

Condition NORMAL





Measurements

Sp1	25.6 °C
Sp2	25.3 °C
Sp3	25.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment No ID Switchboard

FLIR1450.jpg

Component Switches

Thermogram index 67

File name

Condition NORMAL





Measurements

Sp1	28.0 °C
Sp2	26.0 °C
Bx2	
Max	29.8 °C
Bx1	
Max	29.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	l
	l
	l
	l
	l
	l

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment

Component Panelboard

Thermogram index 68

File name FLIR1462.jpg

Condition NORMAL





Measurements

Sp1	25.3 °C
Sp2	25.3 °C
Sp3	25.2 °C
Bx1	
Max	29.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	l
	l
	l
	l
	l
	l

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment L:

Component Panelboard

Thermogram index 69

File name FLIR1478.jpg

Condition NORMAL





Measurements

 Sp1
 25.6 °C

 Sp2
 25.2 °C

 Bx1

Parameters

Emissivity 0.95
Distance 1.00 m
Atmospheric temp. 20.0 °C

Problem:

Deficiency in circuit 41.

Recomendation:

See details in thermogram #70.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment L1 Panelboard Component Circuit 41

Thermogram index 70

File name FLIR1490.jpg
Condition DEFICIENCY





Measurements

Sp1	37.0 °C
Sp2	36.5 °C
Sp3	27.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Hot spot in circuit #41, and bar with signs of overheating.

- -Remove conductor, and circuit breaker.
- -Inspect circuit breaker, busbar and screws.
- -Replace circuit breaker if necessary.
- -Clean the parts, and install circuit breaker (apply torque according to manufacturer specifications.).



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment L2

Component Panelboard

Thermogram index 71

File name FLIR1500.jpg

Condition NORMAL





Measurements

Bx1	
Max	32.9 °C
Sp1	25.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 7. West air handler-electrical & telephone room

Equipment L3

Component Panelboard

Thermogram index 72

File name FLIR1510.jpg

Condition NORMAL





Measurements

Sp1	25.3 °C
Sp2	25.3 °C
Sp3	25.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 7. West air handler-electrical & telephone room

Equipment No ID Panelboard

Component Panelboard Thermogram index 73

File name FLIR1524.jpg

Condition POSSIBLE DEFICIENCY





Measurements

Sp1	25.6 °C
Sp2	25.8 °C
Sp3	25.6 °C
Bx1	
Max	34.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Circuit breaker #29: Circuit breaker loose, poor contact.

Recomendation:

-Remove circuit breaker.

-Inspect circuit breaker, busbar and screws.

-Replace circuit breaker if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room


Equipment 6

Component Panelboard

Thermogram index 74

File name FLIR1540.jpg

Condition NORMAL





Measurements

Sp1	21.4 °C
Sp2	21.3 °C
Sp3	21.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 6. West air handler-electrical & telephone room

Equipment MI

Component Panelboard

Thermogram index 75

File name FLIR1548.jpg
Condition DEFICIENCY





Measurements

Sp1	23.8 °C
Sp2	24.0 °C
Sp3	23.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Circuit breaker #16 is broken.

necomendation.
Replace circuit breaker.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room


Equipment LC

Component Panelboard

Thermogram index 76

File name FLIR1558.jpg

Condition NORMAL





Measurements

Sp1 21.0 °C

Sp2 21.2 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.

Recomendation:

None.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room

Equipment No ID Switchboard
Component No ID Switchboard

Thermogram index 77

File name FLIR1576.jpg

Condition NORMAL





Measurements

BX2	
Max	29.0 °C
Bx1	
Max	30.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room

Equipment 112.5KVA Transformer Component 112.5KVA Transformer

Thermogram index 7

File name FLIR1564.jpg

Condition NORMAL





Measurements

Sp1	29.1 °C
Sp2	24.9 °C
Sp3	26.4 °C
Sp4	35.7 °C
Sp5	35.6 °C
Sp6	35.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room

Equipment 6-

Component Panelboard

Thermogram index 79

File name FLIR1590.jpg

Condition NORMAL





Measurements

 Sp1
 26.1 °C

 Sp2
 26.3 °C

Bx1

Max 31.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	Ì
	Ì
	Ì
	Ì
	ĺ
	l
	ı

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 80

File name FLIR1602.jpg

Condition NORMAL





Measurements

 Sp1
 25.2 °C

 Sp2
 25.2 °C

Bx1

Max 28.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 81

File name FLIR1616.jpg

Condition NORMAL





Measurements

 Sp1
 25.2 °C

 Sp2
 25.2 °C

Bx1

Max 28.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 6. West air handler-electrical & telephone room

Equipment L1


Component Panelboard


Thermogram index 82

File name FLIR1626.jpg

Condition NORMAL







Measurements

 Sp1
 25.1 °C

 Sp2
 25.2 °C

Bx1

Max 28.8 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

04/24/2023 Date

Location Level 6. West air handler-electrical & telephone room


Equipment No ID Panelboard

Panelboard Component

Thermogram index 83

File name FLIR1650.jpg

Condition NORMAL





Measurements

20.5 °C Sp1 20.7 °C Sp2 Bx1

Max 22.4 °C

Parameters

0.95 Emissivity Distance 1.00 m 20.0 °C Atmospheric temp.

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 5. West air handler-electrical & telephone room

Equipment No ID Panelboard
Component Main Circuit breaker

Thermogram index 84

File name FLIR1660.jpg

Condition NORMAL





Measurements

Sp1	21.1 °C
Sp2	21.1 °C
Sp3	21.2 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment LC

Component Panelboard

Thermogram index 85

File name FLIR1664.jpg

Condition NORMAL





Measurements

Sp1 21.8 °C

Sp2 21.8 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.	1
	Ì
	1
	1
	Ì
	Ì
	ı

None.				



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment No ID Switchboard

Component Switchboard

Thermogram index 86

File name FLIR1668.jpg

Condition NORMAL





Measurements

Bx2	
Max	30.8 °C
Вх3	
Max	32.8 °C
Bx1	
Max	35.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Deficiencies in Circuit #1 and 4.

Recomendation:

See details in thermograms #87, and 88.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room

Equipment No ID Switchboard

Component Circuit #1

Thermogram index 87

Condition

File name FLIR1678.jpg

DEFICIENCY





Measurements

Sp1	38.0 °C
Sp2	30.1 °C
Sp3	28.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	24.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holder #3.

Recomendation:

-De-energize and remove the fuses.

-Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).

-Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuses holder if necessary.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 5. West air handler-electrical & telephone room

Equipment No ID Switchboard

Component Circuit #4
Thermogram index 88

File name FLIR1688.jpg

Condition DEFICIENCY





Measurements

Sp1	33.8 °C
Sp2	27.0 °C
Sp3	26.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

A temperature differential is observed between the fuses, hot spot at the fuse holder #2.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse.
- -Replace fuses and/or fuses holder if necessary.
- -All three fuses should be the same type and size.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment S

Component Panelboard

Thermogram index 89

File name FLIR1748.jpg

Condition NORMAL





Measurements

Sp1 24.1 °C

Sp2 24.2 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room

Equipment

Component Panelboard

Thermogram index 90

File name FLIR1696.jpg

Condition NORMAL





Measurements

Sp1	24.7 °C
Sp2	24.8 °C
Bx1	

Max 28.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.	

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment L:

Component Panelboard

Thermogram index 91

File name FLIR1708.jpg

Condition NORMAL





Measurements

Sp1	24.1 °C
Sp2	24.4 °C
Sp3	24.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment L2

Component Panelboard

Thermogram index 92

File name FLIR1714.jpg

Condition NORMAL





Measurements

Sp1	25.0 °C
Sp2	25.0 °C
Sp3	24.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Level 5. West air handler-electrical & telephone room


Equipment L3

Component Panelboard

Thermogram index 93

File name FLIR1724.jpg

Condition NORMAL





Measurements

Sp1	26.6 °C
Sp2	27.4 °C
Bx2	
Max	30.9 °C
Bx1	
Max	35.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Deficiency in circuit #40.				

See details in therm	ogram #94.	



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Level 5. West air handler-electrical & telephone room


Equipment L3 Panelboard

Component CB #40
Thermogram index 94

File name FLIR1736.jpg

Condition DEFICIENCY





Measurements

	I .		
Sp1	2	6.9	°C

Bx1

Max 36.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

Hot spot in circuit #40, and bar with signs of overheating.

- -Remove conductor, and circuit breaker.
- -Inspect circuit breaker, busbar and screws.
- -Replace circuit breaker if necessary.
- -Clean the parts, and install circuit breaker (apply torque according to manufacturer specifications.).



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Parking garage - Storage


Equipment /

Component Panelboard

Thermogram index 95

File name FLIR1774.jpg

Condition NORMAL





Measurements

Sp1 24.4 °C	Sp1	24.4 °C
--------------------	-----	---------

Sp2 24.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Parking garage - Storage


Equipment No ID Panelboard

Component Panelboard

Thermogram index 96

File name FLIR1780.jpg

Condition NORMAL





Measurements

Sp1 24.6 °C

Sp2 24.9 °C

Bx1

Max 26.4 °C

Parameters

Emissivity 0.95 Distance 1.00 m Atmospheric temp. 20.0 $^{\circ}$ C

Problem:

None.			

None.



201 Alhambra Circle, Coral Gables

04/24/2023


Location Parking garage - Storage
Equipment 50KVA Transformer
Component 50KVA Transformer

Thermogram index

Date

File name FLIR1762.jpg

Condition NORMAL





Measurements

Sp1	31.5 °C
Sp2	32.9 °C
Sp3	32.2 °C
Sp4	26.3 °C
Sp5	25.0 °C
Sp6	25.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	20.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room

Equipment MSB1
Component Fuses
Thermogram index 98

File name FLIR1788.jpg

Condition NORMAL





Measurements

Sp1	32.4 °C
Sp2	32.6 °C
Sp3	31.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room

Equipment MSB1
Component Bus bar
Thermogram index 99

File name FLIR1796.jpg

Condition NORMAL





Measurements

Sp1	36.4 °C
Sp2	36.2 °C
Sp3	34.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room

Equipment MSB2
Component Bus bar
Thermogram index 100

File name FLIR1816.jpg

Condition NORMAL





Measurements

Sp1	32.9 °C
Sp2	33.1 °C
Sp3	33.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment MSB2

Component Circuit #1 Fire pump ATS Switch

Thermogram index 101

File name FLIR1822.jpg

Condition NORMAL





Measurements

Sp1	30.9 °C
Sp2	31.1 °C
Sp3	31.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room

Equipment MSB2

Component Circuit 2 ATS

Thermogram index 102

File name FLIR1826.jpg

Condition MAJOR DEFICIENCY





Measurements

Sp1	67.2 °C
Sp2	48.4 °C
Sp3	57.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

A temperature differential is observed between the fuses holder, hot spot at the fuse holder #1, and 2.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Check internal switch blades and perform maintenance.
 -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse.
 -Replace fuses and/or fuses holder if necessary.
- -All three fuses should be the same type and size.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Main Electrical room

Equipment MSB2

Component Circuit #3 Elevator

Thermogram index 103

File name FLIR1836.jpg
Condition DEFICIENCY





Measurements

Bx2	
Max	38.2 °C
Bx3	
Max	32.6 °C
Bx1	
Max	36.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

A temperature differential is observed between the fuses holder, hot spot at the fuse holder #2.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Check internal switch blades and perform maintenance.
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse.
- -Replace fuses and/or fuses holder if necessary.



201 Alhambra Circle, Coral Gables


Date 04/24/2023


Location Main Electrical room

Equipment MSB3
Component Bus bar
Thermogram index 104

File name FLIR1846.jpg

Condition NORMAL





Measurements

Sp1	35.8 °C
Sp2	35.0 °C
Sa3	34.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.		

None.			




201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room

Equipment MSB3
Component Bus bar
Thermogram index 105

File name FLIR1844.jpg
Condition NORMAL





Measurements

Sp1	33.1 °C
Sp2	33.2 °C
Sp3	33.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room

Equipment MSB3


Component Feeder Circuir #1 (H1)

Thermogram index 106

File name FLIR1870.jpg

Condition MAJOR DEFICIENCY





Measurements

Sp1	78.3 °C
Bx2	
Max	33.3 °C
Bx1	
Max	65.3 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

Circuit #1: Hot spot at feeder line #1.	

Recomendation:

Replace conductor and lug, and perform maintenance.



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Main Electrical room

Equipment MSB3

Component Feeder Circuir #1 (H1)

Thermogram index 107

File name FLIR1872.jpg
Condition DEFICIENCY





Measurements

Sp1	43.8 °C
Sp2	34.5 °C
Sp3	33.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

A temperature differential is observed between the fuses holder, possible hot spot at the fuse holder #1.

Recomendation:

-Perform preventive maintenance.

-Ensure all three-phase loading is balanced.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room

Equipment MSB3
Component Fuses
Thermogram index 108

File name FLIR1886.jpg

Condition NORMAL





Measurements

Sp1	36.4 °C
Sp2	35.7 °C
Sp3	35.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment !

Component Panelboard

Thermogram index 109

File name FLIR1886.jpg

Condition NORMAL





Measurements

Sp1	32.1 °C
Sp2	32.0 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment T-2

Component 50KVA Transformer

Thermogram index 110

File name FLIR1908.jpg

Condition NORMAL





Measurements

Sp1	39.4 °C
Sp2	40.3 °C
Sp3	39.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.		

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment H1


Component Panelboard

Thermogram index 111

File name FLIR1916.jpg

Condition NORMAL





Measurements

 Sp1
 32.1 °C

 Sp2
 32.2 °C

 Bx1
 32.2 °C

Parameters

Emissivity 0.95
Distance 1.00 m
Atmospheric temp. $28.0 \,^{\circ}\text{C}$

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Main Electrical room

Equipment Delta 10th FI
Component Disconnect switch

Thermogram index 112

File name FLIR2138.jpg

Condition NORMAL





Measurements

Sp1	32.0 °C
Sp2	32.0 °C
Sp3	31.6 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment T-1

Component 30KVA Transformer

Thermogram index 113

File name FLIR1930.jpg

Condition NORMAL





Measurements

Sp1	56.0 °C
Sp2	56.5 °C
Sp3	56.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment L1

Component Panelboard

Thermogram index 114

File name FLIR1936.jpg

Condition NORMAL





Measurements

Sp3	46.3 °C
Sp1	32.8 °C
Sp2	32.7 °C
Bx2	
Max	40.9 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.	1
	Ì
	1
	1
	Ì
	Ì
	ı

None.			



201 Alhambra Circle, Coral Gables

Date 04/24/2023


Location Main Electrical room

Equipment ATS 1st floor

Component ATS
Thermogram index 115

File name FLIR1962.jpg

Condition NORMAL





Measurements

Sp1	36.0 °C
Sp2	37.6 °C
Sp3	36.8 °C
Bx1	
Max	51.1 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.

None.			



201 Alhambra Circle, Coral Gables

04/24/2023

Location Main Electrical room Equipment No ID Switchboard


Component Switchboard

Thermogram index 116

Date

File name FLIR1978.jpg

Condition NORMAL





Measurements

Bx2	
Max	44.8 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

Bx1

Deficiency in circuit #4.

Recomendation:

See details in thermogram #118.



201 Alhambra Circle, Coral Gables

04/24/2023


Location Main Electrical room Equipment No ID Switchboard

Component Bus bar
Thermogram index 117

Date

File name FLIR1986.jpg

Condition NORMAL





Measurements

Sp1	31.9 °C
Sp2	32.4 °C
Sp3	32.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

None.			

None.			



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room Equipment No ID Switchboard

Component Circuit #4
Thermogram index 118

File name FLIR1984.jpg

Condition NORMAL





Measurements

Sp1	38.1 °C
Sp2	45.0 °C
Sp3	33.7 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

A temperature differential is observed between the fuses.

- -De-energize and remove the fuses.
- -Clean the fuse and fuse holders, and check the screws torque of the fuse holders (Proper torque should be applied).
- -Reinsert the fuse ensuring the fuse holders are providing adequate tension and making good contact with the fuse. -Replace fuses and/or fuses holder if necessary.
- -Ensure all three-phase loading is balanced.



201 Alhambra Circle, Coral Gables

Date 04/24/2023

Location Main Electrical room


Equipment EH1

Component Panelboard

Thermogram index 119

File name FLIR1992.jpg

Condition NORMAL





Measurements

Bx2	
Max	33.8 °C
Bx1	

Max 34.5 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

Possible deficiency in Circuit breaker #5.

Recomendation:

See details in thermogram #120.



201 Alhambra Circle, Coral Gables


Date 04/24/2023

Location Main Electrical room

Equipment EH1
Component Circuit #5
Thermogram index 120

File name FLIR1996.jpg

Condition POSSIBLE DEFICIENCY





Measurements

Sp1	36.0 °C
Sp2	34.4 °C

Parameters

Emissivity	0.95
Distance	1.00 m
Atmospheric temp.	28.0 °C

Problem:

Double tapping in circuits 2, 4, 5 and 6.

Repair tapping properly.		

Annex

Thermographer Certificate

