



Home Citizen Services Business Services Back to Coral Gables.com

Permits and Inspections: Actions

Logon Help Contact

	ME-17-11-1507	Applied	Approved	Issued	Final	Expires
		11/09/2017	08/07/2018	08/07/2018		04/19/2020

Type **MECH COMMERCIAL / RESIDENTIAL WORK**

Status **stop work**

Permit Description

Permit Address **1559 SAN BENITO AVE CORAL GABLES FL 33134**

INSTALL HVAC PER PLAN INCLUSIVE RESIDENCE

Applicant **TYCOON FLOW CONTROL CORPORATIO** Owner **N**

Owner **ATELIER PREMIUM BUILDERS LLC**

Viewing <-- Select the information you would like to view.

Group	Action	Approver	Start Date	Comp'd Date	Comp'd Code	Comment
PERMIT PROCESSING	ppappl - APPLICATION/LICENSE/OWNERSHIP VERIFICATION	ebermudez1		08/06/2018	COMPLETED	
PERMIT PROCESSING	calc fees2 - CALCULATE FEES	mreboiro		08/07/2018	COMPLETED	
PERMIT PROCESSING	apmech - MECHANICAL APPLICATION REVIEW	mreboiro		08/07/2018	APPROVED	
CASHIER	collect - COLLECT FEES	iwebuser		08/07/2018		
INSPECTION	me001 - FINAL MECHANICAL					
INSPECTION	me001 - FINAL MECHANICAL	mreboiro	02/12/2019	02/12/2019	REJECTED	NOT READY FOR FINAL
INSPECTION	me063 - MECHANICAL ROUGH A/C	mreboiro	02/12/2019	02/12/2019		1- MISSING AHU CLOSET DOORS 2- CONDENSING UNITS TO CLOSE TO WALL AND TO EACHOTHER, UNITS SPECS ARE REQUIRED
INSPECTION	me086 - MECHANICAL ROUGH DUCT	mreboiro	08/08/2018	08/08/2018	REJECTED	GRILLES NOT AS PER APPROVED PLAN, A REVISION IS REQUIRE INSPECTED BY JOHN GRAVES FROM MTCI
INSPECTION	me086 - MECHANICAL ROUGH DUCT	mreboiro	02/12/2019	02/12/2019	APPROVED	
INSPECTION	me116 - MECHANICAL ROUGH VENTILATION DUCTWORK					
INSPECTION	me116 - MECHANICAL ROUGH VENTILATION DUCTWORK	mreboiro	02/12/2019	02/12/2019	REJECTED	1- MISSING KITCHEN HOOD 2- MISSING EXHAUST FAN ON 2ND FLOOR BATH

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).