



Applied Digital Programming Technologies, Inc.

A Full Document Management Company

14355 SW 142nd Street Miami, Fl.33186

Tel. (305) 254-7658 Fax (305) 254-5523

Web www.adpt.net e-mail adpt@bellsouth.net

Starting Set of Images For ICN



355936


Application No. Permit No.

Address

0

90 SEVILLA AVE.

QC By : Operator No. 12



Residence for	Mr. Dominick Masissa	All duct work to be in galvanized sheet metal insulated with one inch insul.
Legal	Lots 1-243 Block 21	Insul. 2 1/2" thick
Craft Section		All joints covered by sheet metal screws
Job address	90 Sevilla Ave.	Do not let out pipes to be at 200 in. m.
		Elect. Notes:
		Comp. 240 amps 220v. 1 φ 4 P.
		Cond. Fan 3.5 amps 220v. 1 φ 1/2 H.P.
		Exp. Fan 7.5 amps 115V. 1 φ 1/2 H.P.

90 Sevilla

APPROVED BY THE BOARD

FOR THE BOARD OF
MINE GRADERS

NO AIR CONDITIONING UNITS
REMOVED IN REQUIRED SET

H.K. Eiler

R.S. Paluck

Shunt
Air Conditioning Inspector

19