



[Home](#)
[Citizen Services](#)
[Business Services](#)
[Back to Coral Gables.com](#)

Permits and Inspections: Actions

[Logon](#)
[Help](#)
[Contact](#)



BL-18-04-2837

Applied	Approved	Issued	Final	Expires
04/04/2018	07/06/2018	07/17/2018		04/09/2021

Type **POOL / SPA / FOUNTAIN / POND**

Status **stop work**

Permit Description

Permit Address **6621 SANTONA ST CORAL GABLES FL 33146-3111**

NEW SWIMMING POOL \$30,000

Applicant **WORLDWIDE POOLS CORP** Owner **N**

Owner **ROBERTO GONZALEZ & W ESTHER &**

Viewing **Actions**

<-- Select the information you would like to view.

Group	Action	Approver	Start Date	Comp'd Date	Comp'd Code	Comment
PLAN REVIEW	pradmin - ADMINISTRATIVE BOARD OF ARCHITECTS PLAN REVIEW	cmindreau		03/30/2018	APPROVED	
PLAN REVIEW	ppaipp - ART IN PUBLIC PLACES	ccathers		04/04/2018	WAIVED	
PLAN REVIEW	prbuild - BUILDING PLAN REVIEW	mlopez	04/25/2018	04/25/2018	APPROVED	
PLAN REVIEW	prelec - ELECTRICAL PLAN REVIEW	areyes	04/04/2018	04/05/2018	APPROVED	
PLAN REVIEW	prplbg - PLUMBING PLAN REVIEW	rperez2	04/05/2018	04/05/2018	REJECTED	1- REQUIRED DEPT OF HEALTH APPROVAL ON NEW PLANS SUBMITTED BY NEW E.O.R. 2- PROVIDE DETAIL ELEVATION FOR GRAVITY GUTTER AROUND PERIMETER OF POOL 3- GRAVITY GUTTER PIPING NOT SHOWN ON ISO-DRAWING 4- MAIN DRAIN VENT LINE TERMINATION POINT NOT SHOWN ON POOL LAYOUT 5- PROVIDE VENT LINE LENGTH SCHEDULE ON PLANS
PLAN REVIEW	prplbg - PLUMBING PLAN REVIEW	rperez2	07/02/2018	07/06/2018	APPROVED	
PLAN REVIEW	prpworks - PUBLIC WORKS PLAN REVIEW	emunoz	04/10/2018	04/10/2018	APPROVED	
PLAN REVIEW	prstr - STRUCTURAL PLAN REVIEW	dreczek	04/11/2018	04/19/2018	REJECTED	New drawings show pool excavation

							located closer to the existing residence than that referenced within the previously approved Building Permit (BL-17-10-1544) - please provide a revised letter from the Geotechnical Engineer certifying bearing capacity of soil below existing residence foundations (new pool excavations are within the 45-degree of angle of repose for a typical soil referenced within the FBC).
PLAN REVIEW	prstr - STRUCTURAL PLAN REVIEW	dreczek	06/14/2018	06/28/2018	APPROVED		
PLAN REVIEW	przoning - ZONING PLAN REVIEW	etejera	04/27/2018	05/09/2018	APPROVED		
PLAN PROCESSING	ppappl - APPLICATION/LICENSE/OWNERSHIP VERIFICATION	carguinzon		07/13/2018	COMPLETED		
PLAN PROCESSING	calc fees - CALCULATE FEES	carguinzon		07/13/2018	COMPLETED		
PLAN PROCESSING	pppoolencl - PROTECTIVE ENCLOSURE FORM - POOL/SPA	carguinzon		07/13/2018	INCOMPLETE	MISSING THE POOL ENCLOSURE FORM	
PLAN PROCESSING	pppoolencl - PROTECTIVE ENCLOSURE FORM - POOL/SPA	ebermudez1		07/17/2018	COMPLETED		
CASHIER	collect - COLLECT FEES	iwebuser		07/17/2018			
NOTICE OF COMMENCEMENT	ppnoc - NOTICE OF COMMENCEMENT	dgarcia		07/17/2018	COMPLETED		
INSPECTION	pcompdate - REQUIRED PERMIT COMPLETION DATE	ahernande2		07/15/2020	COMPLETED		
INSPECTION	bi084 - FINAL BUILDING						
INSPECTION	bi084 - FINAL BUILDING	insppp	10/19/2018	10/19/2018	REJECTED	MTCI insp. G. Earl.NEED ACCESS FOR DOOR ALARM	
INSPECTION	pw837 - FINAL PUBLIC WORKS (BLDG PERMIT)						
INSPECTION	pw837 - FINAL PUBLIC WORKS (BLDG PERMIT)	agracia	10/19/2018	10/19/2018	REJECTED	REPLACE ALL DAMAGED SIDEWALKS, SEPARATE PUBLIC WORKS PERMIT IS REQUIRED. LEVEL AND RESOD ALL DAMAGED AREAS.	
INSPECTION	zn004 - FINAL ZONING						
INSPECTION	zn004 - FINAL ZONING	cgonzalez	10/19/2018	10/19/2018	REJECTED	POOL ENCLOSURE NOT COMPLETE.	

							POOL ENCLOSURE NOT AS PER APPROVED SET OF PLANS. LEVEL AND RESOD DAMAGED AREAS. POOL EQUIPMENT SCREENING NOT COMPLETE
INSPECTION	zn004 - FINAL ZONING	bmorales	04/18/2019	04/17/2019	CANCELLED		
INSPECTION	bl213 - POOL STEEL & MAIN DRAIN	jglesias2	08/06/2018	08/06/2018	APPROVED		08-06-18 Approved by MTCI inspector Richard Putonti. *JI*
INSPECTION	zn264 - SETBACK INSP- FOUNDATION SURVEY REQ	cgonzalez	07/18/2018	07/18/2018	REJECTED		NO FOUNDATION SURVEY ON SITE
INSPECTION	zn264 - SETBACK INSP- FOUNDATION SURVEY REQ	cgonzalez	08/03/2018	08/03/2018	APPROVED		
INSPECTION	bl981 - STORMWATER, EROSION AND SEDIMENTATION CONTROL	insppp	10/19/2018	10/19/2018	APPROVED		MTCI insp. G. Earl.

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).