



Home Citizen Services Business Services Back to Coral Gables.com

Permits and Inspections: Actions

Logon Help Contact

	ME-21-09-6448	Applied	Approved	Issued	Final	Expires
		09/22/2021	03/29/2022	04/04/2022		05/30/2023

Type **MECH COMMERCIAL / RESIDENTIAL WORK**

Status **stop work**

Permit Description

Permit Address **382 MIRACLE MILE CORAL GABLES FL 33134-5820**

HOOD SYSTEM **CHANGE OF CONT FROM BL-16-02-2424 COMM INTERIOR ALTERATIONS, NEW REAR DOORS, ROOFTOP EQUIP GUARD/SCREEN \$55,000 REVISION-RV17051666- CHANGE OF ARCHITECT & ADDING NEW STOREFRONT TO SCOPE OF WORK ***INSPECTIONS UNDER THIS PERMIT*****

Applicant **HOOD DEPOT INTERNATIONAL INC Owner N**

Owner **VIENTO UNO INC C/O INTERINVESTMENTS REALTY**

Viewing **Actions** <-- Select the information you would like to view.

Group	Action	Approver	Start Date	Comp'd Date	Comp'd Code	Comment
PERMIT PROCESSING	ppappl - APPLICATION/LICENSE/OWNERSHIP VERIFICATION	ahernande2		03/29/2022	COMPLETED	
PERMIT PROCESSING	calc fees2 - CALCULATE FEES	jperez2		03/29/2022	APPROVED	
PERMIT PROCESSING	apmech - MECHANICAL APPLICATION REVIEW	jperez2		03/29/2022	APPROVED	
CASHIER	collect - COLLECT FEES	iwebuser		04/04/2022		
INSPECTION	me001 - FINAL MECHANICAL					
INSPECTION	me001 - FINAL MECHANICAL	tperez	11/23/2022	11/23/2022	REJECTED	.No access to perform the Inspection , No Contrcator at the job site FBCM 110.1 / 105.1 @10:20AM
INSPECTION	me086 - MECHANICAL ROUGH DUCT					
INSPECTION	me086 - MECHANICAL ROUGH DUCT	tperez	04/08/2022	04/08/2022	PARTIAL	Duct Rough inspection Approved Partial , Light Test Inspection Approved highlighted area on plans , ready to insulate with fire wrap the grease duct.
INSPECTION	me086 - MECHANICAL ROUGH DUCT	tperez	04/28/2022	04/28/2022	PARTIAL	.Kitchen hood type 1 grease duct fire wrap insulation installation of the first layer inspection approved.

INSPECTION	me086 - MECHANICAL ROUGH DUCT	tperez	11/23/2022	11/23/2022	REJECTED	.No access to perform the Inspection , No Contrcator at the job site FBCM 110.1 / 105.1 @10:20AM
INSPECTION	me086 - MECHANICAL ROUGH DUCT	tperez	11/30/2022	11/30/2022	REJECTED	.No Access to perform the Inspection , No Contrcator at the job site FBCM 110.1 / 110.5.1 @ 10:05AM
INSPECTION	me116 - MECHANICAL ROUGH VENTILATION DUCTWORK	tperez	04/08/2022	04/08/2022	PARTIAL	Duct Rough inspection Approved Partial , Light Test Inspection Approved highlighted area on plans , ready to insulate with fire wrap the grease duct.
INSPECTION	me116 - MECHANICAL ROUGH VENTILATION DUCTWORK	tperez	04/29/2022	05/01/2022	APPROVED	.Duct Rough inspecction Approved , for Final Inspection 0" Clearance Hood documents/ specs shall be required FBCM 304.1 .Safety guard/railings required to be installed for Final Inspection according to approved plans on site and code regulations FBCM 107.4 / 304.11

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).