



Home Citizen Services Business Services Back to Coral Gables.com

△ Permits and Inspections: Actions

Logon Help Contact

			<input type="text" value="BL-20-01-4520"/>		Applied	Approved	Issued	Final	Expires
					01/14/2020				07/12/2020

Type **INT / EXT ALTERATIONS**

Status **pending**

Permit Description

Permit Address **445 ALHAMBRA CIR CORAL GABLES FL 33134-4901**

**RESIDENTIAL *HISTORIC *REV #1
01/03/2020 *FINAL W/O PRELIMINARY
*PERIMETER METAL FENCE & GATES W/
COLUMNS FACED IN BRICK/ WALKWAY/
AS-BUILT DECORATIVE PORCH WOOD
DETAILS \$30000**

Applicant **ZACHARY SOTO** Owner **Y**

Owner **ZACHARY SOTO**

Viewing <-- Select the information you would like to view.

Group	Action	Approver	Start Date	Comp'd Date	Comp'd Code	Comment
PLAN REVIEW	ppaipp - ART IN PUBLIC PLACES	ccathers		01/17/2020	WAIVED	
PLAN REVIEW	prfire2 - AUTOMATIC SPRINKLER SYSTEM REQUIRED					
PLAN REVIEW	prboa - BOARD OF ARCHITECTS PLAN REVIEW	carguinzon		01/09/2020	APPROVED	
PLAN REVIEW	prbuild - BUILDING PLAN REVIEW	mlopez	01/14/2020	01/14/2020	APPROVED	
PLAN REVIEW	prelec - ELECTRICAL PLAN REVIEW	gmoreno	01/15/2020	01/16/2020	APPROVED	
PLAN REVIEW	prhist - HISTORICAL PLAN REVIEW					
PLAN REVIEW	prhist - HISTORICAL PLAN REVIEW	eguina	02/19/2020	02/21/2020	REJECTED	Please address
PLAN REVIEW	prpubserv - LANDSCAPE PLAN REVIEW					
PLAN REVIEW	prpubserv - LANDSCAPE PLAN REVIEW	dbell	02/06/2020	02/06/2020	REJECTED	1. Show the existing trees in the City swale and inside the property. Existing trees have a tree root protection zone requirement of 1' distance from tree trunk for each 1" trunk radius. Show tree protection fencing around trunks to these dimensions, and shift the location of new concrete columns that are proposed in the tree root protection zones. No digging is permitted in these zones, and no roots larger than 2" can be cut during excavation. 2. Add a note that landscaping must meet the zoning code requirements of article 5, division 11 at the end of construction.
PLAN REVIEW	prplbg - PLUMBING PLAN REVIEW	rperez2		01/17/2020	APPROVED	
PLAN REVIEW	prpworks - PUBLIC WORKS PLAN REVIEW					
PLAN REVIEW	prpworks - PUBLIC WORKS PLAN REVIEW	pezeani	02/12/2020	02/18/2020	REJECTED	ILLUSTRATE PROPERTY LINE ON COLUMN DETAIL.
PLAN REVIEW	prstr - STRUCTURAL PLAN REVIEW					

PLAN REVIEW	prstr - STRUCTURAL PLAN REVIEW	pguth	01/29/2020	02/04/2020	REJECTED	<p>PROVIDE WRITTEN RESPONSES TO ALL COMMENTS AND INCLUDE ALL REQUESTED SUPPLEMENTAL CALCULATIONS. RE-SUBMITTAL WILL NOT BE REVIEWED WITHOUT THIS INFORMATION INCLUDED. AVOID "GENERIC" RESPONSES SUCH AS "SEE PLANS" OR "SEE CALCULATIONS". FOR PLANS, PROVIDE DRAWING NUMBER AND SPECIFIC PLAN, SECTION OR DETAIL. 1) SHEET A2: For the aluminum fence, provide the following information: a) signed-and-sealed calculations verifying that the member sizes shown are adequate to resist the applied wind loads, b) the wall thicknesses of the aluminum members, c) the aluminum alloy, d) the connection to the masonry/brick posts, d) the footing size and reinforcing at the intermediate aluminum posts. As an alternative to the above, the Design Professional shall clearly indicate on the drawings that the fence design is to be delegated to a Florida Registered Professional Engineer and that signed-and-sealed shop drawings and calculations will be submitted to the City of Coral Gables for review prior to fabrication/erection. 2) SHEET A3: For the decorative wood slat column, provide accurate, as-built details showing how the HSS 1x1 steel tubes are connected at the top and bottom (the current written description does not provide sufficient information). In addition, provide the wall thickness of the HSS 1x1 steel tubes. Also, provide information regarding fastener type, size and spacing for wood-wood and wood-steel connections.</p>
PLAN REVIEW	przoning - ZONING PLAN REVIEW					
PLAN REVIEW	przoning - ZONING PLAN REVIEW	edarna	01/23/2020	01/27/2020	DEFERRED	<p>ZONING COMMENTS # 1 1. PLANS THAT SHOW A POOL MUST SHOW A COMPLETE ZONING CODE APPROVED POOL ENCLOSURE WITH FOUR (4') FEET HIGH FENCES AND WITH ALL GATES MECHANICALLY SELF-CLOSING AND SELF-LOCKING. GATES ENCLOSING THE POOL AREA SHALL BE THE SPRING LOCK TYPE, SO THAT THEY SHALL AUTOMATICALLY BE IN CLOSED AND FASTENED POSITION AT ALL TIMES. GATES SHALL ALSO BE EQUIPPED WITH A SAFE LOCK AND SHALL BE LOCKED WHEN THE SWIMMING POOL IS NOT IN USE. SEE ZONING CODE ARTICLE 5, SECTION 5-108 SWIMMING POOL AND</p>

DIVISION 24 FOR WALL AND FENCES REQUIREMENTS. A INDICATE HEIGHT OF EXISTING CONCRETE WALL GARDEN. B THERE IS A GAP ON THE POOL ENCLOSURE FROM THE REAR PROPERTY LINE TO THE WEST PROPERTY LINE. C PROPOSED SLIDING GATES CAN NOT BE CONSIDERED AS PART OF THE POOL ENCLOSURE. 2. WALKWAYS SHALL BE PERMITTED IN THE REQUIRED SETBACK AREAS AS LONG AS THEY DO NOT EXCEED FIVE FEET IN WIDTH. IN ALL CASES 18 INCHES SHALL BE MAINTAINED BETWEEN A WALKWAY AND THE DRIVEWAY. SEE ARTICLE 5, SECTION 5-118 PAVERS AND WALKWAYS. PROPOSED WALKWAY SHALL COMPLY. 3. THE MINIMUM WIDTH OF INGRESS AND EGRESS DRIVEWAYS SHALL MATCH THE ENTRANCE AND EXIT AISLE WIDTH. SEE ARTICLE 5, SECTION 5-1402 GEOMETRIC STANDARDS FOR PARKING AND VEHICULAR USE AREAS. PLANS NEED TO SHOW COORDINATION BETWEEN DRIVEWAY AND APPROACH ON ALHAMBRA. 4. PLANS MUST INDICATE THAT NOTHING WILL BE ERRECTED, PLACED, PARKED, PLANTED, OR ALLOWED TO GROW IN SUCH A MANNER WITHIN A TRIANGLE OF VISIBILITY SO AS TO MATERIALLY IMPEDE VISION BETWEEN A HEIGHT OF 2 ? FEET, AND 8 FEET ABOVE THE ESTABLISHED GRADE, MEASURED AT THE DRIVEWAY OR AT THE TRIANGLE OF VISIBILITY AND INTERSECTION. REVIEW BY: ELISA DARNA ZONING REVIEWER EMAIL: EDARNA@CORALGABLES.COM CITY WEB SITE: WWW.CORALGABLES.COM

- PLAN ppappl - APPLICATION/LICENSE/OWNERSHIP PROCESSING VERIFICATION
- PLAN calc fees - CALCULATE FEES PROCESSING
- PLAN aplist - HISTORICAL APPLICATION PROCESSING REVIEW
- PLAN ppimpfees - MIAMI-DADE COUNTY PROCESSING IMPACT FEES
- CASHIER collect - COLLECT FEES
- LANDSCAPE ppnoc - NOTICE OF PLAN COMMENCEMENT REVIEW
- INSPECTION bl002 - ARCH/ENG REVIEW SOIL CONDITION LETTER
- INSPECTION pw820 - BASE
- INSPECTION pw821 - CONCRETE PERIMETER/STEEL
- INSPECTION zn002 - DRIVEWAY SETBACK
- INSPECTION pw826 - FINAL - D.E.R. M. - LETTER OF APPROVAL
- INSPECTION pw828 - FINAL - P.W. - COASTAL CONSTRUCTION
- INSPECTION bl084 - FINAL BUILDING

INSPECTION fd905 - FINAL FIRE (BLDG PERMIT)
INSPECTION hi773 - FINAL HISTORICAL (BLDG PERMIT)
INSPECTION pw837 - FINAL PUBLIC WORKS (BLDG PERMIT)
INSPECTION zn004 - FINAL ZONING
INSPECTION pwfinal - FINALIZE PERMIT-REFUND BOND IF APPLICABLE
INSPECTION bi091 - FIRE STOPPING 01 FLOOR
INSPECTION bi112 - FOUNDATION ADDITIONS/NEW - SOIL LETTER REQUIRED
INSPECTION bi114 - FRAMING 01 FLOOR
INSPECTION bi171 - INSULATION 01 FLOOR
INSPECTION bi192 - PENETRATION 01 FLOOR
INSPECTION bi245 - SCREW FOR GYPSUM BOARD 01 FLOOR
INSPECTION bi286 - SHOP DRAWING - SHUTTERS
INSPECTION bi291 - SHOP DRAWING - STOREFRONT
INSPECTION bi290 - SHOP DRAWING - WINDOWS
INSPECTION bi311 - STOREFRONT ANCHORS - SHOP DRAWING REQUIRED
INSPECTION pw981 - STORMWATER, EROSION & SEDIMENTATION CONTROL - FINAL
INSPECTION pw807 - SUBGRADE
INSPECTION bi358 - WINDOW/DOOR ANCHORS 01 FLOOR - BUCK INSPECTION REQUIRED
INSPECTION bi375 - WINDOW/DOOR BUCK 01 FLOOR - SHOP DRAWING REQUIRED
PLAN certificat - CERT OF COMPLETION OR OCCUPANCY ISSUANCE

The City's online services are protected with an [SSL encryption certificate](#). For technical assistance, please call 305-569-2448 (8am-5pm, M-F).