

ATLANTIC PROPANE GAS

Commercial / Residential
 "Best Prices in Dade and Broward County"

7105 S.W. 8 Street • Suite 201 • Miami, FL 33144 • Office: 305.264.6600 • Fax: 305.264.6611
 Email: atlanticgas14@yahoo.com

New Customer Documentation Form

Date: 8/22/2014
 Customer Name: Aronas del Peris Customer#: #3069
 Address: 1930 Ponce de Leon Blvd
 City: Coral Gables State: FL Zip: 33134 Tel: 305-476-5885

List All Appliances - Check all that apply and note quantity of each:

<input checked="" type="checkbox"/>	Stove	Qty. <u>1</u>	Serial# <u>2 Burns</u>	<input checked="" type="checkbox"/>	Other List <u>Fisher</u>	Qty. <u>3 (cookrite)</u>
<input checked="" type="checkbox"/>	Space Heater	Qty. <u>1</u>	Serial# <u>Royal</u>	<input checked="" type="checkbox"/>	Other List <u>Wok Range</u>	Qty. <u>1 (IKON)</u>
<input type="checkbox"/>	Water Heater	Qty. <u>X</u>	Serial# <u>X</u>			
<input checked="" type="checkbox"/>	Kitchen Range	Qty. <u>2</u>	Serial# <u>Imperial</u>		<u>(1) 10 Burners (1) 4 Burners</u>	<u>(Royal)</u>
<input type="checkbox"/>	Clothes Dryer	Qty. <u>X</u>	Serial# <u>X</u>			

Tank / Cylinder
3 x 420
 Size

Serial #	Mfr.	Mfr. Date
<u>559228</u>	<u>Manchester</u>	<u>03/2012</u>
<u>559240</u>	<u>Manchester</u>	<u>03/2012</u>
<u>797474</u>	<u>Manchester</u>	<u>07/2014</u>

Regulators
Fisher (1st stage) Make
R622H-265 Model
07/2010 Mfr. Date

Fisher (2nd Stage) Make
R622-DEF Model
05/2010 Mfr. Date

Pressure Test (new piping): Start Pressure _____ psi End Pressure _____ psi Time Held: _____ minutes

Lockup Pressure (1st Stage): 10 psi Lockup Pressure (2nd Stage): 11 inches w.c.

Delivery Pressure (1st Stage): _____ psi Delivery Pressure (2nd Stage): _____ inches w.c.

Leak Check Results:

High Pressure Method: 160 (psi) 150 (psi) 150 (psi) for 10 minutes

(Tank Pressure (TP) less 10 psi TP Start End

Intermediate Pressure Method: _____ (psi) _____ (psi) _____ (psi) for _____ minutes

(System Pressure (SP) less 5 psi TP Start End

Low Pressure Method: _____ (psi) _____ (psi) _____ (psi) for _____ minutes

(9' w.c. +/- 1/2 w.c.) Start End

Comments: According to regulations, a drop test was performed on the line and regulators. The tanks were visually checked and are in very good condition, certify the tanks' very safety.

"I certify that the above noted information and test results are accurate".

Driver/Technician Signature _____ Date: 8/22/2014

Customer Acknowledgment:

- I know how to turn off my gas supply in an emergency.
- I have smelled propane and can detect its odor.
- I have received the following brochure. "Important Safety Information for you and your Family", part #PRC003121, or "Propane Safety", part #PRC005606.
- I understand that my gas company representative did conduct a complete inspection of my entire gas system. I understand this inspection covered propane /LP Gas items and equipment visible and accessible to the service technician and represents the conditions existing on the date of the inspection and does NOT cover latent or manufacturing defects, the internal workings of sealed equipment or structural components or vent systems and can not be construed to cover future unforeseen happenings.
- All Pilots are lit and I am satisfied with the services performed.

Customer's Signature _____

Date: August 22nd 2014