

May 21, 2014

Ernesto R. Pino, R.A.  
Interim Public Works Director  
Public Works Department  
City of Coral Gables, Florida  
2800 SW 72nd Avenue  
Miami, FL 33155

Re: Youth Center Ball Field Lighting – Proposal Review


Dear Mr. Pino:

Please know that we are in receipt of the lighting manufacturer proposal for the equipment and installation dated May 15<sup>th</sup>, 2014. It was reviewed by our engineering group specifically to determine if the scope addresses the deficiencies previously identified by the structural evaluation that was completed by our firm. It was also reviewed to determine if the proposal is consistent with the conclusions specified in the Outdoor Ball Field Lighting Evaluation (dated March 5<sup>th</sup>, 2014) that was also completed for your office.

This proposal considers the use of high intensity discharge (HID) light sourcing as the replacement equipment with a cost commensurate to the scope of the work for this project. It also addresses the recommendations of the structural evaluation with a combination of replacing and repairing the pole structures. The five most structurally distressed poles identified in the evaluation are presumed to be the poles that would undergo replacement and the remaining nine poles will undergo the minor reconditioning as described in the recommendations. This approach is considered adequate for addressing the deficiencies. As such, it would therefore be advisable to consider this bid proposal as satisfactory in achieving the objectives described in the evaluation.

Please feel free to contact me with any further questions or comments that you may have.

Sincerely,



Juan Carlos Hernandez, PE  
Senior Associate