9/13/22, 5:04 PM Actions



**Permits and Inspections: Actions** 

**Business Services Back to Coral Gables.com** 

BL-17-02-0213

Logon Applied Approved **Issued** Final **Expires** 02/03/2017 03/07/2017 02/28/2017 08/02/2018

Help

Contact

Type POOL / SPA / FOUNTAIN / POND

Status stop work Permit Address 522 SAN LORENZO AVE CORAL GABLES FL 33146-1341 Permit Description

SWIMMING POOL, SPA & PAVER POOL

Applicant ARCHIE CONSTRUCTION Owner N

**DECK \$21,000** Owner TOBY SCOTT BARNHART CAROL FERN

| DECK \$21,000                     | Owner TOBY SCOTT BARNHART CAROL FERN   |         |                         |               |                          |                |   |  |  |
|-----------------------------------|--|---------|-------------------------|---------------|--------------------------|----------------|---|--|--|
| Viewing Actions                   | < Select the information you would like to view.                               |         |                         |               |                          |                |   |  |  |
| Group                             | Action   |         | Approver                | Start<br>Date | Comp'd<br>Date           | Comp'd<br>Code | Comment   |  |  |
| PLAN REVIEW                       | prboa - BOARD OF ARCHITECTS<br>PLAN REVIEW                                     |         | jray                    | ,             | 02/02/2017               | APPROVED       |   |  |  |
| PLAN REVIEW                       | prbuild - BUILDING PLAN R  | EVIEW   | mlopez                  | 02/22/2017    | 02/23/2017               | APPROVED       |   |  |  |
| PLAN REVIEW                       | prelec - ELECTRICAL PLAN REVIEW  |         | areyes                  | 02/06/2017    | 02/06/2017               | APPROVED       |   |  |  |
| PLAN REVIEW                       | prplbg - PLUMBING PLAN R   | EVIEW   | rperez2                 | 02/03/2017    | 02/03/2017               | REJECTED       | 1- SHOW<br>COMPLIANCE<br>FOR CHANNEL<br>DRAINS -F.B.C<br>RES. P4501.6.6<br>& VGB  |  |  |
| PLAN REVIEW                       | prplbg - PLUMBING PLAN R   | EVIEW   | rperez2                 | 02/06/2017    | 02/27/2017               | APPROVED       | see attached<br>document for<br>linear drain  |  |  |
| PLAN REVIEW                       | prpworks - PUBLIC WORKS<br>REVIEW  | PLAN    | emunoz                  | 02/21/2017    | 02/21/2017               | APPROVED       |   |  |  |
| PLAN REVIEW                       | prstr - STRUCTURAL PLAN I  | REVIEW  | dreczek                 | 02/16/2017    | 02/17/2017               | APPROVED       |   |  |  |
| PLAN REVIEW                       | przoning - ZONING PLAN R   | EVIEW   | awhitmore               | 02/07/2017    | 02/16/2017               | DEFERRED       | 1. THE POOL PATIO IS NOT IN COORDINATION WITH THE MASTER PERMIT. THE PATIO IS RESTRICTED BY THE SAME SIDE SETBACKS AS THE MAIN RESIDENCE. THE EXTENSION ON THE WEST SIDE NEXT TO THE GAZEBO IS NOT ALLOWED. SEE NOTATION ON THE OFFICE SET FOR AREA IN QUESTION. 2. FURTHER REVIEW REQUIRED UPON RESUBMITTAL. |  |  |
| PLAN REVIEW<br>PLAN<br>PROCESSING | przoning - ZONING PLAN R<br>ppappl -<br>APPLICATION/LICENSE/OW<br>VERIFICATION |         | awhitmore<br>carguinzon | 02/27/2017    | 02/28/2017<br>03/07/2017 |                | MISSING THE<br>PERMIT<br>APPLICATION<br>W/ THE<br>CONTRACT<br>COST OF THE<br>JOB.   |  |  |
| PLAN<br>PROCESSING                | ppappl -<br>APPLICATION/LICENSE/OW<br>VERIFICATION                             | NERSHIP | ebermudez1              |               | 03/07/2017               | COMPLETED      |   |  |  |

| PLAN<br>PROCESSING     | calc fees - CALCULATE FEES                               | carguinzon |            | 03/07/2017 | INCOMPLETE | NEED THE<br>CONTRACT<br>COST OF THE<br>JOB.               |
|------------------------|--|------------|------------|------------|------------|---|
| PLAN<br>PROCESSING     | calc fees - CALCULATE FEES                               | ebermudez1 |            | 03/07/2017 | COMPLETED  |   |
| PLAN<br>PROCESSING     | pppoolencl - PROTECTIVE<br>ENCLOSURE FORM - POOL/SPA     | carguinzon |            | 03/07/2017 | COMPLETED  |   |
| CASHIER                | collect - COLLECT FEES                                   | iwebuser   |            | 03/07/2017 |            |   |
| NOTICE OF COMMENCEMENT | ppnoc - NOTICE OF COMMENCEMENT                           | ebermudez1 |            | 03/09/2017 | COMPLETED  |   |
| INSPECTION             | bl084 - FINAL BUILDING                                   |            |            |            |            |   |
| INSPECTION             | pw837 - FINAL PUBLIC WORKS<br>(BLDG PERMIT)              |            |            |            |            |   |
| INSPECTION             | zn004 - FINAL ZONING                                     |            |            |            |            |   |
| INSPECTION             | bl213 - POOL STEEL & MAIN DRAIN                          | emartin    | 03/22/2017 | 03/22/2017 | REJECTED   | need to<br>pressurize<br>plumbing main<br>drain pipes. EM |
| INSPECTION             | bl213 - POOL STEEL & MAIN DRAIN                          | emartin    | 03/23/2017 | 03/23/2017 | APPROVED   |   |
| INSPECTION             | zn264 - SETBACK INSP-<br>FOUNDATION SURVEY REQ           | cgonzalez  | 03/10/2017 | 03/10/2017 | APPROVED   |   |
| INSPECTION             | bl981 - STORMWATER, EROSION<br>AND SEDIMENTATION CONTROL |            |            |            |            |   |

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).