



NOVI-24-06-8104



City of Coral Gables
Code Enforcement Division
427 Biltmore Way, Suite 100



SCAN ME
Need to search or
appeal your citation?

4706 BROOKER ST.
Notice of Violation

October 3, 2024

WESLI RIY-VES EST OF
PO BOX 348702
MIAMI, FL 33234

10/3/24

Case #:NOVI-24-06-8104

Folio #: 0341200061080

Dear Property Owner and/or Occupant:

This letter constitutes a notice that a violation(s) exists on the premises at:

4706 BROOKER ST, Coral Gables, FL 33133--4819

The violation(s) found was:

Floors, walls, ceilings and roofs - Sec. 105-278. - Floors, walls, ceilings and roofs.
Floors, walls, ceilings and roofs of every structure used for human habitation shall be structurally
sound, and maintained in a clean and sanitary condition. They shall be free from cracks, breaks,
loose plaster and similar conditions so serious as to endanger the safety of occupants or to
seriously mar the attractiveness of the premises.


(Code 1958, § 16A-36; Code 1991, § 12-178; Code 2006, § 105-289; Ord. No. 1142, § 4.5, 7-14-1959;
Ord. No. 2013-07, § 2, 5-28-2013)

Code Enforcement Officer Comments: Carport roof has rotting wood and flaking paint and in need
of repairs, exterior walls are dirty and need to be pressure cleaned or painted, windows and doors
are covered with plywood and metal shutters.

The following steps should be taken to correct the violation:

Comply with Section 105-278 - repair and paint carport roof, clean or prep and paint dirty exterior
walls, remove plywood and metal shutters from covered windows and doors and implement
necessary repairs; A permit is required.

The regulations enforced by the City have been adopted in order to protect the public and assure continuing high
property values. Your immediate attention to correcting the violation(s) listed above is required.

The Code Enforcement Division will re-inspect the property on 11/3/2024 to determine if corrective measures
have been completed. If the violation(s) has not been completed at the time of inspection, your case will be
presented to the Code Enforcement Board for review and possible action. At that time, you will have the
opportunity to explain to the citizens serving on the Board the reasons why the violation(s) has not been
corrected. The Board has the authority to assess a fine against you for as long as the violation continues.

The Division is available for consultation on this matter from 7:30 AM to 4:00 PM. Please do not hesitate to call
the Code Enforcement Officer below for additional assistance or the Code Enforcement Hot-line at 305-441-
5777. or see us in person at 427 Biltmore Way, 2nd Floor, Coral Gables FL, 33134.

Vazquez, Thomas

tvazquez@coralgables.com

305-849-5506

10-03-2024 04:06 PM