

City of Coral Gables

Code Enforcement Division 427 Biltmore Way, Suite 100



Folio #: 0341170084360

Code Enforcement Violation Warning

September 2, 2025 Case #:NOVI-25-09-11541

HUMBERTO AUBI TR 1100 MADRD ST CORAL GABLES, FL 33134-2212

Dear Property Owner and/or Occupant:

As part of an ongoing effort to enhance the health, safety, and welfare of the citizens of Coral Gables, a recent inspection was made to the premises at:

406 MALAGA AVE, Coral Gables, FL 33134---6560

At that time, a Code Enforcement Officer found the following violation(s) evident on the property:

Outdoor Lighting - Section 12-102. Outdoor lighting permitted with standards
Outdoor lighting for areas such as but not limited to, tennis courts, golf courses, sporting
grounds, outside lighting for security purposes and night lighting of commercial buildings, any of
which abut residential areas shall be permitted under the following conditions:

A. A permit for outdoor lighting may be issued if, after review of the plans and after consideration of the

adjacent area and residential uses, the proposed lighting will be deflected, shaded and focused away from adjacent properties and will not be a nuisance to such adjacent properties.

B. Outdoor lighting shall be designed so that any overspill of lighting onto adjacent properties shall not exceed one-half ($\frac{1}{2}$) foot-candle (vertical) and one-half ($\frac{1}{2}$) foot candle (horizontal) illumination on adjacent properties.

Code Enforcement Officer Comments: Outdoor lighting was observed with glare and reflection extending beyond the property line.

The following steps should be taken to correct the violation:

Must install and appropriate shielding or covering on the outdoor light fixture to ensure that illumination is directed downward and contained within the property line. Comply with Section 12-102

Coral Gables has earned the title of "The City Beautiful" with the help of the residents. Your immediate cooperation in correcting the violation(s) listed above would be gratefully appreciated.

The Code Enforcement Division will re-inspect the property on 9/17/2025 to determine if corrective measures have been completed. If corrective measures have not been completed by 9/17/2025, a Notice of Violation and/or citation will be issued.

The Division is available for consultation on this matter from 7:30 AM to 4:00 PM. Please do not hesitate to call Salvador Sole at 305-733-0274 for additional assistance or the Code Enforcement Hot-line at 305-441-5777. or see us in person at 427 Biltmore Way, 2nd Floor, Coral Gables FL, 33134.

305-733-0274