

CITY OF CORAL GABLES, FLORIDA

RESOLUTION _____

A RESOLUTION AUTHORIZING AN EMERGENCY PURCHASE FOR THE REPLACEMENT OF TRANE CHILLER NO. 1'S ADAPTIVE FREQUENCY DRIVE (AFD) POWER MODULE COMPONENT AT THE PUBLIC SAFETY BUILDING (PSB), 2151 SALZEDO STREET, PURSUANT TO SECTION 2-690 EMERGENCY PROCUREMENT, OF THE CITY'S PROCUREMENT CODE IN THE AMOUNT OF \$141,094.

WHEREAS, the PSB's chiller no. 1 has failed due to complications with the adaptive frequency drive (AFD) power module component; and

WHEREAS, currently, chiller no. 2 has been running at 100% to compensate for the failed chiller; and

WHEREAS, the Trane company has rebuilt chiller no. 1 under warranty however Trane claims this component is not covered. Currently, the City Attorney's Office is looking into possible legal options; and

WHEREAS, currently, the City Attorney's Office is looking into possible legal options; and

WHEREAS, to avoid disruptions to the building's air conditioning, it is recommended repairs are made expeditiously.

NOW THEREFORE BE IT RESOLVED BY THE COMMISSION OF THE CITY OF CORAL GABLES:

Section 1. The foregoing "Whereas" clauses are hereby ratified and confirmed as being true and correct and are hereby made a specific part of this Resolution upon adoption hereof.

Section 2. That the City Commission approve the emergency repairs in the amount of \$25,387 for this project, pursuant to Section 2-690 of the City's Procurement Code.

Section 3. That this Resolution shall become effective upon the date of its adoption herein.

PASSED AND ADOPTED THIS TWENTY-SEVENTH DAY OF FEBRUARY 2024.

(Moved by _____, Seconded by _____)
(Passed 0/0 vote)

VINCE C. LAGO
MAYOR

ATTEST:

BILLY Y. URQUIA
CITY CLERK

APPROVED AS TO FORM AND
LEGAL SUFFICIENCY:

CRISTINA M. SUAREZ
CITY ATTORNEY