

Type:	FBC Building (Commercial)- Other	Status:	Denied	Project Name:	
Applied Date:	03/31/2025	Issue Date:			
District:	City of Coral Gables	Expire Date:			
Square Feet:	0.00	Valuation:	\$1,500.00	Finalized Date:	
Description:	PLEASE REFER TO REPLACE FRONT ENTRANCE STAIR STEPS TILES				

- Summary
- Locations
- Fees
- Reviews
- Inspections
- Attachments
- Contacts
- Sub-Records
- More Info

FBC - Building Interior Alteration

Submittal Status	Received Date	Due Date	Completed Date
Requires Re-submit	04/02/2025	04/30/2025	04/30/2025

! Fire • Disapproved • Gagliano - Fire Reviewer Frank • Completed : 04/08/2025

Due Date	Completed Date
04/30/2025	04/08/2025

Correction (1)

Correction Type	Fire Correction	Category	Fire Correction
Corrective Action	Provide note for referenced codes to reflect the Florida Fire Prevention Code 8th Ed. Provide detail of new stair ability to comply with NFPA 101 7.2.2		