



City of Coral Gables
CITY COMMISSION MEETING
May 19, 2026

ITEM TITLE:

A Resolution authorizing the ratification of emergency work performed by Jomark Equipment and Consulting Inc. for sewer main fitting connection repairs at the canal crossing (Lugo Avenue Canal Bridge), pursuant to Section 2-690 Emergency Procurement, in the amount of \$113,500.

DEPARTMENT HEAD RECOMMENDATION:

Approval.

BRIEF HISTORY:

A fitting connection on the 6-inch sewer force main at the canal crossing (Lugo Avenue Canal Bridge) failed. To prevent a wastewater discharge, emergency repairs were initiated immediately, requiring the removal and replacement of approximately 90 feet of 6-inch force main piping.

Under Section 2-690 of the Procurement Code, entitled "Emergency Procurement," where the City Manager authorizes the emergency procurements of supplies, services, or construction when there exists an immediate threat to public health, welfare, or safety or to prevent or minimize serious disruption of government services.

FINANCIAL INFORMATION:

No.	Amount	Account No.	Source of Funds
1.	\$113,500	410-1660-535-6350	Lugo Bridge FM - SSF
Total:	\$113,500		

Fiscal Impact:

The necessary repairs and use of emergency procurement minimized the impact of scheduled programming of this sewer force main.

ATTACHMENT (S):

1. Resolution
2. Emergency Procurement
3. Proposal