Actions Page 1 of 2



Citizen Services **Business Services Back to Coral Gables.com** Home **Permits and Inspections: Actions** Contact Logon Help **Applied Issued Final Expires Approved** PL-18-11-2558 11/02/2018 05/01/2019 PLUMB COMMERCIAL / Status pending Type **RESIDENTIAL WORK** Permit Description Permit Address 750 SAN JUAN DR CORAL GABLES FL 33143-6225 PLUMBING GAS WORK { PROPANE } FOR Applicant PAUL DI CAPUA Owner Y (1) A.G. GAS TANK, GAS RANGE **CONNECTION & PIPING *** (AFTER THE** Owner PAUL DI CAPUA **FACT)** *** Viewing Actions <-- Select the information you would like to view. Start Comp'd Comp'd Group Action Comment Approver **Date Date** Code PERMIT jpino ppappl -11/02/2018 COMPLETED APPLICATION/LICENSE/OWNERSHIP **PROCESSING** VERIFICATION **PERMIT** calc fees2 - CALCULATE FEES PROCESSING PERMIT applbg - PLUMBING APPLICATION **PROCESSING** REVIEW PERMIT applbg - PLUMBING APPLICATION 11/05/2018 REJECTED 1- REQUIRED GAS rperez2 PROCESSING REVIEW CONTRACTOR FOR APPLICATION SUBMITTED AND SIGNATURE BY QUALIFIER PERMIT prplbg - PLUMBING PLAN REVIEW **PROCESSING** PERMIT prplbg - PLUMBING PLAN REVIEW 11/05/2018 **REJECTED** 1- REQUIRED ZONING rperez2 **PROCESSING APPROVAL PERMIT** przoning - ZONING PLAN REVIEW **PROCESSING** ZONING COMMENT #1 1. ALL **PERMIT** przoning - ZONING PLAN REVIEW 11/07/2018 11/09/2018 DEFERRED edarna **PROCESSING** ABOVE GROUND GAS TANKS MUST COMPLY WITH THE REQUIRED SETBACKS. NEED TO PROVIDE A SITE PLAN WITH BOTH SIDE SETBACKS DIMENSIONS TO PROPOSED GAS TANK. 2. PROPOSED GAS TANK WILL REQUIRE BOA APPROVAL FOR MECHANICAL SCREENING. GAS TANK MUST BE SCREENED FROM STREET VIEW, REVIEW BY: ELISA DARNA ZONING REVIEWER EMAIL: EDARNA@CORALGABLES.COM CITY WEB SITE: WWW.CORALGABLES.COM **CASHIER** collect - COLLECT FEES NOTICE OF ppnoc - NOTICE OF COMMENCEMENT COMMENCEMENT INSPECTION hi773 - FINAL HISTORICAL (BLDG PERMIT) INSPECTION pl001 - FINAL PLUMBING INSPECTION pl062 - PLUMBING ROUGH INSPECTION pl103 - PLUMBING SEWER CONNECTION INSPECTION pl130 - PLUMBING WATER PIPING

Actions Page 2 of 2

INSPECTION pl147 - PLUMBING WATER SERVICE

The City's online services are protected with an **SSL encryption certificate**. For technical assistance, please call 305-569-2448 (8am-5pm, M-F).